

June 17, 2014

VIA ELECTRONIC FILING

Veronique Dubois
Régie de l'énergie
Tour de la Bourse
800, Place Victoria
Bureau 255
Montréal, Québec H4Z 1A2

Re: *North American Electric Reliability Corporation*

Dear Ms. Dubois:

On February 21 2014, the North American Electric Reliability Corporation (“NERC”) filed a Notice of Filing of proposed Reliability Standard PRC-005-3. References to “Automatic Reclosing” and “Component” used in certain definitions in PRC-005-3 were not properly capitalized during the revision process. NERC intended for the terms to carry the meaning associated with the definitions of “Automatic Reclosing” and “Component.” The correct capitalization in the definitions used in PRC-005-3 are as follows:

- **Protection System Maintenance Program (PSMP)** — An ongoing program by which Protection System and ~~automatic~~ Automatic reclosing ~~Reclosing components~~ Components are kept in working order and proper operation of malfunctioning ~~components~~ Components is restored. A maintenance program for a specific ~~component~~ Component includes one or more of the following activities:

Verify—Determine that the ~~component~~ Component is functioning correctly.

Monitor—Observe the routine in-service operation of the ~~component~~ Component.

Test—Apply signals to ~~component~~ Component to observe functional performance or output behavior, or to diagnose problems.

Inspect—Examine for signs of ~~component~~ Component failure, reduced performance or degradation.

Calibrate—Adjust the operating threshold for measurement accuracy of a measuring element to meet the intended performance requirement.

3353 Peachtree Road NE
Suite 600, North Tower
Atlanta, GA 30326
404-446-2560 | www.nerc.com

- **Unresolved Maintenance Issue**—A deficiency identified during a maintenance activity that causes the ~~component~~ Component to not meet the intended performance, cannot be corrected during the maintenance interval, and requires follow-up corrective action

NERC has updated the standard version number to reflect the errata change and will update the *NERC Glossary of Terms*. NERC has also updated the VSL in Requirement R1 to match the change directed to PRC-005-2 filed concurrently with this errata. A replacement Exhibit A to the filing is included.

Respectfully submitted,

/s/ William H. Edwards

William H. Edwards
Counsel
North American Electric Reliability
Corporation
1325 G St., NW, Suite 600
Washington, DC 20005
(202) 400-3000
(202) 644-8099 – facsimile
william.edwards@nerc.net

Exhibit A

PRC-005-3 Clean and Redline Standard

(Available on the NERC Website at

http://www.nerc.com/FilingsOrders/ca/Canadian%20Filings%20and%20Orders%20DL/Attachments_PR_C-005-3_Errata_filing.pdf)