

Approved by Stakeholders: September 1, 2007

Approved by NERC Board of Trustees: October 23, 2007

Interpretation of BAL-001-0 — Real Power Balancing Control Performance, Requirement 1 and BAL-003-0 — Frequency Response and Bias, Requirement 3

Request for Interpretation received from WECC on June 1, 2007:

Does the WECC Automatic Time Error Control Procedure (WATEC) violate Requirement 1 of BAL-001-0 or Requirement 3 of BAL-003-0?

Interpretation provided by NERC Resources Subcommittee on July 6, 2007:

Requirement 1 of BAL-001 — Real Power Balancing Control Performance, is the definition of the area control error (ACE) equation and the limits established for Control Performance Standard 1 (CPS1).

BAL-001-0

R1. Each Balancing Authority shall operate such that, on a rolling 12-month basis, the average of the clock-minute averages of the Balancing Authority's Area Control Error (ACE) divided by 10B (B is the clock-minute average of the Balancing Authority Area's Frequency Bias) times the corresponding clock-minute averages of the Interconnection's Frequency Error is less than a specific limit. This limit ϵ_{12} is a constant derived from a targeted frequency bound (separately calculated for each Interconnection) that is reviewed and set as necessary by the NERC Operating Committee.

- The WATEC procedural documents ask Balancing Authorities to maintain raw ACE for CPS reporting and to control via WATEC-adjusted ACE.
- As long as Balancing Authorities use raw (unadjusted for WATEC) ACE for CPS reporting purposes, the use of WATEC for control is not in violation of BAL-001 Requirement 1.

Requirement 3 of BAL-003-0 — Frequency Response and Bias deals with Balancing Authorities using Tie-Line Frequency Bias as the normal mode of automatic generation control.

BAL-003-0

R3. Each Balancing Authority shall operate its Automatic Generation Control (AGC) on Tie Line Frequency Bias, unless such operation is adverse to system or Interconnection reliability.

- Tie-Line Frequency Bias is one of the three foundational control modes available in a Balancing Authority's energy management system. (The other two are flat-tie and flat-frequency.) Many Balancing Authorities layer other control objectives on top of their basic control mode, such as automatic inadvertent payback, CPS optimization, time control (in single BA Interconnections).
- As long as Tie-Line Frequency Bias is the underlying control mode and CPS1 is measured and reported on the associated ACE equation, there is no violation of BAL-003-0 Requirement 3:

$$ACE = (NI_A - NI_S) - 10B (F_A - F_S) - I_{ME}$$