

Implementation Plan for BAL-003-1 – Frequency Response & Frequency Bias Setting Standard

Prerequisite Approvals

There are no other reliability standards or Standard Authorization Requests (SARs), in progress or approved, that must be implemented before this standard can be implemented.

Modified Standards

BAL-003-0.1b should be retired midnight of the day immediately prior to the Effective Date of BAL-003-1 in the Jurisdiction in which the new standard is becoming effective.

New or Modified Definitions

The following definitions shall become effective when BAL-003-1 Requirements R2, R3, R4 and R5 become effective:

Frequency Response Measure (FRM): The median of all the Frequency Response observations reported annually by Balancing Authorities for frequency events specified by the ERO. This will be calculated as MW/0.1Hz.

Frequency Response Obligation (FRO): The Balancing Authority's share of the required Frequency Response needed for the reliable operation of an Interconnection. This will be calculated as MW/0.1Hz.

Frequency Bias Setting: A number value, either fixed or variable, usually expressed in MW/0.1 Hz, included in set into a Balancing Authority's Area Control Error equational algorithm to account for that allows the Balancing Authority's inverse Frequency Response contribution to contribute its frequency response to the Interconnection, and discourage withdrawal through secondary control systems.

Frequency Response Sharing Group (FRSG): A group whose members consist of two or more Balancing Authorities that collectively maintain, allocate, and supply operating resources required to jointly meet the Frequency Response Obligations of its members.

The existing definition of Frequency Bias Setting should be retired midnight of the day immediately prior to the Effective Date of BAL-003-1 in the Jurisdiction in which the new standard is becoming effective.

February 21, 2012

116-390 Village Boulevard, Princeton, New Jersey 08540-5721

Phone: 609.452.8060 • Fax: 609.452.9550 • www.nerc.com

The proposed revised definition for “Frequency Bias Setting” is incorporated in the following NERC approved standards:

- BAL-001-0.1a Real Power Balancing Control Performance
- BAL-004-0 Time Error Correction
- BAL-004-1 Time Error Correction
- BAL-005-0.1b Automatic Generation Control

Compliance with Standards

Once this standard becomes effective, the responsible entities identified in the applicability section of the standard must comply with the requirements. These include:

- Balancing Authorities
- Frequency Response Sharing Groups

Proposed Effective Date

Compliance with BAL-003-1 shall be implemented over a two-year period, as follows:

- In those jurisdictions where regulatory approval is required, Requirements R2, R3 and R4 of this standard shall become effective the first calendar day of the first calendar quarter 12 months after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, Requirements R2, R3 and R4 of this standard shall become effective the first calendar day of the first calendar quarter 12 months after Board of Trustees adoption.
- In those jurisdictions where regulatory approval is required, Requirements R1 of this standard shall become effective the first calendar day of the first calendar quarter 24 months after applicable regulatory approval. In those jurisdictions where no regulatory approval is required, Requirements R1 of this standard shall become effective the first calendar day of the first calendar quarter 24 months after Board of Trustees adoption.
- Requirement R1 cannot be implemented prior to the addition of Frequency Response Sharing Group to the Compliance Registry.