

Implementation Plan for Newly identified Automatic Reclosing Components due to generation changes in the Balancing Authority Area

Project 2007-17.2 Protection System Maintenance and Testing - Phase 2
(Reclosing Relays)

This applies to PRC-005-3 and successor standards.

Additional applicable Automatic Reclosing Components may be identified because of the addition or retirement of generating units; or increases of gross generation capacity of individual generating units or plants within the Balancing Authority area.

In such cases, the responsible entities must complete the maintenance activities, described in Table 4, for the newly identified Automatic Reclosing Components prior to the end of the following calendar year unless documented prior maintenance fulfilling the requirements of Table 4 is available.