

## Table of Issues and Directives

Project 2007-17.2 PRC-005-3

Protection System and Automatic Reclosing Maintenance

Table of Issues and Directives Associated with PRC-005-3

Source	Directive Language (including pg #)	Disposition	Section and/or Requirement(s)
FERC Order 758	27. We note that the original project to revise Reliability Standard PRC-005 failed a recirculation ballot in July of 2011. The project was subsequently reinitiated to continue the efforts to develop Reliability Standard PRC-005-2. Given that the project to draft proposed revisions to Reliability Standard PRC-005-1 continues in this reinitiated effort, and the importance of maintaining and testing reclosing relays, we direct NERC to include maintenance and testing of reclosing relays that can affect the reliable operation of the Bulk-Power System, as discussed above, within these reinitiated efforts to revise Reliability Standard PRC-005.	Specific minimum activities and maximum allowable intervals are included in the draft standard within Table 4.	Applicability 4.2.6 Requirement R1, R3, Requirement R4, Table 4