

# Implementation Plan

## Project 2010-14.1 Balancing Authority Reliability-based Controls - Reserves

Implementation Plan for BAL-002-2 – Disturbance Control Performance - Contingency Reserve for Recovery from a Balancing Contingency Event

### *Approvals Required*

BAL-002-2 – Disturbance Control Performance - Contingency Reserve for Recovery from a Balancing Contingency Event

### *Prerequisite Approvals*

None

### *Revisions to Glossary Terms*

The following definitions shall become effective when BAL-002-2 becomes effective:

**Balancing Contingency Event:** Any single event described in Subsections (A), (B), or (C) below, or any series of such otherwise single events, with each separated from the next by less than one minute.

- A. Sudden Loss of generation:
  - a. Due to
    - i. Unit tripping,
    - ii. Loss of generator Interconnection Facility resulting in isolation of the generator from the Bulk Electric System or from the responsible entity's electric system, or
    - iii. Sudden unplanned outage of transmission Facility yes;
  - b. And, that causes an unexpected change to the responsible entity's ACE;
- B. Sudden loss of an Import, due to forced outage of transmission equipment that causes an unexpected imbalance between generation and load on the Interconnection ~~change to the responsible entity's ACE.~~
- C. Sudden restoration loss of a ~~known~~ load that was used as a resource that causes an unexpected change to the responsible entity's ACE.

**Most Severe Single Contingency (MSSC):** The Balancing Contingency Event, due to a single contingency, that would result in the greatest loss (measured in MW) of resource output used by the Reserve Sharing Group (RSG) or a Balancing Authority that is not participating as a member of a RSG at the time of the event to meet firm system load and export obligation (excluding export obligation for which Contingency Reserve obligations are being met by the sink Balancing Authority).

**Reportable Balancing Contingency Event:** Any Balancing Contingency Event resulting in a loss of MW output greater than or equal to the lesser amount of 80 percent of the Most Severe Single Contingency, or the amount listed below for the applicable Interconnection~~500 MW~~ and occurring within a rolling one-minute interval based on EMS scan rate data. The 80% threshold may be reduced upon written notification to the Regional Entity.

- Eastern Interconnection – 900 MW
- Western Interconnection – 500 MW
- ERCOT – 800 MW
- Quebec – 500 MW

**Contingency Event Recovery Period:** A period beginning at the time that the resource output begins to decline within the first one-minute interval that defines a Balancing Contingency Event, and extends for fifteen minutes thereafter.

**Contingency Reserve Restoration Period:** A period not exceeding 90 minutes following the end of the Contingency Event Recovery Period.

**Pre-Reportable Contingency Event ACE Value:** The average value of Reporting ACE, or Reserve Sharing Group Reporting ACE when applicable, in the 16 second interval immediately prior to the start of the Contingency Event Recovery Period based on EMS scan rate data.

**Reserve Sharing Group Reporting ACE:** At any given time of measurement for the applicable Reserve Sharing Group, the algebraic sum of the ACEs (or equivalent as calculated at such time of measurement) of ~~all of~~ the Balancing Authorities participating in that make up the Reserve Sharing Group at the time of measurement.

**Contingency Reserve:** The provision of capacity that may be deployed by the Balancing Authority to respond to a Balancing Contingency Event and other ~~NERC~~ contingency requirements (such as Energy Emergency Alerts Level 2 or Level 3). The capacity may be provided by resources such as Demand Side Management (DSM), Interruptible Load and unloaded generation.

Reporting ACE: The scan rate values of a Balancing Authority's Area Control Error (ACE) measured in MW, which includes the difference between the Balancing Authority's Net Actual Interchange

and its Net Scheduled Interchange, plus its Frequency Bias obligation, plus any known meter error. In the Western Interconnection, Reporting ACE includes Automatic Time Error Correction (ATEC).

Reporting ACE is calculated as follows:

$$\text{Reporting ACE} = (NI_A - NI_S) - 10B (F_A - F_S) - I_{ME}$$

Reporting ACE is calculated in the Western Interconnection as follows:

$$\text{Reporting ACE} = (NI_A - NI_S) - 10B (F_A - F_S) - I_{ME} + I_{ATEC}$$

Where:

**NI<sub>A</sub> (Actual Net Interchange)** is the algebraic sum of actual megawatt transfers across all Tie Lines and includes Pseudo-Ties. Balancing Authorities directly connected via asynchronous ties to another Interconnection may include or exclude megawatt transfers on those Tie Lines in their actual interchange, provided they are implemented in the same manner for Net Interchange Schedule.

**NI<sub>S</sub> (Scheduled Net Interchange)** is the algebraic sum of all scheduled megawatt transfers, including Dynamic Schedules, with adjacent Balancing Authorities, and taking into account the effects of schedule ramps. Balancing Authorities directly connected via asynchronous ties to another Interconnection may include or exclude megawatt transfers on those Tie Lines in their scheduled Interchange, provided they are implemented in the same manner for Net Interchange Actual.

**B (Frequency Bias Setting)** is the Frequency Bias Setting (in negative MW/0.1 Hz) for the Balancing Authority.

**10** is the constant factor that converts the Frequency Bias Setting units to MW/Hz.

**F<sub>A</sub> (Actual Frequency)** is the measured frequency in Hz.

**F<sub>S</sub> (Scheduled Frequency)** is 60.0 Hz, except during a time correction.

**I<sub>ME</sub> (Interchange Meter Error)** is the meter error correction factor and represents the difference between the integrated hourly average of the net interchange actual (NIA) and the cumulative hourly net interchange energy measurement (in megawatt-hours).

**I<sub>ATEC</sub> (Automatic Time Error Correction)** is the addition of a component to the ACE equation for the Western Interconnection that modifies the control point for the purpose of continuously paying back Primary Inadvertent Interchange to correct accumulated time error. Automatic Time Error Correction is only applicable in the Western Interconnection.

$$I_{ATEC} = \frac{PII_{accum}^{on/off\ peak}}{(1-Y)*H} \text{ when operating in Automatic Time Error Correction control mode.}$$

I<sub>ATEC</sub> shall be zero when operating in any other AGC mode.

- Y = B / B<sub>S</sub>.
- H = Number of hours used to payback Primary Inadvertent Interchange energy. The value of H is set to 3.

- $B_S$  = Frequency Bias for the Interconnection (MW / 0.1 Hz).
- Primary Inadvertent Interchange ( $PII_{hourly}$ ) is  $(1-Y) * (I_{actual} - B * \Delta TE/6)$
- $I_{actual}$  is the hourly Inadvertent Interchange for the last hour.
- $\Delta TE$  is the hourly change in system Time Error as distributed by the Interconnection Time Monitor. Where:  
 $\Delta TE = TE_{end\ hour} - TE_{begin\ hour} - TD_{adj} - (t)*(TE_{offset})$
- $TD_{adj}$  is the Reliability Coordinator adjustment for differences with Interconnection Time Monitor control center clocks.
- $t$  is the number of minutes of Manual Time Error Correction that occurred during the hour.
- $TE_{offset}$  is 0.000 or +0.020 or -0.020.
- $PII_{accum}$  is the Balancing Authority's accumulated  $PII_{hourly}$  in MWh. An On-Peak and Off-Peak accumulation accounting is required.

Where:

$$\underline{PII_{accum}^{on/off\ peak}} = \underline{\text{last period's } PII_{accum}^{on/off\ peak}} + \underline{PII_{hourly}}$$

All NERC Interconnections with multiple Balancing Authorities operate using the principles of Tie-line Bias (TLB) Control and require the use of an ACE equation similar to the Reporting ACE defined above. Any modification(s) to this specified Reporting ACE equation that is(are) implemented for all BAs on an Interconnection and is(are) consistent with the following four principles will provide a valid alternative Reporting ACE equation consistent with the measures included in this standard.

1. All portions of the Interconnection are included in one area or another so that the sum of all area generation, loads and losses is the same as total system generation, load and losses.
2. The algebraic sum of all area Net Interchange Schedules and all Net Interchange actual values is equal to zero at all times.
3. The use of a common Scheduled Frequency  $F_S$  for all areas at all times.
4. The absence of metering or computational errors. (The inclusion and use of the  $I_{ME}$  term to account for known metering or computational errors.)

**Applicable Entities**

Balancing Authority

Reserve Sharing Group

***Applicable Facilities***

N/A

***Conforming Changes to Other Standards***

None

***Effective Dates***

BAL-002-2 shall become effective as follows:

First day of the first calendar quarter that is six months beyond the date that this standard is approved by applicable regulatory authorities, or in those jurisdictions where regulatory approval is not required, the standard becomes effective the first day of the first calendar quarter that is six months beyond the date this standard is approved by the NERC Board of Trustees', or as otherwise made pursuant to the laws applicable to such ERO governmental authorities.

***Justification***

The six-month period for implementation of BAL-002-2 will provide ample time for Balancing Authorities to make necessary modifications to existing software programs to ensure compliance.

***Retirements***

BAL-002-0, Disturbance Control Performance, and BAL-002-1, Disturbance Control Performance should be retired at midnight of the day immediately prior to the Effective Date of BAL-002-2 in the particular jurisdiction in which the new standard is becoming effective.