

## Consideration of Comments

**Project Name:** 2016-EPR-02 Enhanced Periodic Review of VAR Standards | Template for VAR-001-4.1

**Comment Period Start Date:** 2/28/2017

**Comment Period End Date:** 4/13/2017

There were 30 sets of responses, including comments from approximately 94 different people from approximately 77 companies representing the 10 Industry Segments as shown in the table on the following pages.

All comments submitted can be reviewed in their original format on the [project page](#).

If you feel that your comment has been overlooked, please let us know immediately. Our goal is to give every comment serious consideration in this process. If you feel there has been an error or omission, you can contact the Director of Standards Development, [Steve Noess](#) (via email) or at (404) 446-9691.

### Executive Summary

The periodic review team completed a comprehensive review of VAR-002-4 – Generator Operation for Maintaining Network Voltage Schedules. The team found the standard is sufficient to protect reliability and meet the reliability objective of the standard; however, there may be future opportunity to improve a non-substantive or insignificant quality and content issue. Industry comments also affirmed that the standard: 1) is sufficient to protect reliability, 2) meets the reliability objective of the standard, and 3) no immediate revision is necessary. The following are the observations and recommendations of the periodic review team.

## Questions

1. VAR-001-4.1 Requirement R4, regarding exemptions and exempted units, does not require periodic reviews or reviews triggered by changes; such as, technology, system conditions or other factors. Does this create an impact to reliability? If yes, please explain.
2. If the voltage schedule issued by the TOP to the GOP (Requirement R5) results in a generating unit routinely running at maximum limits, does a lack of dynamic reactive reserve have a reliability impact?
3. As of April 1, 2017, there will no longer be any explicit requirements for monitoring or ensuring adequate reactive reserves. Absent of any explicit requirements to monitor or ensure adequate reactive reserves within the IRO, TOP, or VAR standards, is there an impact to reliability? If yes, please explain.
4. As VAR-001-4.1 Requirement R5, Part 5.2 is silent with regards to a time duration that a generator can be outside of voltage schedule before notification is required. If the TOP is not required to specify the timing portion of the notification requirements while maintaining the necessary flexibility, is there an impact to reliability? If yes, please explain.
5. VAR-001-4.1 Requirement R5 does not include the RC as a recipient of voltage or Reactive Power schedules issued to generators. Is there an impact to reliability? If yes, please explain.
6. VAR-001-4.1 Requirement R5 dictates the status of an AVR. Does the lack of a similar requirement to identify the initial state of the PSS impact reliability? If yes, please explain.
7. The continent-wide VAR standards do not address external control loops to the AVR that may impact the reactive response of a generator. Some external control loops do not have the purpose of automatic voltage control, therefore, is there a need to coordinate external loops to prevent an impact to reliability?[1] If yes, please explain.

[1] See also: Lesson Learned, Generator Distributed Control System Impact on Automatic Voltage Regulators, June 9, 2015, ([http://www.nerc.com/pa/rrm/ea/Lessons Learned Document Library/LL20150602 Generator Distributed Control System Impact on Automatic Voltage Regulators.pdf](http://www.nerc.com/pa/rrm/ea/Lessons%20Learned%20Document%20Library/LL20150602%20Generator%20Distributed%20Control%20System%20Impact%20on%20Automatic%20Voltage%20Regulators.pdf))

8. There are a number of errata (i.e., administrative) type observations listed in Attachment 4 of the VAR-001-4.1 template. If you disagree with any of the observations, please list the reference number when providing comment.

9. There are a number of other observations in Attachment 5 of the VAR-001-4.1 template that could enhance the standard, but would require a drafting team to develop for industry feedback. If you have any comments about these, please list the reference number when providing comment.

10. The team did not identify a concern related to cost effectiveness as drafted. Do you agree? If not, please provide additional detail.

11. Given the items identified by the periodic review team in the VAR-001-4.1 template, do you agree that the Reliability Standard is sufficient to protect reliability and meet the reliability objective of the standard and does not need immediate modification through standards development; however, there may be a future opportunity to improve any non-substantive or insignificant quality and content issues? If you have any other comments on this review that you haven't already mentioned above, please provide them here.

**The Industry Segments are:**

- 1 — Transmission Owners
- 2 — RTOs, ISOs
- 3 — Load-serving Entities
- 4 — Transmission-dependent Utilities
- 5 — Electric Generators
- 6 — Electricity Brokers, Aggregators, and Marketers
- 7 — Large Electricity End Users
- 8 — Small Electricity End Users
- 9 — Federal, State, Provincial Regulatory or other Government Entities
- 10 — Regional Reliability Organizations, Regional Entities

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
ACES Power Marketing	Brian Van Gheem	6	NA - Not Applicable	ACES Standards Collaborators	Shari Heino	Brazos Electric Power Cooperative, Inc.	1,5	Texas RE
					Tara Lightner	Sunflower Electric Power Corporation	1	SPP RE
					Greg Froehling	Rayburn Country Electric Cooperative, Inc.	3	SPP RE
					Bob Solomon	Hoosier Energy Rural Electric Cooperative, Inc.	1	RF
					Mark Ringhausen	Mark Ringhausen	3,4	SERC
					John Shaver	Arizona Electric Power Cooperative, Inc.	1	WECC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					Bill Hutchison	Southern Illinois Power Cooperative	1	SERC
					Michael Brytowski	Great River Energy	1,3,5,6	MRO
					Ginger Mercier	Prairie Power, Inc.	1,3	SERC
Duke Energy	Colby Bellville	1,3,5,6	FRCC,RF,SERC	Duke Energy	Doug Hills	Duke Energy	1	RF
					Lee Schuster	Duke Energy	3	FRCC
					Dale Goodwine	Duke Energy	5	SERC
					Greg Cecil	Duke Energy	6	RF
New York Independent System Operator	Gregory Campoli	2		ISO/RTO Standards Review Committee	Gregory Campoli	NYISO	2	NPCC
					Ben Li	IESO	2	NPCC
					Kathleen Goodman	ISONO	2	NPCC
					Mark Holman	PJM	2	NPCC
					Charles Yeung	SPP	2	SPP RE
					Terry Bilke	MISO	2	MRO
					Nathan Bigbee	ERCOT	2	Texas RE
					Ali Miremadi	CAISO	2	WECC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
Entergy	Julie Hall	6		Entergy/NERC Compliance	Oliver Burke	Entergy - Entergy Services, Inc.	1	SERC
					Jaclyn Massey	Entergy - Entergy Services, Inc.	5	SERC
DTE Energy - Detroit Edison Company	Karie Barczak	3,4,5		DTE Energy - DTE Electric	Jeffrey Depriest	DTE Energy - DTE Electric	5	RF
					Daniel Herring	DTE Energy - DTE Electric	4	RF
					Karie Barczak	DTE Energy - DTE Electric	3	RF
Southern Company - Southern Company Services, Inc.	Pamela Hunter	1,3,5,6	SERC	Southern Company	Katherine Prewitt	Southern Company Services, Inc.	1	SERC
					R. Scott Moore	Alabama Power Company	3	SERC
					William D. Shultz	Southern Company Generation	5	SERC
					Jennifer G. Sykes	Southern Company Generation	6	SERC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
						and Energy Marketing		
Northeast Power Coordinating Council	Ruida Shu	1,2,3,4,5,6,7,8,9,10	NPCC	RSC no ISO-NE	Paul Malozewski	Hydro One.	1	NPCC
					Guy Zito	Northeast Power Coordinating Council	NA - Not Applicable	NPCC
					Randy MacDonald	New Brunswick Power	2	NPCC
					Wayne Sipperly	New York Power Authority	4	NPCC
					Glen Smith	Entergy Services	4	NPCC
					Brian Robinson	Utility Services	5	NPCC
					Bruce Metruck	New York Power Authority	6	NPCC
					Alan Adamson	New York State Reliability Council	7	NPCC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					Edward Bedder	Orange & Rockland Utilities	1	NPCC
					David Burke	Orange & Rockland Utilities	3	NPCC
					Michele Tondalo	UI	1	NPCC
					Sylvain Clermont	Hydro Québec	1	NPCC
					Si Truc Phan	Hydro Québec	2	NPCC
					Helen Lainis	IESO	2	NPCC
					Laura Mcleod	NB Power	1	NPCC
					Michael Forte	Con Edison	1	NPCC
					Kelly Silver	Con Edison	3	NPCC
					Peter Yost	Con Edison	4	NPCC
					Brian O'Boyle	Con Edison	5	NPCC
					Greg Campoli	NY-ISO	2	NPCC
					Michael Schiavone	National Grid	1	NPCC
					Michael Jones	National Grid	3	NPCC

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					David Ramkalawan	Ontario Power Generation Inc.	5	NPCC
					Quintin Lee	Eversource Energy	1	NPCC
					Silvia Mitchell	NextEra Energy - Florida Power and Light Co.	6	NPCC
					Sean Bodkin	Dominion Resources Services, Inc.	4	NPCC
Southwest Power Pool, Inc. (RTO)	Shannon Mickens	2	SPP RE	SPP Standards Review Group	Shannon Mickens	Southwest Power Pool Inc.	2	SPP RE
					Jim Nail	City of Independence, Power and Light Department	5	SPP RE
					John Allen	City Utilities of Springfield, Missouri	4	SPP RE
					Kevin Giles	Westar Energy	1	SPP RE

Organization Name	Name	Segment(s)	Region	Group Name	Group Member Name	Group Member Organization	Group Member Segment(s)	Group Member Region
					mike kidwell	Empire District Electric Company	1,3,5	SPP RE
					Tara Lightner	Sunflower Electric Power Corporation	1	SPP RE
					Don Schmit	Nebraska Public Power District	5	SPP RE
					J.Scott Williams	City Utilities of Springfield	1,4	SPP RE

**1. VAR-001-4.1 Requirement R4, regarding exemptions and exempted units, does not require periodic reviews or reviews triggered by changes; such as, technology, system conditions or other factors. Does this create an impact to reliability? If yes, please explain.**

**Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC**

**Answer** No

**Document Name**

**Comment**

BPA does not exempt any qualified units.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company**

**Answer** No

**Document Name**

**Comment**

Not necessarily. Generally speaking, IAs and Operating Agreements usually contain language that requires notifications between the GO and TO/TSP/TOP and vice-versa when there are changes. That would serve as the prompt to re-evaluate. Even absent the aforementioned prompt to re-evaluate, nothing precludes the TOP from re-evaluating exemptions.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Stephanie Burns - International Transmission Company Holdings Corporation - 2 - MRO,SPP RE,RF**

**Answer** No

**Document Name**

**Comment**

This sounds like an improvement in theory but it would manifest as a documentation requirement and add little value. A requirement would likely be met by showing an annual review of a procedure containing the exemption criteria.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Chris Scanlon - Exelon - 1,3,5,6**

**Answer** No

**Document Name**

**Comment**

There is no need for an administrative requirement to conduct a periodic review.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name RSC no ISO-NE**

**Answer** No

**Document Name**

**Comment**

The exemption should be based on the system need. Operating experience will bring to light when an exception needs to be reconsidered. There is no need to create a requirement to perform a review.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) concluded based on industry comment that the current TOP/IRO standards provide for an Operational Planning Analysis (OPA) and Real-time Assessment (RTA) that will identify any reliability issues; therefore, no immediate revision to the standard is warranted. Based on minority response, the PRT affirms that there may be future opportunities to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Russel Mountjoy - Midwest Reliability Organization - 10**

**Answer** No

**Document Name**

**Comment**

There are 30 minute system evaluations, next day analysis and other operation studies being run that would highlight if this were an issue. See Reliability Standards – TOP-001-3 & TOP-002-4.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) concluded based on industry comment that the current TOP/IRO standards provide for an Operational Planning Analysis (OPA) and Real-time Assessment (RTA) that will identify any reliability issues; therefore, no immediate revision to the standard is warranted. Based on minority response, the PRT affirms that there may be future opportunities to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Colby Bellville - Duke Energy - 1,3,5,6 - FRCC,SERC,RF, Group Name Duke Energy**

**Answer** No

**Document Name**

**Comment**

Duke Energy does not believe a periodic review or a review triggered by the specified changes is necessary, and does not believe that the lack of a requirement impacts reliability.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators**

**Answer** No

**Document Name**

**Comment**

TOPs already assess operations that would impact reliability through various Real Time Assessments and Operational Planning Analyses, as required in NERC Reliability Standards TOP-001-3 and TOP-002-4. We feel introducing a requirement for a periodic review of these exemptions would only cause confusion.

Likes 0

Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) concluded based on industry comment that the current TOP/IRO standards provide for an Operational Planning Analysis (OPA) and Real-time Assessment (RTA) that will identify any reliability issues; therefore, no immediate revision to the standard is warranted. Based on minority response, the PRT affirms that there may be future opportunities to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.	
<b>Elizabeth Axson - Electric Reliability Council of Texas, Inc. - 2</b>	
Answer	No
Document Name	
<b>Comment</b>	
ERCOT agrees that TOPs should periodically review any exemptions provided along with the criteria for granting such exemptions, but it is not necessary to require that through a standard. If a unit's exemption is causing reliability issues, the symptoms will more likely be observed in Planning Assessments, Operational Planning Analysis, and Real Time Assessments. This will prompt either Corrective Actions Plans or Operating Plans to be developed to address.	
Likes	0
Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) concluded based on industry comment that the current TOP/IRO standards provide for an Operational Planning Analysis (OPA) and Real-time Assessment (RTA) that will identify any reliability issues; therefore, no immediate revision to the standard is warranted. Based on minority response, the PRT affirms that there may be future opportunities to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.	
<b>Glen Farmer - Avista - Avista Corporation - 1,3,5</b>	
Answer	No
Document Name	

**Comment**

Likes 0

Dislikes 0

**Response**

**Dennis Chastain - Tennessee Valley Authority - 1,3,5,6 - SERC**

**Answer**

No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Preston Walker - PJM Interconnection, L.L.C. - 2 - RF**

**Answer**

No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

<b>Michelle Amarantos - APS - Arizona Public Service Co. - 1,3,5,6</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Sean Bodkin - Dominion - Dominion Resources, Inc. - 3,5,6</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name DTE Energy - DTE Electric</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	

Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Jesus Sammy Alcaraz - Imperial Irrigation District - 1</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>David Jendras - Ameren - Ameren Services - 1,3,6</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	

**Laura Nelson - IDACORP - Idaho Power Company - 1**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Sandra Shaffer - Berkshire Hathaway - PacifiCorp - 6**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Michael Cruz-Montes - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE**

**Answer** No

**Document Name**

**Comment**

Likes	0
Dislikes	0
<b>Response</b>	
Shannon Mickens - Southwest Power Pool, Inc. (RTO) - 2 - SPP RE, Group Name SPP Standards Review Group	
Answer	No
Document Name	
<b>Comment</b>	
Likes	0
Dislikes	0
<b>Response</b>	
Gregory Campoli - New York Independent System Operator - 2, Group Name ISO/RTO Standards Review Committee	
Answer	No
Document Name	
<b>Comment</b>	
Likes	0
Dislikes	0
<b>Response</b>	
Hien Ho - Tacoma Public Utilities (Tacoma, WA) - 1,3,4,5,6	

<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Thomas Foltz - AEP - 3,5</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
<p>There should be a requirement to conduct a periodic review to the units that are exempt, at a minimum of every three years of the exemption criteria. In addition, the specified voltage schedule supplied to the unit should be reviewed as well. For example, the initial stages of a wind farm project may not require a specific voltage schedule (i.e. exempt), but as the project progresses, changes (perhaps driven by a proposed increase in the size of the wind farm), a voltage schedule may need to be developed.</p>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<p>Thank you for your comment. The periodic review team (PRT) concluded based on industry comment that the current TOP/IRO standards provide for an Operational Planning Analysis (OPA) and Real-time Assessment (RTA) that will identify any reliability issues; therefore, no immediate revision to the standard is warranted. Based on minority response, the PRT affirms that there may be future opportunities to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.</p>	

**Julie Hall - Entergy - 6, Group Name** Entergy/NERC Compliance

**Answer** Yes

**Document Name**

**Comment**

Agree that there is a gap there. The review could be periodic or trigger based such as an equipment modification or any change that could impact the exempted status.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Aubrey Short - FirstEnergy - FirstEnergy Corporation - 1,3,4**

**Answer** Yes

**Document Name**

**Comment**

Exemptions and exemption units should be required to ensure statuses have been updated to and from TOP and GOP on a predetermined periodic schedule.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Rachel Coyne - Texas Reliability Entity, Inc. - 10**

<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Texas RE recommends periodic reviews of exemptions. In order to determine the best actions to support the reliability of the grid, TOPs need to understand the status or capability of available resources. When a generating unit becomes exempt, the TOP loses visibility to that generator.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) concluded based on industry comment that the current TOP/IRO standards provide for an Operational Planning Analysis (OPA) and Real-time Assessment (RTA) that will identify any reliability issues; therefore, no immediate revision to the standard is warranted. Based on minority response, the PRT affirms that there may be future opportunities to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.	
<b>Richard Jackson - U.S. Bureau of Reclamation - 1,5</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Reclamation asserts it is prudent to apply a time period for the TOP to review their specific criteria for generator exemptions. Reclamation asserts that the logical time period would coincide with the time period specified in the NERC system modeling (MOD) standards. Reclamation suggests Requirement R4 should specify that at least once every 10 years the Transmission Operator shall review and evaluate its exemption criteria for generators and notify pertinent Generator Operators of any changes to the previous criteria.	
Likes 0	
Dislikes 0	

**Response**

Thank you for your comment. The periodic review team (PRT) concluded based on industry comment that the current TOP/IRO standards provide for an Operational Planning Analysis (OPA) and Real-time Assessment (RTA) that will identify any reliability issues; therefore, no immediate revision to the standard is warranted. Based on minority response, the PRT affirms that there may be future opportunities to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**John Seelke - LS Power Transmission, LLC - 1**

**Answer**

**Document Name**

LS Power Transmission Comments Project 2016-EPR 04.13,17.docx

**Comment**

LS Power Transmission's comments address a problem with **both** and are therefore separately attached..

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) addresses the redundancy issue in the Periodic Review Recommendations: VAR-001-4.1 – Voltage and Reactive Control document, Attachment 5: Other Miscellaneous Corrections/Revisions, Item 1.1.

**2. If the voltage schedule issued by the TOP to the GOP (Requirement R5) results in a generating unit routinely running at maximum limits, does a lack of dynamic reactive reserve have a reliability impact?**

**Elizabeth Axson - Electric Reliability Council of Texas, Inc. - 2**

**Answer** No

**Document Name**

**Comment**

A lack of dynamic reactive reserves on only a single unit will not typically have a reliability impact. However, multiple generating units in the same reactive zone all running at Qmax or Qmin limits while using their dynamic reactive capability to provide that response could have a reliability impact. If seen ahead of time, or if monitored in real time with voltage stability applications, voltage stability System Operating Limits can be established to monitor when it would become a reliability impact. Voltage Schedules should be optimized to use static reactive devices first in order to maximize availability of generating unit dynamic reactive capability. While this is best practice, ERCOT does not necessarily agree that this should be captured in a standard

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Michael Godbout - Hydro-Québec TransÉnergie - 1 - NPCC**

**Answer** No

**Document Name**

**Comment**

Not necessarily. A specific unit running at maximum doesn't mean there is a lack of dynamic reactive reserve.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Shannon Mickens - Southwest Power Pool, Inc. (RTO) - 2 - SPP RE, Group Name SPP Standards Review Group**

**Answer** No

**Document Name**

**Comment**

The SPP Review Group has the perspective that a single generating unit is not a concern, because voltage control is a wider area issue involving multiple generator resources. However, if the drafting team feels that the focus of this project extends beyond the single generator, we recommend the drafting team revise the project language to reflect those concerns.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Russel Mountjoy - Midwest Reliability Organization - 10**

<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
<p>TOP's have the responsibility to ensure adequate dynamic reactive response. From the TOP perspective, reliability impact depends on available resources for the area and dynamic response available for the TOP footprint.</p>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<p>Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.</p>	
<b>Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name RSC no ISO-NE</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
<p>Not necessarily. This would have to be studied to determine whether there is a reliability impact. Planning studies should identify areas that lack sufficient reactive capability. If there are, system modifications should be proposed.</p>	
Likes 0	
Dislikes 0	
<b>Response</b>	

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Sandra Shaffer - Berkshire Hathaway - PacifiCorp - 6**

**Answer** No

**Document Name**

**Comment**

This question is not clear.

Likes 0

Dislikes 0

**Response**

**Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company**

**Answer** No

**Document Name**

**Comment**

Not necessarily - this cannot be generally answered. A single unit in an entire interconnect running at it maximum limits should not have an adverse reliability impact. If something like this occurs routinely, it could indicate the need for an overall review of reactive planning in the area. However, the described behavior of the generating unit could be in line with the overall reactive plan for that area.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Sean Bodkin - Dominion - Dominion Resources, Inc. - 3,5,6**

**Answer**

No

**Document Name**

**Comment**

Any impact on the system would be highly dependent on the specific system characteristics as well as the specific unit characteristics. A large unit near a critical interface has more impact than a small unit attached to a very strong network. This issue should not be addressed in a continent wide reliability standard.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Preston Walker - PJM Interconnection, L.L.C. - 2 - RF**

**Answer**

No

**Document Name**

**Comment**

Any impact on the system would be highly dependent on the specific system characteristics as well as the specific unit characteristics. A large unit near a critical interface has more impact than a small unit attached to a very strong network. This issue should not be addressed in a continent wide reliability standard.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Colby Bellville - Duke Energy - 1,3,5,6 - FRCC,SERC,RF, Group Name Duke Energy**

**Answer**

No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Michael Cruz-Montes - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE**

**Answer**

No

**Document Name**

**Comment**

Likes 0	
Dislikes 0	
<b>Response</b>	
<b>David Jendras - Ameren - Ameren Services - 1,3,6</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Jesus Sammy Alcaraz - Imperial Irrigation District - 1</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	

**Dennis Chastain - Tennessee Valley Authority - 1,3,5,6 - SERC**

Answer No

Document Name

Comment

Likes 0

Dislikes 0

Response

**Glen Farmer - Avista - Avista Corporation - 1,3,5**

Answer No

Document Name

Comment

Likes 0

Dislikes 0

Response

**Richard Jackson - U.S. Bureau of Reclamation - 1,5**

Answer Yes

Document Name

Comment

Reclamation asserts there are several variables to consider. Reclamation considers routinely operating all generating units at the maximum limits to be an undesirable practice because it removes available reactive margin to respond to a grid event. The TOP, as the entity with the area-wide purview, should be aware of other available equipment (for adequate reactive reserves), and would need the flexibility to develop voltage schedules accordingly. If System design limits dictate the need for a voltage schedule which requires routinely running the generating units at maximum limits, the design should be modified to allow units to have more reactive reserve capability.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators**

**Answer**

Yes

**Document Name**

**Comment**

The question is ambiguous and does not provide sufficient background regarding the system’s current conditions and configurations for proper context. Furthermore, the question assumes that the generator is the sole source for reactive reserves in the local region. However, we believe TOP-required Real Time Assessments and Operational Planning Analyses, as well as annual TP-required Planning Assessments, would already identify areas where additional infrastructure would be necessary to address potential voltage and reactive reserves issues.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Rachel Coyne - Texas Reliability Entity, Inc. - 10**

<b>Answer</b>	Yes
---------------	-----

<b>Document Name</b>	
----------------------	--

**Comment**

Generation routinely running at maximum reactive output is an indicator of insufficient reactive infrastructure support in the surrounding system. Voltage collapse or voltage degradation can result in load loss or equipment damage. Planning studies should encompass periodic corrections for inductive load growth.

Likes	0
-------	---

Dislikes	0
----------	---

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Aubrey Short - FirstEnergy - FirstEnergy Corporation - 1,3,4**

<b>Answer</b>	Yes
---------------	-----

<b>Document Name</b>	
----------------------	--

**Comment**

In a circumstance where numerous generators (not specified within the question) were operating at their VAR limits there would be potential for some impact on the reliability of the system. The systems, capability to react to an event would render the local area with the highest risk.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Laura Nelson - IDACORP - Idaho Power Company - 1**

**Answer**

Yes

**Document Name**

**Comment**

This would impact reliability, which is why we do not operate this way.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC**

**Answer**

Yes

**Document Name**

**Comment**

BPA believes it depends on whether the voltage schedule would place the whole plant or multiple plants under stress. The wide area risk would not be significant for a single unit operating at reactive limits.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Julie Hall - Entergy - 6, Group Name** Entergy/NERC Compliance

**Answer**

Yes

**Document Name**

**Comment**

Entergy expressed concerns that there is not a feedback loop between the TOP and GOP to raise concerns for issues with the voltage schedule – this should be allowed by the standard. If a generating unit is struggling to meet its voltage schedule, it would also not have margin left for dynamic reserves.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would

be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name** DTE Energy - DTE Electric

**Answer** Yes

**Document Name**

**Comment**

If additional reactive is needed for BES operation, the generator will not be able to assist in supplying additional reactive. If the generator is routinely running at maximum limits, system upgrades need to be performed such as installation of additional capacitors. This should be addressed with the TOP yearly review of the Voltage Schedules.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

**Michelle Amarantos - APS - Arizona Public Service Co. - 1,3,5,6**

**Answer** Yes

**Document Name**

**Comment**

A lack of dynamic reactive reserves could have a reliability impact if the TOP system is depending upon the generator to provide VAR support during transients to maintain reliability. However, the TOPs study work should identify this condition in advance.

Likes 0

Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.	
<b>Thomas Foltz - AEP - 3,5</b>	
Answer	Yes
Document Name	
<b>Comment</b>	
While a potential lack of dynamic reserves for a single unit may not have far-reaching impacts, a wide-scale lack of dynamic reserves could very well have an impact on reliability. Voltage schedules should be developed to allow a unit to have dynamic reserves available under normal conditions to respond to contingencies or disturbances. If a unit is hitting limits on reactive capability, the GOP and TOP should work together to resolve the issue (for example, voltage schedule change, exemptions, GSU tap changes, auxiliary transformer tap changes, etc.).	
Likes	0
Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.	
<b>Hien Ho - Tacoma Public Utilities (Tacoma, WA) - 1,3,4,5,6</b>	
Answer	Yes

<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Gregory Campoli - New York Independent System Operator - 2, Group Name ISO/RTO Standards Review Committee</b>	
<b>Answer</b>	
<b>Document Name</b>	
<b>Comment</b>	
<p>We do not fully understand the question since the term “lack of dynamic reactive reserve” needs to be clarified wrt whether it means:</p> <ul style="list-style-type: none"> <li>a. Lack of dynamic reactive reserve capability?</li> <li>b. Lack of dynamic reactive reserve requirements?</li> <li>c. Both</li> </ul> <p>Not knowing the exact meaning of the term, we are unable to provide relevant comment wrt whether or not the lack of any of the above can have a reliability impact.</p> <p>In general, we hold the view that if there are dynamic reactive reserve requirements, then they need to be met by having sufficient dynamic reactive reserve capability. Hence, the lack of dynamic reactive requirements does not have any reliability impact. On the other hand, the lack of dynamic reactive reserve capability may have a reliability impact; it depends on whether or not there are any dynamic reactive reserve requirements.</p>	

<b>Footnote: ERCOT does not support the joint response provided.</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.	
<b>Chris Scanlon - Exelon - 1,3,5,6</b>	
<b>Answer</b>	
<b>Document Name</b>	
<b>Comment</b>	
Difficult to answer at the unit level. A reasonable presumption is that if a unit is always at the max point then the unit is not able to supply dynamic support but the TOP is in a position to know if that is a concern.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.	
<b>Stephanie Burns - International Transmission Company Holdings Corporation - 2 - MRO,SPP RE,RF</b>	
<b>Answer</b>	

<b>Document Name</b>	
<b>Comment</b>	
Maybe, this is very situational. The TOP would need the discretion to decide what is best for the system for each situation.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.	

**3. As of April 1, 2017, there will no longer be any explicit requirements for monitoring or ensuring adequate reactive reserves. Absent of any explicit requirements to monitor or ensure adequate reactive reserves within the IRO, TOP, or VAR standards, is there an impact to reliability? If yes, please explain.**

**Preston Walker - PJM Interconnection, L.L.C. - 2 - RF**

**Answer** No

**Document Name**

**Comment**

The absence of an explicit requirement to monitor reactive reserves does not create a reliability gap.

The IRO suite of standards requires the RC to perform Operational Analyses and Real-time Assessments to prevent instability, uncontrolled separation, or Cascading and to ensure prompt action to prevent or mitigate instances of exceeding Interconnection Reliability Operating Limits (IROLs).

The TOP suite of standards requires the TOP to perform Operational Analyses and Real-time Assessments to prevent instability, uncontrolled separation, or Cascading and to ensure prompt action to prevent or mitigate instances of exceeding System Operating limits SOLs).

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Sean Bodkin - Dominion - Dominion Resources, Inc. - 3,5,6**

<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
<p>The absence of an explicit requirement to monitor reactive reserves does not create a reliability gap.</p> <p>The IRO suite of standards requires the RC to perform Operational Analyses and Real-time Assessments to prevent instability, uncontrolled separation, or Cascading and to ensure prompt action to prevent or mitigate instances of exceeding Interconnection Reliability Operating Limits (IROLs).</p> <p>The TOP suite of standards requires the TOP to perform Operational Analyses and Real-time Assessments to prevent instability, uncontrolled separation, or Cascading and to ensure prompt action to prevent or mitigate instances of exceeding System Operating limits (SOLs).</p>	
Likes	0
Dislikes	0
<b>Response</b>	
<p>Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.</p>	
<p><b>Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company</b></p>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	

No, TPL-001-4 covers this. In addition, reactive reserve requirements are generally specific to each region or locale, and each TOP is best-qualified to determine those requirements within their respective transmission systems.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. While the PRT agrees that TPL-001-4 will identify any stability issues that may manifest as a result of reactive reserve deficiencies, VAR-001-4.1 focuses on the operations time horizon. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored. Any future effort will have the flexibility to identify the appropriate entity (e.g., TOP).

**Chris Scanlon - Exelon - 1,3,5,6**

**Answer**

No

**Document Name**

**Comment**

IRO and TOP standards are sufficient to address this.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a

general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Sandra Shaffer - Berkshire Hathaway - PacifiCorp - 6**

**Answer** No

**Document Name**

**Comment**

Monitoring and operations are covered by other NERC Reliability standards such as TOPs.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name RSC no ISO-NE**

**Answer** No

**Document Name**

**Comment**

There are requirements to remain within limits post contingency. Operators would be aware of reactive reserve deficiencies if a plan cannot be developed to maintain the system within voltage limits post contingency. See TOP-002-4 R2, TOP-004-2 R1 and TOP-006-2 R3.

Therefore monitoring is being done. Additionally it may be impossible to “ensure” adequate reactive reserves if the planning process did not provide adequate reserves.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Russel Mountjoy - Midwest Reliability Organization - 10**

**Answer**

No

**Document Name**

**Comment**

Reactive reserves adequacy is addressed in the Real-time and next day Operating studies.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards (Operational Planning Analysis) and Real-time Assessments (RTA) address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Colby Bellville - Duke Energy - 1,3,5,6 - FRCC,SERC,RF, Group Name Duke Energy**

<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
<p>Duke Energy does not believe that the lack of requirements for monitoring of reactive resources impacts reliability. An effective operator will already be aware of reactive reserves, and adequacy of reactive reserves is covered by Real-time assessments already.</p>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<p>Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.</p>	
<b>Shannon Mickens - Southwest Power Pool, Inc. (RTO) - 2 - SPP RE, Group Name SPP Standards Review Group</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
<p>The SPP Review Group agrees with the TOP/IRO mapping document that provides supportive details addressing monitoring adequate reactive reserves in the VAR Standards. However, we recommend that the drafting team include the mapping document in future resource materials to provide clarity on these type of discussions.</p>	
Likes 0	
Dislikes 0	
<b>Response</b>	

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators**

**Answer** No

**Document Name**

**Comment**

We believe other reliability requirements in place to conduct Real Time Assessments and Operational Planning Analyses already address these concerns.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Richard Jackson - U.S. Bureau of Reclamation - 1,5**

**Answer** No

**Document Name**

**Comment**

Reclamation supports that the absence of explicit requirements for monitoring or ensuring adequate reactive reserves does not in itself impact reliability; however, the absence of adequate reactive reserves would impact reliability. Reclamation contends that ensuring

sufficient var capacity is quite difficult outside of requiring AVRs and sufficient amounts of spinning reserve. In order to ensure adequate reactive reserves, Reclamation suggests that an explicit requirement be retained.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Glen Farmer - Avista - Avista Corporation - 1,3,5**

**Answer**

No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Dennis Chastain - Tennessee Valley Authority - 1,3,5,6 - SERC**

**Answer**

No

**Document Name**

**Comment**

Likes	0
Dislikes	0
<b>Response</b>	
Michelle Amarantos - APS - Arizona Public Service Co. - 1,3,5,6	
Answer	No
Document Name	
<b>Comment</b>	
Likes	0
Dislikes	0
<b>Response</b>	
Jesus Sammy Alcaraz - Imperial Irrigation District - 1	
Answer	No
Document Name	
<b>Comment</b>	
Likes	0
Dislikes	0
<b>Response</b>	
Michael Cruz-Montes - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE	

Answer	No
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
<b>Gregory Campoli - New York Independent System Operator - 2, Group Name ISO/RTO Standards Review Committee</b>	
Answer	No
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
<b>Hien Ho - Tacoma Public Utilities (Tacoma, WA) - 1,3,4,5,6</b>	
Answer	No
Document Name	
Comment	
Likes 0	

Dislikes	0
<b>Response</b>	
Thomas Foltz - AEP - 3,5	
Answer	Yes
Document Name	
<b>Comment</b>	
<p>From an overall situational awareness point of view, there should be a mechanism to monitor reactive reserve capabilities. While we agree there needs to be an awareness, it is unclear what “adequate” reactive reserves mean. If voltage contingencies in your Real Time Assessment are being monitored, operating plans should be developed for any potential SOL’s. While we believe that there should be a requirement for monitoring reactive reserves, the diversity in the renewable generation mix makes modeling of the reserve units more complex.</p>	
Likes	0
Dislikes	0
<b>Response</b>	
<p>Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.</p>	
Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name DTE Energy - DTE Electric	
Answer	Yes
Document Name	
<b>Comment</b>	

Reactive reserves must be available to support the reliable operation of the BES. The TOP must be required to know the status of reactive reserves at all times.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Julie Hall - Entergy - 6, Group Name** Entergy/NERC Compliance

**Answer**

Yes

**Document Name**

**Comment**

Entergy agrees, monitoring reactive reserves is part of the purpose of this standard but is not addressed by any requirements.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC**

**Answer**

Yes

<b>Document Name</b>	
<b>Comment</b>	
In lieu of RTCA voltage stability analysis, BPA believes an explicit requirement for monitoring is necessary.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.	
<b>Stephanie Burns - International Transmission Company Holdings Corporation - 2 - MRO,SPP RE,RF</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
One could argue that VAR-001-4.1 R2, the RTA, and the OPA work to ensure adequate reactive reserves. However, there are no requirements for monitoring reactive reserves. For many TOPs, there are not frequent reactive reserve issues. Therefore, it is often not given adequate attention. A lack of frequent reactive reserve issues may lead some to discount their importance. Lack of awareness of reactive reserves is a common factor during voltage collapse events.	
Not requiring that any party monitor reactive reserves (in real-time) impacts reliability. Furthermore, the TOP is the appropriate party to monitor reactive reserves. A requirement to monitor reactive reserves would fit well within the VAR-001 standard.	
Likes 0	
Dislikes 0	

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored. Any future effort will have the flexibility to identify the appropriate entity (e.g., TOP).

**David Jendras - Ameren - Ameren Services - 1,3,6**

<b>Answer</b>	Yes
---------------	-----

<b>Document Name</b>	
----------------------	--

**Comment**

With no requirements to monitor or ensure adequate reactive reserves within the IRO, TOP, or VAR standards, there is a risk of falling below adequate resources and not being aware. Were this to occur and an initiating event occurred, it could be too late to acquire such resources.

Likes	0
-------	---

Dislikes	0
----------	---

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Aubrey Short - FirstEnergy - FirstEnergy Corporation - 1,3,4**

<b>Answer</b>	Yes
---------------	-----

<b>Document Name</b>	
----------------------	--

**Comment**

Primary reliance on TO's to accurately report VAR reserves absent a specific requirement could negatively impact accurate knowledge of VAR reserves available on the system and create the potential to impact reliability.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Elizabeth Axson - Electric Reliability Council of Texas, Inc. - 2**

**Answer**

Yes

**Document Name**

**Comment**

MVAR or Reactive reserves should be monitored to ensure pre and post contingency voltage stability. With many entities having real time / online voltage stability monitoring tools, MVAR reserves can be monitored in terms of MW flows along an interface. So, if all reactive zones are either monitored via real time / next day voltage stability limit calculating tools (i.e. an SOL exists for each zone) OR thermal constraints (Facility Ratings) are always more limiting than Voltage stability limits, then it would not impact reliability. OPA and RTA is predicated on evaluation for SOL exceedances, so if there is not an SOL that represents a reactive zone/area, then there is potential for voltage stability issues if MVAR reserves is not monitored in its stead. Voltage instability and reactive reserve deficiencies were contributing causes to the 2003 Northeast Blackout.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Laura Nelson - IDACORP - Idaho Power Company - 1**

**Answer**

**Document Name**

**Comment**

N/A

Likes 0

Dislikes 0

**Response**

**Rachel Coyne - Texas Reliability Entity, Inc. - 10**

**Answer**

**Document Name**

**Comment**

Texas RE is concerned the entity will have too much leeway in determining its reactive reserves. TOPs need to understand its voltage levels. The TOPs need to have the ability to accurately assess current voltage control capability in order to take proper action during abnormal voltage conditions.

Likes 0

Dislikes 0

### Response

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**4. As VAR-001-4.1 Requirement R5, Part 5.2 is silent with regards to a time duration that a generator can be outside of voltage schedule before notification is required. If the TOP is not required to specify the timing portion of the notification requirements while maintaining the necessary flexibility, is there an impact to reliability? If yes, please explain.**

**Elizabeth Axson - Electric Reliability Council of Texas, Inc. - 2**

**Answer** No

**Document Name**

**Comment**

TOP-003 already provides a mechanism for TOPs to notify GOPs of duration requirements.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Richard Jackson - U.S. Bureau of Reclamation - 1,5**

**Answer** No

**Document Name**

**Comment**

Reclamation asserts it is appropriate to allow the TOP to determine whether to specify a timing portion of the notification requirement.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators**

**Answer** No

**Document Name**

**Comment**

The question is ambiguous. The TOP is already required to specify a duration when a GOP deviates outside the required range or tolerance band. We assume the question asks how soon after the initial deviation occurs that the GOP must notify the TOP. If so, we believe System Operators who monitor the BES will likely be notified by EMS alarms first for significant deviations causing a reliability impact. For other deviations, the TOP has followed best practices and established a notification requirement for the GOP, as part of the timing duration requirement.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

VAR-001 R5.2 does not require a time duration for which it is acceptable for the GOP to be outside of the schedule, then return to within the schedule, but not be required to notify the TOP.

**Shannon Mickens - Southwest Power Pool, Inc. (RTO) - 2 - SPP RE, Group Name SPP Standards Review Group**

**Answer** No

**Document Name**

**Comment**

We have no concerns that the TOP notification to the GOP doesn't contain a timing limit for the generator in Part 5.2 of the standard. The TOP's responsibility to provide the GOP with notification requirements would reasonably include the timing of such notifications.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Colby Bellville - Duke Energy - 1,3,5,6 - FRCC,SERC,RF, Group Name Duke Energy**

**Answer**

No

**Document Name**

**Comment**

Duke Energy does not believe that the absence of a requirement outlining a time duration that a generator can be outside of the voltage schedule before notification is required presents a clear impact to reliability. From a reliability standpoint, there are already standards that require the TOP to monitor SOL limits. In doing so, a TOP would be notified based on monitoring of SOL(s) whether a GOP sent notification or not. We believe this mitigates any potential issue pertaining to reliability of the system. We do feel that additional guidance around this topic may be useful to industry stakeholders in the form of a guidelines and technical basis section.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Russel Mountjoy - Midwest Reliability Organization - 10**

<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Requirement 5.2 states that the TOP provides the GOP with the notification requirements for deviations from the voltage schedule.	
Likes	0
Dislikes	0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name RSC no ISO-NE**

<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
No, the TOP is aware of real time and post contingency voltages and whether the system is or will be within limits. If the system is not or will not be within limits the TOP can call the generator to inquire the status of the AVR or their ability to control to the reactive schedule.	
Likes	0
Dislikes	0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

The PRT agrees that if a generator was outside of a voltage schedule, reliability issues would be identified by the TOP by its RTA. If these issues persisted, the TOP has the ability to modify its notification requirements, as needed.

**Aubrey Short - FirstEnergy - FirstEnergy Corporation - 1,3,4**

<b>Answer</b>	No
---------------	----

<b>Document Name</b>	
----------------------	--

**Comment**

While the requirement does not specify a timing requirement it is likely implemented in practice. For FirstEnergy, PJM manuals document the notification requirement for when a generator is outside of its voltage schedule and a timing aspect is included. The standard should not mandate a specific time, however, it could generally indicate that the notification must specify an expected timing for the notification.

Likes 0	
---------	--

Dislikes 0	
------------	--

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Chris Scanlon - Exelon - 1,3,5,6**

<b>Answer</b>	No
---------------	----

<b>Document Name</b>	
----------------------	--

**Comment**

We don't believe this has a significant reliability impact, This should be left to the discretion of the TOP and can be detailed in the voltage schedule issued to the GOP if the TOP requires it.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Stephanie Burns - International Transmission Company Holdings Corporation - 2 - MRO,SPP RE,RF**

**Answer**

No

**Document Name**

**Comment**

Reliability may not be affected, but a timing duration that a generator can be outside of a schedule before notification is required can significantly reduce compliance risk for the GOP. This compliance risk does not align with an improvement to reliability. It would be reasonable for NERC to require the TOP specify a time duration before a notification is required by the GOP.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company**

<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Not necessarily - the TOP has the flexibility to specify the time frame for any required notification where they determine that timing is critical. R5.2 of VAR-001-4.1 is sufficient as it is.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.	
<b>Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
If BPA dispatch specified a deviation from the voltage or reactive schedule, it would include a projected time frame. This is considered an Operating Instruction in accordance with COM-002-4.	
Likes 0	
Dislikes 0	
<b>Response</b>	

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name DTE Energy - DTE Electric**

**Answer** No

**Document Name**

**Comment**

There is not an impact to reliability but this issue needs to be addressed for compliance monitoring. The GOP must know how long the voltage can be outside the generator bus schedule. This will assist the auditor when reviewing compliance and assist the GOP in knowing when a self report is required.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Thomas Foltz - AEP - 3,5**

**Answer** No

**Document Name**

**Comment**

While there may be no significant impact to reliability, not specifying the duration that a unit can be outside the specified band could result in communication issues. For example, this could potentially result in excessive phone calls which could be distracting to both the

GOP and TOP. Perhaps the language in the requirement could be changed to suggest examples of what can be included in the notification requirement from the TOP to the GOP.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Hien Ho - Tacoma Public Utilities (Tacoma, WA) - 1,3,4,5,6**

Answer No

Document Name

Comment

Likes 0

Dislikes 0

**Response**

**Gregory Campoli - New York Independent System Operator - 2, Group Name ISO/RTO Standards Review Committee**

Answer No

Document Name

Comment

Likes 0

Dislikes 0	
<b>Response</b>	
<b>Michael Cruz-Montes - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE</b>	
Answer	No
Document Name	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Sandra Shaffer - Berkshire Hathaway - PacifiCorp - 6</b>	
Answer	No
Document Name	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Laura Nelson - IDACORP - Idaho Power Company - 1</b>	
Answer	No

<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Jesus Sammy Alcaraz - Imperial Irrigation District - 1</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Sean Bodkin - Dominion - Dominion Resources, Inc. - 3,5,6</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	

**Response**

**Michelle Amarantos - APS - Arizona Public Service Co. - 1,3,5,6**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Preston Walker - PJM Interconnection, L.L.C. - 2 - RF**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Dennis Chastain - Tennessee Valley Authority - 1,3,5,6 - SERC**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Glen Farmer - Avista - Avista Corporation - 1,3,5**

**Answer**

No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**David Jendras - Ameren - Ameren Services - 1,3,6**

**Answer**

Yes

**Document Name**

**Comment**

If the TOP is not required to specify the timing portion of notifying them of a generator being outside of the voltage schedule and VAR-002 does not specify such timing for notification, a generator could be outside of the TOP's provided voltage schedule an indefinite amount of time. We believe that it is obvious that this could have an impact to reliability.

Currently the voltage schedule is an hourly average, however, this has nothing to do with notification. Currently the schedule that we send only indicates, "All such notices to the TOS shall be without intentional delay." If there is no stipulation in 5.2, we envision some GOPs will insist that they have no requirement for notification.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

The PRT contends that if a generator was outside of a voltage schedule, reliability issues would be identified by the TOP by its RTA. If these issues persisted, the TOP has the ability to modify its notification requirements, as needed.

**Julie Hall - Entergy - 6, Group Name** Entergy/NERC Compliance

**Answer**

Yes

**Document Name**

**Comment**

Agree that the timing portion should be required to be specified by the TOP. Do not agree that this parameter should be prescriptively defined by NERC.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

**Rachel Coyne - Texas Reliability Entity, Inc. - 10**

Answer

Document Name

Comment

: Texas is concerned that if there is no timing requirement, there is no control in place to ensure the generator’s reactive schedule is reset back to normal, which could mean an entity could be out of its voltage schedule indefinitely. Texas RE frequently recommends entities provide timing in notifications so expectations are set.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

The PRT contends that if a generator was outside of a voltage schedule, reliability issues would be identified by the TOP by its RTA. If these issues persisted, the TOP has the ability to modify its notification requirements, as needed.

**5. VAR-001-4.1 Requirement R5 does not include the RC as a recipient of voltage or Reactive Power schedules issued to generators. Is there an impact to reliability? If yes, please explain.**

**Dennis Chastain - Tennessee Valley Authority - 1,3,5,6 - SERC**

Answer

No

Document Name

**Comment**

Provided within a timeframe specified by the RC upon request would be adequate.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name** DTE Energy - DTE Electric

**Answer**

No

**Document Name**

**Comment**

Voltage control is a local issue. The TOP, GOP and DP must be aware and concerned with voltage control. The RC is looking a higher level and at a much larger area where local voltage control should not be a concern.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Julie Hall - Entergy - 6, Group Name** Entergy/NERC Compliance

**Answer**

No

<b>Document Name</b>	
<b>Comment</b>	
This is already addressed in IRO-010 and VAR-001 is not the appropriate place to address this. Entergy disagrees with adding this requirement to VAR-001.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.	
<b>Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
BPA believes VAR-001-4.1, R1.1 ensures that the RC and adjacent TOP's receive the system voltage schedule on request. BPA believes the IRO-010 data request would be available for the RC to receive the voltage or Reactive Power schedules.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.	

<b>Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
R1.1 of VAR-001-4.1 gives the RC the ability to request this information if needed.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information, even if beyond or different than VAR-001-4.1, Requirement R1, Part 1.1. Therefore, no reliability gap exists.	
<b>Stephanie Burns - International Transmission Company Holdings Corporation - 2 - MRO,SPP RE,RF</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
The RC can specify this as required data in their documented specification for data from IRO-010-2.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.	

**Chris Scanlon - Exelon - 1,3,5,6****Answer** No**Document Name****Comment**

The RC has other ways of getting this information.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Sandra Shaffer - Berkshire Hathaway - PacifiCorp - 6****Answer** No**Document Name****Comment**

RC is informed as part of IRO-010.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name RSC no ISO-NE****Answer** No**Document Name****Comment**

Per R1.1 the RC can obtain a copy of the voltage schedule. Therefore the schedules are available to the RC.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information, even if beyond or different than VAR-001-4.1, Requirement R1, Part 1.1. Therefore, no reliability gap exists.

**Russel Mountjoy - Midwest Reliability Organization - 10****Answer** No**Document Name****Comment**

The TOP is responsible for system operations and reliability. The RC can specify their data needs per IRO-010-2.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Colby Bellville - Duke Energy - 1,3,5,6 - FRCC,SERC,RF, Group Name Duke Energy**

**Answer** No

**Document Name**

**Comment**

An RC may already be receiving this information via established agreements with member entities, and can request this information at any time. While having this information may be helpful for the RC, we do not see a real impact to reliability with there not being a requirement to provide the RC with these scehdules.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Shannon Mickens - Southwest Power Pool, Inc. (RTO) - 2 - SPP RE, Group Name SPP Standards Review Group**

**Answer** No

**Document Name**

**Comment**

The review group does not find any reliability impact with the RC not receiving the voltage and Reactive Power schedules from the TOP. However as registered RC, SPP finds the data in the schedules to be very valuable to other processes associated with the RC function. For example, this particular data can help increase the accuracy of the network applications as well as the Real-time Assessment. In our review and interpretation of the IRO Standards, it is our understanding that the IRO-010-2 Standard addresses the RC receiving this type of data and eliminating any concerns for reliability issues.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators**

Answer

No

Document Name

**Comment**

By its definition, a TOP is the entity responsible for the reliability of its “local” transmission system. The issuance of voltage or Reactive Power schedules to generators should be identified as a “local” reliability concern. We feel the inclusion of the RC as a recipient would be burdensome, particularly when monitoring and assessing the Wide Area view of the BES.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Gregory Campoli - New York Independent System Operator - 2, Group Name ISO/RTO Standards Review Committee**

Answer

No

Document Name

**Comment**

NERC currently has IRO Standards that require RC's to obtain this information.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Richard Jackson - U.S. Bureau of Reclamation - 1,5**

**Answer**

No

**Document Name**

**Comment**

Reclamation proposes the TOP should provide the RC with copies of the voltage or Reactive Power schedules issued to generators so that the RC has the appropriate information for analysis and operations.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Michael Godbout - Hydro-Québec TransÉnergie - 1 - NPCC**

**Answer**

No

**Document Name**

**Comment**

We support NPCC's comments. That is, requirement 1.1 provides for an mandatory communication of the schedules to the RC upon the RC's request.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information, even if beyond or different than VAR-001-4.1, Requirement R1, Part 1.1. Therefore, no reliability gap exists.

**Elizabeth Axson - Electric Reliability Council of Texas, Inc. - 2**

**Answer**

No

**Document Name**

**Comment**

IRO-010 provides the RC the means to get the desired information, if necessary.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Glen Farmer - Avista - Avista Corporation - 1,3,5**

**Answer**

No

<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Preston Walker - PJM Interconnection, L.L.C. - 2 - RF</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Michelle Amarantos - APS - Arizona Public Service Co. - 1,3,5,6</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	

<b>Response</b>	
<b>Sean Bodkin - Dominion - Dominion Resources, Inc. - 3,5,6</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Jesus Sammy Alcaraz - Imperial Irrigation District - 1</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Laura Nelson - IDACORP - Idaho Power Company - 1</b>	
<b>Answer</b>	No
<b>Document Name</b>	

**Comment**

Likes 0

Dislikes 0

**Response**

**Aubrey Short - FirstEnergy - FirstEnergy Corporation - 1,3,4**

**Answer**

No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Michael Cruz-Montes - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE**

**Answer**

No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

<b>Hien Ho - Tacoma Public Utilities (Tacoma, WA) - 1,3,4,5,6</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Thomas Foltz - AEP - 3,5</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
<p>The RC is required to monitor SOL's and IROL's. The information in the voltage/reactive power schedules could, at a minimum, be used to improve the RC's awareness. While this could potentially have a positive reliability impact, we do not believe VAR-001 is the proper standard for such an obligation. Rather, we believe IRO-010-2 would be more appropriate.</p>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<p>Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.</p>	

**David Jendras - Ameren - Ameren Services - 1,3,6**

**Answer** Yes

**Document Name**

**Comment**

In many cases the RC is the Planning Authority for the TOP. If the RC is not aware of the voltage schedule provided to the generators, this cannot be taken into account for system planning.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**Rachel Coyne - Texas Reliability Entity, Inc. - 10**

**Answer**

**Document Name**

**Comment**

Texas RE suggests it would be prudent for the RC to understand its entities' voltage and Reactive Power schedules. Understanding these schedules allow for better planning of reactive resources and, system awareness. Since the RC has the authority to direct dispatch of generation outside of its voltage or reactive power schedule due to real time concerns or contingencies, it should know it is doing so. Knowledge of normal reactive schedules is a primary means by which an RC can realize the extent of reactively deficient areas.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

**6. VAR-001-4.1 Requirement R5 dictates the status of an AVR. Does the lack of a similar requirement to identify the initial state of the PSS impact reliability? If yes, please explain.**

**Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators**

**Answer** No

**Document Name**

**Comment**

The question assumes that all generators have a PSS. This is simply not true. For those that do, the GOP is already required to notify the TOP of a PSS status change in Requirement R3 of NERC Standard VAR-002-4. This notification is used to identify what is outside normal operation and could affect a generator’s availability.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.

**Shannon Mickens - Southwest Power Pool, Inc. (RTO) - 2 - SPP RE, Group Name SPP Standards Review Group**

**Answer** No

**Document Name**

**Comment**

The SPP Review Group has no concerns with the power system stabilizer (PSS) initial state not being mentioned in this particular requirement. After reviewing VAR-001 and VAR-002 Standards, the review group believes that the PSS status change concerns are addressed in VAR-002-4 under Requirement R3 and there are no concerns in reference to reliability issues.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.

**Russel Mountjoy - Midwest Reliability Organization - 10**

**Answer**

No

**Document Name**

**Comment**

The NSRF acknowledges a potential impact on reliability, but only when there is an identified reliability need per the TPL-001-4 stability analysis. We agree there is a need to know the initial state. However, VAR-002-4 R3 already requires the GOP to notify the TOP of PSS change. The TOP can pursue other avenues via a data specification request (TOP-003-3 and IRO-010-2).

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.

**Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name RSC no ISO-NE**

<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
A PSS would only be installed if there was a reliability reason. Presumably when the generator and PSS were commissioned the TOP knew the status. Therefore only notifications of changes to the status are necessary.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.	
<b>Chris Scanlon - Exelon - 1,3,5,6</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
A PSS does not function like an AVR, a PSS is typically not enabled automatically until a certain MWe when ramping a unit up in power and subsequently disabled at a certain MWe on ramping a unit down in power. Specifying an initial state may not be meaningful.	
Likes 0	
Dislikes 0	
<b>Response</b>	

Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.

**Stephanie Burns - International Transmission Company Holdings Corporation - 2 - MRO,SPP RE,RF**

**Answer** No

**Document Name**

**Comment**

It may not be wise for the TOP to dictate the PSS status as part of a NERC standard. However, the TOP should be aware of the PSS status. Perhaps, the GOP should be required to tell the TOP the actual and normal PSS status on an annual basis, in addition to real-time notification of status changes.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.

**Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company**

**Answer** No

**Document Name**

**Comment**

PSS requirements are often already detailed in the interconnection requirements or existing regional requirements. A PSS is typically set up in such a way it would be automatically turned on/off at pre-determined MW setpoints when the AVR is in service. So, with language on AVR, it will typically also cover the PSS.

Likes	0
Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.	
<b>Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC</b>	
Answer	No
Document Name	
<b>Comment</b>	
As BPA is a part of the WECC region, there is already standard VAR-501-WECC-2 with a requirement for PSS to be kept in service.	
Likes	0
Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.	
<b>Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name DTE Energy - DTE Electric</b>	
Answer	No
Document Name	
<b>Comment</b>	

The PSS on many units do not come into service until the unit is on line and loaded to some point. The initial state of the PSS should be considered out of service until documentation provided by the GOP states when the PSS comes into service. Once that point is obtained, the PSS should be considered in service unless noted other wise by the GOP.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.

**Michelle Amarantos - APS - Arizona Public Service Co. - 1,3,5,6**

**Answer**

No

**Document Name**

**Comment**

The PSS status information does not meaningfully impact the TOP.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.

**Hien Ho - Tacoma Public Utilities (Tacoma, WA) - 1,3,4,5,6**

**Answer**

No

<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Colby Bellville - Duke Energy - 1,3,5,6 - FRCC,SERC,RF, Group Name Duke Energy</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Michael Cruz-Montes - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	

**Response**

**Aubrey Short - FirstEnergy - FirstEnergy Corporation - 1,3,4**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Sandra Shaffer - Berkshire Hathaway - PacifiCorp - 6**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Laura Nelson - IDACORP - Idaho Power Company - 1**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Jesus Sammy Alcaraz - Imperial Irrigation District - 1**

**Answer**

No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Sean Bodkin - Dominion - Dominion Resources, Inc. - 3,5,6**

**Answer**

No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

<b>Preston Walker - PJM Interconnection, L.L.C. - 2 - RF</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes	0
Dislikes	0
<b>Response</b>	
<b>Dennis Chastain - Tennessee Valley Authority - 1,3,5,6 - SERC</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Likes	0
Dislikes	0
<b>Response</b>	
<b>Glen Farmer - Avista - Avista Corporation - 1,3,5</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	

Likes 0	
Dislikes 0	
<b>Response</b>	
Elizabeth Axson - Electric Reliability Council of Texas, Inc. - 2	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
There are instances where the PSS will have an impact on IROL Limits. PSS desired states should be determined for each generator. ERCOT has Protocols that identify the necessary coordination. While this is a best practice, ERCOT sees no need to codify this in a standard.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.	
Richard Jackson - U.S. Bureau of Reclamation - 1,5	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	

Reclamation contends both AVR and PSS should be addressed in both VAR-001-4.1 and VAR-002-4. The lack of including PSS creates the need to address PSS in regional variances to ensure grid stability. Reclamation asserts that it is important for PSSs to be required as applicable.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.

**Gregory Campoli - New York Independent System Operator - 2, Group Name ISO/RTO Standards Review Committee**

**Answer**

Yes

**Document Name**

**Comment**

**Impacts on the system would be highly dependent on the specific system characteristics as well as the specific unit characteristics, however There can be instances where the PSS will have an impact on IROL Limits.**

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.

**Rachel Coyne - Texas Reliability Entity, Inc. - 10**

**Answer**

Yes

<b>Document Name</b>	
<b>Comment</b>	
<p>Texas RE recommends a similar requirement for the PSS. Understanding the PSS availability gives a broader view of the system and its ability to damp out instability. While the PSS is not a reactive resource (it is a real power resource), studies should provide input on which assumptions concerning PSS were used, and whether there should be PSS in-service requirements for regional generation. If determined dynamically necessary, enough PSSs must be in service regionally to provide the necessary oscillatory damping.</p>	
Likes	0
Dislikes	0
<b>Response</b>	
<p>Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.</p>	
<b>David Jendras - Ameren - Ameren Services - 1,3,6</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
<p>In many cases system stability is greatly altered with a PSS out of service. Therefore the initial state of the PSS is very important and should be stipulated. PSS is normally fixed in the firmware of the generator and cannot be changed or altered.</p> <p>If a unit is designed such that the initial state of the PSS will be “on” when the unit is first synchronized, that this information can be shared with the TOP in a ONE TIME notification which will inform the TOP that the PSS is always on, unless notified. It is essential that the TOP know the state of the PSS but if the design “forces” the PSS to be on unless otherwise “switched” off and the “switch off” entails notice, then the TOP would know the status.</p>	
Likes	0

Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.	
<b>Julie Hall - Entergy - 6, Group Name</b> Entergy/NERC Compliance	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Agree that clarity is needed, but this should appear in VAR-002 R1, not related to VAR-001 R5. Disagree with putting this content in VAR-001.	
Likes	0
Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.	
<b>Thomas Foltz - AEP - 3,5</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
While Power System Stabilizers are not used on all generating units, a requirement to inform the TOP of the initial state of the PSS may be beneficial for those instances where they <i>are</i> used. That being said, since a Power System Stabilizer does not regulate voltage or reactive	

power, and, instead, is used to dampen electro-mechanical oscillations, references to Power System Stabilizers should not be added to VAR-001. In addition, consideration might also be given to removing PSS references from VAR-002 as well. It may be worth considering that requirements relating to PSS operation and status be placed in a different standard or technical guide; otherwise, the scope of these standards should be expanded to encompass PSS operation and status.

Likes	0
Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.	

7. The continent-wide VAR standards do not address external control loops to the AVR that may impact the reactive response of a generator. Some external control loops do not have the purpose of automatic voltage control, therefore, is there a need to coordinate external loops to prevent an impact to reliability?<sup>[1]</sup> If yes, please explain.

<sup>[1]</sup> See also: Lesson Learned, Generator Distributed Control System Impact on Automatic Voltage Regulators, June 9, 2015, (<http://www.nerc.com/pa/rrm/ea/Lessons Learned Document Library/LL20150602 Generator Distributed Control System Impact on Automatic Voltage Regulators.pdf>)

Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name DTE Energy - DTE Electric

Answer No

Document Name

Comment

No comments

Likes 0

Dislikes 0

Response

Julie Hall - Entergy - 6, Group Name Entergy/NERC Compliance

Answer No

Document Name

Comment

The "how" of meeting the specifications of the TOP is not the TOP's job to define. This may be a lessons learned to consider these factors in your "net" response. This should be results based and not method determinate.

Likes	0
Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.	
<b>Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name</b> Southern Company	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
Not necessarily - it depends - at the high speed response level (the inverter) most DGR sites do not employ voltage control - most run in reactive control or PF control. They respond to commands from the outer loop plant voltage control. The external (plant wide) control loops are slower in response time to what is traditionally considered to be used for system transient voltage conditions. The external loops can assist with ensuring that the voltage schedule is followed.	
Likes	0
Dislikes	0
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.	
<b>Colby Bellville - Duke Energy - 1,3,5,6 - FRCC,SERC,RF, Group Name</b> Duke Energy	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	

While external control loops can provide an unintended impact to reliability we do not believe that VAR-001 is the correct standard to address identifying and correcting these deficiencies. We believe MOD-025 or MOD-026 would be a more appropriate standard to identify the need to document and communicate the impact of external control loop actions on the AVR to the TOP.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.

**Shannon Mickens - Southwest Power Pool, Inc. (RTO) - 2 - SPP RE, Group Name SPP Standards Review Group**

**Answer**

No

**Document Name**

**Comment**

The SPP Review Group has no concerns with control loops not being mentioned in this particular requirement as well as seeing no reliability issues. The status change of the alternative voltage controlling device (control loops) has been addressed in the VAR-002-4 Standard under Requirement R3.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.

**Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators**

<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
<p>We do not believe there is a need to require coordination of external loops. Though we thank the Periodic Review Team for reaffirming the importance of this documented NERC lesson learned, we disagree that the occurrence of this singularity necessitates a NERC enforceable requirement. This would set a precedence for all future NERC Lesson Learned and undermine the intent of that program.</p>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<p>Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.</p>	
<b>Richard Jackson - U.S. Bureau of Reclamation - 1,5</b>	
<b>Answer</b>	No
<b>Document Name</b>	
<b>Comment</b>	
<p>Reclamation contends that VAR-001-4.1 should require external control loops to be coordinated.</p>	
Likes 0	
Dislikes 0	
<b>Response</b>	

Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.

Some commenters identified, and the PRT agrees, that TOP involvement in detailed AVR external controller loop design is outside the scope of VAR-001.

**Glen Farmer - Avista - Avista Corporation - 1,3,5**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Dennis Chastain - Tennessee Valley Authority - 1,3,5,6 - SERC**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Preston Walker - PJM Interconnection, L.L.C. - 2 - RF**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Michelle Amarantos - APS - Arizona Public Service Co. - 1,3,5,6**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Sean Bodkin - Dominion - Dominion Resources, Inc. - 3,5,6**

**Answer** No

**Document Name**

**Comment**

Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Jesus Sammy Alcaraz - Imperial Irrigation District - 1</b>	
Answer	No
Document Name	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Aubrey Short - FirstEnergy - FirstEnergy Corporation - 1,3,4</b>	
Answer	No
Document Name	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Michael Cruz-Montes - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE</b>	

Answer	No
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
<b>Russel Mountjoy - Midwest Reliability Organization - 10</b>	
Answer	No
Document Name	
Comment	
Likes	0
Dislikes	0
Response	
<b>Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC</b>	
Answer	Yes
Document Name	
Comment	
<p>There are external control loops, like VAR regulators and power factor controllers, that can over-ride action of generator's Automatic Voltage Regulator. The action of such controls is one of the contributing factors to the August 10, 1996 Western Interconnection power</p>	

outage. BPA believes if language were to be included in a Standard revision, it would need to be carefully drafted as it may become too prescriptive, requiring expensive equipment replacements.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.

**Stephanie Burns - International Transmission Company Holdings Corporation - 2 - MRO,SPP RE,RF**

**Answer** Yes

**Document Name**

**Comment**

Both GOP and TOP need to understand how a generator is going to control voltage. Requiring that the GOP understand and document any external control schemes lends itself to improving reliability.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.

**David Jendras - Ameren - Ameren Services - 1,3,6**

**Answer** Yes

**Document Name**

**Comment**

If the AVR response is altered due to external control loops, this needs to be taken into account. The purpose of VAR-001 in its entirety is for the TOP to understand the VAR resources available from each generator. If the resource availability is altered due to something other than automatic voltage control, the TOP needs to be aware of it and also have the latitude to request removal of the loop if it is not for the protection of the unit, transmission system or equipment on which either is dependent.

AVR is required to operate in auto if not a notification is required per VAR-002.

We are concerned that even though the AVR could stay in auto, an external control loop might impact the reactive response of the generator. We believe that this could, in effect, defeat the purpose of the AVR to control the voltage as mandated.

Likes	0
-------	---

Dislikes	0
----------	---

**Response**

Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.

Some commenters identified, and the PRT agrees, that TOP involvement in detailed AVR external controller loop design is outside the scope of VAR-001.

**Gregory Campoli - New York Independent System Operator - 2, Group Name ISO/RTO Standards Review Committee**

Answer	Yes
--------	-----

Document Name	
---------------	--

**Comment**

If there are external controls loops that could override the AVR and limit the reactive output, some level of coordination or notification should be required. Plant owners need to be diligent that external control loops do not counteract the primary function of excitation or governor control.

Likes 0

Dislikes 0

### Response

Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.

Some commenters identified, and the PRT agrees, that TOP involvement in detailed AVR external controller loop design is outside the scope of VAR-001.

**Elizabeth Axson - Electric Reliability Council of Texas, Inc. - 2**

Answer

Yes

Document Name

### Comment

If there are external controls loops that could override the AVR and limit the reactive output, some level of coordination or notification is appropriate. However, this does not necessarily require modification to a standard.

Likes 0

Dislikes 0

### Response

Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.

**Laura Nelson - IDACORP - Idaho Power Company - 1**

Answer

Document Name

Comment

N/A

Likes 0

Dislikes 0

Response

**Rachel Coyne - Texas Reliability Entity, Inc. - 10**

Answer

Document Name

Comment

Texas RE recommends external control loops (for example, PSS) that have an affect on AVR operations should be considered in planning studies to alleviate impacts to reliability.

Likes 0

Dislikes 0

Response

Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.

Some commenters identified, and the PRT agrees, that TOP involvement in detailed AVR external controller loop design is outside the scope of VAR-001.

**8. There are a number of errata (i.e., administrative) type observations listed in Attachment 4 of the VAR-001-4.1 template. If you disagree with any of the observations, please list the reference number when providing comment.**

**Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators**

**Answer**

**Document Name**

**Comment**

We agree with the errata list and thank the Periodic Review Team for identifying these administrative type observations.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Richard Jackson - U.S. Bureau of Reclamation - 1,5**

**Answer**

**Document Name**

**Comment**

Reclamation agrees with the proposed errata.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Russel Mountjoy - Midwest Reliability Organization - 10**

**Answer**

**Document Name**

**Comment**

The NSRF agrees with the review team.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Rachel Coyne - Texas Reliability Entity, Inc. - 10**

**Answer**

**Document Name**

**Comment**

Texas RE recommends using the latest Results Based Standards template for VAR-001. Texas RE noticed R4 starts with “The Transmission Operator...” but the R4 Measure says “Each Transmission Operator...”

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The periodic review team (PRT) added the additional errata to the Periodic Review Recommendations: VAR-001-4.1 – Voltage and Reactive Control document.

**Sandra Shaffer - Berkshire Hathaway - PacifiCorp - 6**

<b>Answer</b>	
<b>Document Name</b>	
<b>Comment</b>	
No comment.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC	
<b>Answer</b>	
<b>Document Name</b>	
<b>Comment</b>	
No comments	
Likes 0	
Dislikes 0	
<b>Response</b>	
Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name DTE Energy - DTE Electric	
<b>Answer</b>	
<b>Document Name</b>	
<b>Comment</b>	

No comments	
Likes 0	
Dislikes 0	
<b>Response</b>	
Julie Hall - Entergy - 6, Group Name Entergy/NERC Compliance	
<b>Answer</b>	
<b>Document Name</b>	
<b>Comment</b>	
2.4 Reactive Power Schedule should be defined and included the “which could include” statement one time and not repeated throughout the document. It impairs readability.	
Likes 0	
Dislikes 0	
<b>Response</b>	
Thank you for your comment. The periodic review team (PRT) retained this recommendation in Attachment 5 of the Periodic Review Recommendations: VAR-001-4.1 – Voltage and Reactive Control document, Item 3.1.	

**9. There are a number of other observations in Attachment 5 of the VAR-001-4.1 template that could enhance the standard, but would require a drafting team to develop for industry feedback. If you have any comments about these, please list the reference number when providing comment.**

**Julie Hall - Entergy - 6, Group Name** Entergy/NERC Compliance

**Answer**

**Document Name**

**Comment**

1.1 Disagree, these are separate actions by separate functional entities and need to be required independently. Could reword to say "...in automatic control mode as specified by the TOP".

2.1 Entergy does not find this unclear – is this a frequently violated or misunderstood requirement in the industry?

2.2 Disagree - don't see this as an action that will improve reliability. This seems like an administrative or business practice that is out of scope of the standard.

2.3 agree

2.4 disagree. the transmission operators are already tasked with maintaining the reliability of the BES in their interconnection by detailed means.

2.5 Recommend solving this issue with a glossary term, as commented above. Avoid excess noisy verbiage in the requirements that might cause confusion and impair readability.

3.1 Agree, see comments above.

4.1 and 4.2 - Disagree, would like to see "assess and schedule" added to R2 to make the wording more robust.

4.3 Agree - - term "instruct" should be used consistently throughout the standards (it is an Operating Instruction).

- 4.5 Agree, change to "all applicable" or "all non-exempt" also applies to part 1 of R5 severe VSL
- 4.6 Agree, Severe is for missing all of the applicable GOPs, High would be for missing 1 or more of non-exempt GOPs.
- 4.7 and 4.8 Agree
- 4.9 We agree that this information is important and needs to be considered, but feel that dynamic voltage schedules need to be developed into a new/separate requirement (new R6) and make the original R6 into R7.
- 5.1 agree
- 5.2 agree, recommend to go with "instruct" consistently in this and other standards. (see reasoning above)
- 5.3 Agree - TOP should coordinate with the "GSU Owner" rather than trying to specify any Functional Entity.
- 9.1 Not necessary for clarity - is this a highly violated and misunderstood requirement in industry?

Likes 0

Dislikes 0

**Response**

Thank you for your comments.

- 1.1 The periodic review team (PRT) retained this item (R5, Part 5.1 redundancy clause) based upon the majority of comments received from industry.
- 2.1 There is no current indication that these more recent versions of the VAR standards are frequently violated.
- 2.2 The PRT retained this item as many of the stakeholder responses indicate that clarity could be improved.
- 2.3 Thank you for your comments.

2.4 The PRT retained this item as many of the stakeholder responses indicate that clarity could be improved. Clarity could be addressed in the Guidelines and Technical Basis section.

2.5 Thank you for your comments.

3.1 Thank you for your comments.

4.1-4.2 The PRT retained this item as many of the stakeholder responses indicate that clarity could be improved in the Measure.

4.3-5.3 Thank you for your comments.

9.1 The PRT retained this item as many of the stakeholder responses indicate that clarity could be improved. There is no current indication that these more recent versions of the VAR standards are frequently violated.

**Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name** DTE Energy - DTE Electric

**Answer**

**Document Name**

**Comment**

No comments

Likes 0

Dislikes 0

**Response**

**Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name** Southern Company

**Answer**

**Document Name**

**Comment**

Item 1.1: R5.1 of VAR-001-4.1 is not a GOP requirement, so there is no redundancy with R1 of VAR-002-4.

Item 2.2: No additional clarity is needed for R2.2 of VAR-001-4.1 for how a TP determines the exemption criteria needs to be individually decided and not dictated.

Item 3.1: It is not necessary to define the terms listed in the article - generator owners and operators are already fully aware of the meaning of the terms.

Item 2.4: No additional clarity is needed around coordination of implementing voltage schedules at the same point in time. Transmission Operators are well aware of the system response to changes in voltage schedule and already take that into consideration.

Likes 0

Dislikes 0

**Response**

Thank you for your comments.

1.2 The periodic review team (PRT) retained this item (R5, Part 5.1 redundancy clause) based upon the majority of comments received from industry.

2.2 The PRT retained this item as many of the stakeholder responses indicate that clarity could be improved.

3.1 The PRT retained this item as many of the stakeholder responses indicate that clarity could be improved.

2.4 The PRT retained this item as many of the stakeholder responses indicate that clarity could be improved. Clarity could be addressed in the Guidelines and Technical Basis section.

**Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC**

**Answer**

<b>Document Name</b>	
<b>Comment</b>	
No comments	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Sandra Shaffer - Berkshire Hathaway - PacifiCorp - 6</b>	
<b>Answer</b>	
<b>Document Name</b>	
<b>Comment</b>	
No comment.	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>David Jendras - Ameren - Ameren Services - 1,3,6</b>	
<b>Answer</b>	
<b>Document Name</b>	
<b>Comment</b>	

For #1 in Attachment 5, VAR-002-4 Requirement R1 is not redundant with VAR-001-4.1 Requirement R5 in that it does not specify the location of the monitoring or control. VAR-002-4 Requirement R2, Part 2.3 does stipulate that the GOP must inform the TOP if the location is not the location the TOP required when they provided the voltage schedule. However, it does not allow for approval by the TOP of the methodology for conversion of the schedule. Therefore, the requirement in VAR-001-4.1 Requirement 5 should not be retired.

Likes 0

Dislikes 0

### Response

Thank you for your comments.

1.1 The periodic review team (PRT) retained this item based upon the majority of comments received from industry.

### Rachel Coyne - Texas Reliability Entity, Inc. - 10

Answer

Document Name

Comment

Texas RE does not have comments on this question.

Likes 0

Dislikes 0

### Response

Thank you for your comment.

### Russel Mountjoy - Midwest Reliability Organization - 10

Answer

Document Name

**Comment**

The review team has highlighted a number of issues that would help with clarification of requirements, however the review team has also indicated that this is not a highly violated standard, is practically implemented and addresses a reliability need.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Richard Jackson - U.S. Bureau of Reclamation - 1,5**

**Answer**

**Document Name**

**Comment**

Reclamation agrees with the proposed observations.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators**

**Answer**

**Document Name**

**Comment**

We thank the Periodic Review Team for identifying Paragraph 81 requirements within this standard. However, the team also identified the need for additional requirements. We believe this is a step in the wrong direction for a standard that is not often violated.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Elizabeth Axson - Electric Reliability Council of Texas, Inc. - 2**

**Answer**

**Document Name**

**Comment**

It may be helpful to define the terms “voltage schedules” and “Automatic Voltage Regulators” for the sake of clarity. There has been confusion around the terms “voltage schedules,” “reactive power schedules,” and “voltage limits.” The recent Reactive Power Planning Reliability Guideline has added some clarity to what is a “voltage schedule,” and it seems clear that this is not synonymous with “voltage limits,” but the definition could be clearer than the parentheticals in the requirements R1 and R5 today. Additionally there has been confusion between the voltage schedules in R1 and those mentioned in R5 if they are one and the same or different.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Michael Godbout - Hydro-Québec TransÉnergie - 1 - NPCC**

**Answer**

**Document Name**

**Comment**

Attachment 5, point 5.3.

In the Québec interconnection, a number of step-up transformers are owned by TOs. Standards like FAC-008-3 and PRC-025-1 allow for this reality. This standard does not (R6). We believe that when this standard is revised, this change should be made in order to make the standard consistently applicable.

This same requirement (R6) (and the matching requirements in VAR-002-4) do not seem to be RBS. In particular, they do not specify a performance to be achieved, only a means - tap changes - by which an unspecified goal must be attained. In the Enhanced Periodic Review, some parties stated that such a requirement regarding tap changes was necessary in some regions. Nevertheless, such a requirement currently calls out a single manner of achieving an unnamed goal. Currently, the requirement, as written, causes us no problems. However, when the standard is revised, it should be rewritten to reflect a performance-based approach.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**10. The team did not identify a concern related to cost effectiveness as drafted. Do you agree? If not, please provide additional detail.**

**Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC**

**Answer** No

**Document Name**

**Comment**

Per Question 7 – BPA believes any new requirement would need to be drafted in such a way that the needed functionality can be achieved without requiring the potential for replacing a bevy of equipment.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Sean Bodkin - Dominion - Dominion Resources, Inc. - 3,5,6**

**Answer** No

**Document Name**

**Comment**

Without additional information and studies it is difficult to determine cost impacts relative to the reliability benefits provided by the standard.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Shannon Mickens - Southwest Power Pool, Inc. (RTO) - 2 - SPP RE, Group Name SPP Standards Review Group**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Aubrey Short - FirstEnergy - FirstEnergy Corporation - 1,3,4**

**Answer** No

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Richard Jackson - U.S. Bureau of Reclamation - 1,5**

**Answer** Yes

**Document Name**

**Comment**

Reclamation does not have any concerns related to the cost effectiveness of VAR-001-4.1, but asserts that the standard would be more cost-effective after incorporating the above suggestions.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Sandra Shaffer - Berkshire Hathaway - PacifiCorp - 6**

**Answer**

Yes

**Document Name**

**Comment**

Cost effectiveness is always a concern but should not take precedence over reliability issues.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name DTE Energy - DTE Electric**

**Answer**

Yes

**Document Name**

**Comment**

No comments

Likes	0
Dislikes	0
<b>Response</b>	
<b>Hien Ho - Tacoma Public Utilities (Tacoma, WA) - 1,3,4,5,6</b>	
Answer	Yes
Document Name	
<b>Comment</b>	
Likes	0
Dislikes	0
<b>Response</b>	
<b>Rachel Coyne - Texas Reliability Entity, Inc. - 10</b>	
Answer	Yes
Document Name	
<b>Comment</b>	
Likes	0
Dislikes	0
<b>Response</b>	
<b>Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators</b>	

Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
<b>Russel Mountjoy - Midwest Reliability Organization - 10</b>	
Answer	Yes
Document Name	
Comment	
Likes 0	
Dislikes 0	
Response	
<b>Laura Nelson - IDACORP - Idaho Power Company - 1</b>	
Answer	Yes
Document Name	
Comment	
Likes 0	

Dislikes 0	
<b>Response</b>	
Chris Scanlon - Exelon - 1,3,5,6	
Answer	Yes
Document Name	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
David Jendras - Ameren - Ameren Services - 1,3,6	
Answer	Yes
Document Name	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
Stephanie Burns - International Transmission Company Holdings Corporation - 2 - MRO,SPP RE,RF	
Answer	Yes

<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Julie Hall - Entergy - 6, Group Name</b> Entergy/NERC Compliance	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Jesus Sammy Alcaraz - Imperial Irrigation District - 1</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	

**Response**

**Michelle Amarantos - APS - Arizona Public Service Co. - 1,3,5,6**

**Answer** Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Preston Walker - PJM Interconnection, L.L.C. - 2 - RF**

**Answer** Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Dennis Chastain - Tennessee Valley Authority - 1,3,5,6 - SERC**

**Answer** Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Glen Farmer - Avista - Avista Corporation - 1,3,5**

**Answer**

Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**11. Given the items identified by the periodic review team in the VAR-001-4.1 template, do you agree that the Reliability Standard is sufficient to protect reliability and meet the reliability objective of the standard and does not need immediate modification through standards development; however, there may be a future opportunity to improve any non-substantive or insignificant quality and content issues? If you have any other comments on this review that you haven't already mentioned above, please provide them here.**

**Stephanie Burns - International Transmission Company Holdings Corporation - 2 - MRO,SPP RE,RF**

**Answer** No

**Document Name**

**Comment**

Due to the lack of a requirement across all the NERC standards for any party to monitor reactive reserves, the VAR-001 standard should be revised to include such a requirement on the TOP. This standard review should be graded as REVISE – RED.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The consensus of the industry is the standard is sufficient to protect reliability and meet the reliability objective of the standard. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

**Elizabeth Axson - Electric Reliability Council of Texas, Inc. - 2**

**Answer** No

**Document Name**

**Comment**

ERCOT does believe the Reliability Standard is sufficient to protect reliability and meet the reliability objective of the standard and does not need immediate modification through standards development.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The consensus of the industry is the standard is sufficient to protect reliability and meet the reliability objective of the standard.

**Karie Barczak - DTE Energy - Detroit Edison Company - 3,4,5, Group Name DTE Energy - DTE Electric**

**Answer** Yes

**Document Name**

**Comment**

No comments

Likes 0

Dislikes 0

**Response**

**Michelle Amarantos - APS - Arizona Public Service Co. - 1,3,5,6**

**Answer** Yes

**Document Name**

**Comment**

AZPS recommends a change the Purpose to remove “monitoring” since there are no monitoring requirements.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. Monitoring of voltage is implicit in VAR-001-4.1 in the performance of the standard; therefore, the periodic review team (PRT) contends that the term “monitoring” should remain in the Purpose statement.

**Aaron Cavanaugh - Bonneville Power Administration - 1,3,5,6 - WECC**

**Answer** Yes

**Document Name**

**Comment**

No comments

Likes 0

Dislikes 0

**Response**

**Pamela Hunter - Southern Company - Southern Company Services, Inc. - 1,3,5,6 - SERC, Group Name Southern Company**

**Answer** Yes

**Document Name**

**Comment**

All suggested changes found in Attachment 4 of the periodic review are acceptable. The other changes suggested are not needed.

Likes	0
Dislikes	0
<b>Response</b>	
Thank you for your comment. The consensus of the industry is the standard is sufficient to protect reliability and meet the reliability objective of the standard. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to reflect the majority of industry comment.	
<b>Aubrey Short - FirstEnergy - FirstEnergy Corporation - 1,3,4</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
While our responses to Q1, Q2 and Q3 suggestion some improvements in the standard may be warranted based on the questions asked, we believe that overall the standard is sufficient. However, if the majority of industry also believes there may be some reliability impact to the items raised in Q1, Q2 and Q3 then NERC may need to further investigate those items through a standards development project.	
Likes	0
Dislikes	0
<b>Response</b>	
Thank you for your comment. The consensus of the industry is the standard is sufficient to protect reliability and meet the reliability objective of the standard. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to reflect the majority of industry comment.	
<b>Michael Cruz-Montes - CenterPoint Energy Houston Electric, LLC - 1 - Texas RE</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	

CenterPoint Energy believes that the VAR-001-4.1 Standard is sufficient to protect reliability and meet the reliability objective of the standard and does not need immediate modification through standards development. We appreciate the efforts of the review team in identifying potential areas for future improvement to low priority issues.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The consensus of the industry is the standard is sufficient to protect reliability and meet the reliability objective of the standard. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to reflect the majority of industry comment.

**Brian Van Gheem - ACES Power Marketing - 6 - NA - Not Applicable, Group Name ACES Standards Collaborators**

**Answer**

Yes

**Document Name**

**Comment**

We thank you for this opportunity to provide these comments.

Likes 0

Dislikes 0

**Response**

Thank you for your comment.

**Richard Jackson - U.S. Bureau of Reclamation - 1,5**

**Answer**

Yes

**Document Name**

**Comment**

Reclamation asserts that VAR-001-4.1 should be modified to include the proposed requirements, errata, and observations. Reclamation supports periodic reviews of standards like these as essential, and appreciates the work of the Periodic Review Team.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The consensus of the industry is the standard is sufficient to protect reliability and meet the reliability objective of the standard. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to reflect the majority of industry comment.

**Michael Godbout - Hydro-Québec TransÉnergie - 1 - NPCC**

**Answer** Yes

**Document Name**

**Comment**

The PRT has identified a number of issues. However, most issues identified so far seem relatively minor. We do not see a pressing need to revise the standard at this time. At some point though, the standard will have to be revised and cleaned up though.

Likes 0

Dislikes 0

**Response**

Thank you for your comment. The consensus of the industry is the standard is sufficient to protect reliability and meet the reliability objective of the standard. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to reflect the majority of industry comments.

**Glen Farmer - Avista - Avista Corporation - 1,3,5**

**Answer** Yes

<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Dennis Chastain - Tennessee Valley Authority - 1,3,5,6 - SERC</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Preston Walker - PJM Interconnection, L.L.C. - 2 - RF</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	

**Response**

**Sean Bodkin - Dominion - Dominion Resources, Inc. - 3,5,6**

**Answer** Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Jesus Sammy Alcaraz - Imperial Irrigation District - 1**

**Answer** Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Julie Hall - Entergy - 6, Group Name Entergy/NERC Compliance**

**Answer** Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**David Jendras - Ameren - Ameren Services - 1,3,6**

**Answer**

Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Ruida Shu - Northeast Power Coordinating Council - 1,2,3,4,5,6,7,8,9,10 - NPCC, Group Name RSC no ISO-NE**

**Answer**

Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

<b>Chris Scanlon - Exelon - 1,3,5,6</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Likes	0
Dislikes	0
<b>Response</b>	
<b>Laura Nelson - IDACORP - Idaho Power Company - 1</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Likes	0
Dislikes	0
<b>Response</b>	
<b>Sandra Shaffer - Berkshire Hathaway - PacifiCorp - 6</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	

Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Shannon Mickens - Southwest Power Pool, Inc. (RTO) - 2 - SPP RE, Group Name SPP Standards Review Group</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	
<b>Russel Mountjoy - Midwest Reliability Organization - 10</b>	
<b>Answer</b>	Yes
<b>Document Name</b>	
<b>Comment</b>	
Likes 0	
Dislikes 0	
<b>Response</b>	

**Gregory Campoli - New York Independent System Operator - 2, Group Name ISO/RTO Standards Review Committee**

**Answer** Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Hien Ho - Tacoma Public Utilities (Tacoma, WA) - 1,3,4,5,6**

**Answer** Yes

**Document Name**

**Comment**

Likes 0

Dislikes 0

**Response**

**Rachel Coyne - Texas Reliability Entity, Inc. - 10**

**Answer**

**Document Name**

**Comment**

Texas RE frequently encounters wind farms that do not recognize that the technology to maintain voltage is an AVR. Wind Farm Management Systems (under a variety of names) clearly demonstrate the capability to control voltage and are used daily but, because it is not specifically called an “AVR”, entities often miss responsibilities. With the penetration of wind, it is imperative that this get corrected globally, rather than one-off awareness (via an compliance discovery method) or workshops that are not necessarily attended by all parties. Texas RE has done outreach and will continue to do so but would encourage a project to clarify the VAR standards.

Likes 0

Dislikes 0

### Response

Thank you for your comment. The consensus of the industry is the standard is sufficient to protect reliability and meet the reliability objective of the standard. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to reflect the majority of industry comments. The PRT agrees that an Automatic Voltage Regulator (AVR) definition added in a future revision could provide additional clarity as identified in the VAR-001-4.1 Enhanced Periodic Review Recommendation document, Attachment 5: Other Miscellaneous Corrections/Revisions, Item 3.1.

### *Comments received from Leonard Kula of IESO*

#### Questions

- VAR-001-4.1 Requirement R4, regarding exemptions and exempted units, does not require periodic reviews or reviews triggered by changes; such as, technology, system conditions or other factors. Does this create an impact to reliability? If yes, please explain.

Yes

No

Comments:

**The exemption criteria may change due to changes in technology or system conditions, hence if not reviewed, may deem the previously established criteria invalid. A periodic review is necessary to ensure there are no reliability gaps.**

**Response**

Thank you for your comment. The periodic review team (PRT) concluded based on industry comment that the current TOP/IRO standards provide for an Operational Planning Analysis (OPA) and Real-time Assessment (RTA) that will identify any reliability issues; therefore, no immediate revision to the standard is warranted. Based on minority response, the PRT affirms that there may be future opportunities to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

2. If the voltage schedule issued by the TOP to the GOP (Requirement R5) results in a generating unit routinely running at maximum limits, does a lack of dynamic reactive reserve have a reliability impact?

Yes

No

Comments:

**We do not fully understand the question since the term “lack of dynamic reactive reserve” needs to be clarified wrt whether it means:**

- a. **Lack of dynamic reactive reserve capability?**
- b. **Lack of dynamic reactive reserve requirements?**
- c. **Both**

**Not knowing the exact meaning of the term, we are unable to provide relevant comment wrt whether or not the lack of any of the above can have a reliability impact.**

**In general, we hold the view that if there are dynamic reactive reserve requirements, then they need to be met by having sufficient dynamic reactive reserve capability. Hence, the lack of dynamic reactive requirements does not have any reliability impact. On the other hand, the lack of dynamic reactive reserve capability may or may not have any reliability impact; it depends on whether or not there are any dynamic reactive reserve requirements.**

**Response**

Thank you for your comment. The periodic review team (PRT) notes that industry submitted comments that the lack of reserves on a single unit would not pose a reliability issue regarding the need for a periodic review. Any issues involving multiple generating units would

be identified as part of an Operational Planning Analysis (OPA) or Real-Time Assessment (RTA). The PRT affirms that there may be future opportunity to revise the standard or provide technical guidance (e.g., guideline) outside of a Reliability Standard.

3. As of April 1, 2017, there will no longer be any explicit requirements for monitoring or ensuring adequate reactive reserves. Absent of any explicit requirements to monitor or ensure adequate reactive reserves within the IRO, TOP, or VAR standards, is there an impact to reliability? If yes, please explain.

Yes

No

Comments:

**We do not believe that explicit requirements to monitor or ensure adequate reactive reserves are needed. Reactive reserves are needed to support voltage schedule (R2), which in turn supports SOLs and IROLs (R1). The need to monitor and ensure sufficiency of reactive reserve is implicit in meeting Requirements R1 and R2 of VAR-001-4.1.**

#### Response

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that recently approved TOP/IRO standards address the issue and that no reliability gap exists. The PRT retained a general recommendation that a future Standards Authorization (SAR) or technical guideline outside of a NERC Reliability Standard could address monitoring reactive reserves as a minority of commenters noted reactive reserves should be monitored.

4. As VAR-001-4.1 Requirement R5, Part 5.2 is silent with regards to a time duration that a generator can be outside of voltage schedule before notification is required. If the TOP is not required to specify the timing portion of the notification requirements while maintaining the necessary flexibility, is there an impact to reliability? If yes, please explain.

Yes

No

Comments:

**We assume that the TOP will include in its notification requirement, the time duration that a generator can be outside of voltage schedule before notification is required. Hence we don't believe there is any reliability impact for not having such explicit wording. However, we are indifferent as to whether or not such wording should be added to Part 5.2.**

#### Response

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Template document to capture comments that VAR-001 Requirement 5.2 allows the flexibility to specify a time duration, requiring a time duration would be prescriptive, and that there may be future opportunity to provide technical guidance outside of a Reliability Standard.

5. VAR-001-4.1 Requirement R5 does not include the RC as a recipient of voltage or Reactive Power schedules issued to generators. Is there an impact to reliability? If yes, please explain.

Yes

No

Comments:

**The RC may have a reliability need to be notified the of voltage or Reactive Power schedules issued to generators. The requirement in Part 1.1 only addresses the situation when a request is made by the RC; it not address the situations when the TOP itself develops and conveys the schedule to the GOP. Not having the latter information can have a reliability impact if the RC needs to monitor and ensure adherence to the schedule.**

#### Response

Thank you for your comment. The periodic review team (PRT) has modified its Enhanced Periodic Review Recommendation document to capture the comments that IRO-010-2 addresses the issue by allowing the Reliability Coordinator to identify and request such information. Therefore, no reliability gap exists.

6. VAR-001-4.1 Requirement R5 dictates the status of an AVR. Does the lack of a similar requirement to identify the initial state of the PSS impact reliability? If yes, please explain.

- Yes  
 No

Comments:

**We believe that the default assumption is that the PSS is initially in service. A change to this initial status is required in VAR-002 (R3). This should suffice to ensure reliability. That said, we do not oppose strongly to adding an explicit requirement under VAR-001, R5.**

#### Response

Thank you for your comment. The periodic review team (PRT) appended the recommendation to note that industry comments affirm that it is not necessary to require notification of the initial state of the PSS. Regional practices, interconnection agreements, and data specifications can address the initial state of the PSS; therefore, revising the continent-wide VAR-001-4.1 standard is not necessary.

7. The continent-wide VAR standards do not address external control loops to the AVR that may impact the reactive response of a generator. Some external control loops do not have the purpose of automative voltage control, therefore, is there a need to coordinate external loops to prevent an impact to reliability?<sup>1</sup> If yes, please explain.

- Yes  
 No

Comments:

**Notes to IESO SME: please assess if we have similar set up in Ontario, and provide draft comment accordingly. Please see excerpt from NERC's assessment of the current VAR-001-4.1 (the VAR-001-4.1 template):**

<sup>1</sup> See also: Lesson Learned, Generator Distributed Control System Impact on Automatic Voltage Regulators, June 9, 2015, (<http://www.nerc.com/pa/rm/ea/Lessons Learned Document Library/LL20150602 Generator Distributed Control System Impact on Automatic Voltage Regulators.pdf>)

“The WECC variance E.A.18 is specific to external control loops to the manufacturer’s AVR control loop. Due to the system configuration of the WECC, it was one of the earlier adopters of AVR and PSS controls. Due to the age of the controls or difficulty with setting reactive droop compensation on some older style controls, external loop controls were implemented from the plant control system. This can be done via DCS or SCADA. Variance E.A.18 requires that if external controls are used, that they do not affect the AVR’s transient response during fault conditions. There is a need to determine if this type of control is used outside of the WECC. Adding this variance to the continent wide NERC standard might be justified if other utilities practice this method of voltage control and there have been documented cases that the external control hindered the AVR from responding properly during a fault event.”

#### Response

Thank you for your comment. The periodic review team (PRT) has modified the Enhanced Periodic Review document to reflect that industry comments did not reveal any reliability related need to address external control loops within the continent-wide Reliability Standard.

8. There are a number of errata (i.e., administrative) type observations listed in Attachment 4 of the VAR-001-4.1 template. If you disagree with any of the observations, please list the reference number when providing comment.

Comments:

**No comment.**

9. There are a number of other observations in Attachment 5 of the VAR-001-4.1 template that could enhance the standard, but would require a drafting team to develop for industry feedback. If you have any comments about these, please list the reference number when providing comment.

Comments:

**We generally agree with the proposed enhancements presented in Attachment 5, but do support developing the definitions for those terms listed under Section 3.1. The VAR-001 standard has been in place for almost 10 years and there have not been many issues with the lack of clarity associated with the terms “generator voltage schedule”, “generator Reactive Power schedule, “system voltage schedule,” and “automatic voltage regulator (AVR). We not believe that defining them will improve the understanding of the VAR-001 standard. Rather, adding these definitions to the NERC Glossary may**

**prolong the development and approval of the next VAR-001 version, and add unnecessary chore to maintaining the glossary down the road.**

#### Response

Thank you for your comment. The periodic review team (PRT) retained this recommendation in Attachment 5 of the Periodic Review Recommendations: VAR-001-4.1 – Voltage and Reactive Control document, Item 3.1.

10. The team did not identify a concern related to cost effectiveness as drafted. Do you agree? If not, please provide additional detail.

Yes

No

Comments:

11. Given the items identified by the periodic review team in the VAR-001-4.1 template, do you agree that the Reliability Standard is sufficient to protect reliability and meet the reliability objective of the standard and does not need immediate modification through standards development; however, there may be a future opportunity to improve any non-substantive or insignificant quality and content issues? If you have any other comments on this review that you haven't already mentioned above, please provide them here.

Yes

No

Comments:

***Additional comments received from John Seelke of LS Power Transmission, LLC***

VAR Standards Enhanced Periodic Review (EPR)  
Comments of Behalf of LS Power Transmission, LLC (LSPT)

The comments below address an issue with both VAR standards – VAR-001-4.1 and VAR-002-4. While the review team reviewed each standard individually, they did not identify the reliability issue discussed below. Because comments were requested separately for each standard, LSPT’s comments do not fit within either standard.

The issue is contradictory language regarding a Transmission Operator’s (TOP’s) obligations regarding the automatic voltage regulator obligations of its Generator Operators (GOPs). This issue can easily be addressed by the review team.

**VAR-001-4.1**, in part, is listed below:

**R5.** Each Transmission Operator shall specify a voltage or Reactive Power schedule (which is either a range or a target value with an associated tolerance band) at either the high voltage side or low voltage side of the generator step-up transformer at the Transmission Operator’s discretion.

*[Violation Risk Factor: Medium] [Time Horizon: Operations Planning]*

**5.1.** The Transmission Operator shall provide the voltage or Reactive Power schedule (which is either a range or a target value with an associated tolerance band) to the associated Generator Operator and direct the Generator Operator to comply with the schedule in automatic voltage control mode (the AVR is in service and controlling voltage).

The highlighted text in 5.1 *requires* the TOP to “direct the Generator Operator to comply with the schedule in automatic voltage control mode (the AVR in service and controlling voltage).” This language should be *deleted* because an AVR’s operation is more completely addressed in VAR-002-4, R1.

**R1.** The Generator Operator shall operate each generator connected to the interconnected transmission system in the automatic voltage control mode (with its automatic voltage regulator (AVR) in service and controlling voltage) or in a different control mode as instructed by the Transmission Operator unless: 1) the generator is exempted by the Transmission Operator, or 2) the Generator Operator has notified the Transmission Operator of one of the following: [Violation Risk Factor: Medium] [Time Horizon: Real-time Operations]

- That the generator is being operated in start-up,<sup>1</sup> shutdown,<sup>2</sup> or testing mode pursuant to a Real-time communication or a procedure that was previously provided to the Transmission Operator; or
- That the generator is not being operated in automatic voltage control mode or in the control mode that was instructed by the Transmission Operator for a reason other than start-up, shutdown, or testing.

While the first phrase in R1 *requires* the GOP to “operator each generator...in the automatic voltage control mode (with its automatic voltage regulator (AVR) in service and controlling voltage,” the remaining language in R1 describes *exceptions* to this rule. These exceptions require either the TOP’s approval or the TOP’s notification by its GOP. VAR-002-4, R1 contradicts VAR-001-4.1, part 5.1, because *no* TOP directive to its GOPs is required regarding AVR operation. Furthermore, part 5.1 *does not permit the exceptions* described in R1. Would a TOP that did not direct its GOPs on its AVR operation as required by part 5.1 be non-compliant with part 5.1? That question is moot if the highlighted language in VAR-001-4, part 5.1 were deleted.

Therefore, the language in R1 should be the *only* requirement addressing normal AVR operation. The confusion created highlighted language in VAR-001-4.1, part 5.1 can only have a negative impact on reliability.

## End of Report