

A. Introduction

1. **Title:** Reliability Coordinator Actions to Operate Within IROLs
2. **Number:** IRO-009-~~24~~
3. **Purpose:** To prevent instability, uncontrolled separation, or ~~e~~Cascading ~~outages~~ that adversely impacts the reliability of ~~the the interconnection~~Bulk Electric System by ensuring prompt action to prevent or mitigate instances of exceeding Interconnection Reliability Operating Limits (IROLs).
4. **Applicability:**
 - 4.1. Reliability Coordinator.
5. **Proposed Effective Date:**

~~In those jurisdictions where no regulatory approval is required, the standard shall become effective on the latter of either April 1, 2009 or the first day of the first calendar quarter, three months after BOT adoption.~~

~~In those jurisdictions where regulatory approval is required, the standard shall become effective on the latter of either April 1, 2009 or the first day of the first calendar quarter, three months after applicable regulatory approval.~~

B. Requirements

- R1.** For each IROL (in its Reliability Coordinator Area) that the Reliability Coordinator identifies one or more days prior to the current day, the Reliability Coordinator shall have one or more Operating Processes, Procedures, or Plans that identify actions it shall take or actions it shall direct others to take (up to and including load shedding): ~~that can be implemented in time to prevent exceeding those IROLs.~~ *(Violation Risk Factor: Medium) (Time Horizon: Operations Planning or Same Day Operations)*
 - R1.1.** ~~That can be implemented in time to prevent exceeding each of the identified~~those IROLs.
 - ~~R1.1.~~R1.2. ~~_____~~

~~For each IROL (in its Reliability Coordinator Area) that the Reliability Coordinator identifies one or more days prior to the current day, the Reliability Coordinator shall have one or more Operating Processes, Procedures, or Plans that identify actions it shall take or actions it shall direct others to take (up to and including load shedding) to mitigate the magnitude and duration of exceeding each of the identified that IROLs such that each the IROL is relieved within the IROL's T_v. (Violation Risk Factor: Medium) (Time Horizon: Operations Planning or Same Day Operations)~~
- R2.** When an assessment of actual or expected system conditions predicts that an IROL in its Reliability Coordinator Area will be exceeded, the Reliability Coordinator shall implement one or more Operating Processes, Procedures or Plans (not limited to the Operating Processes, Procedures, or Plans developed for Requirements R1) to prevent exceeding that IROL. *(Violation Risk Factor: High) (Time Horizon: Real-time Operations)*
- R3.** When actual system conditions show that there is ~~an instance of exceeding~~ an IROL exceedance in its Reliability Coordinator Area, the Reliability Coordinator shall;

~~without delay~~, act or direct others to act to mitigate the magnitude and duration of the instance of exceeding that IROL within the IROL's T_v . (*Violation Risk Factor: High*) (*Time Horizon: Real-time Operations*)

- R4.** If unanimity cannot be reached on the value for an IROL or its T_v , each Reliability Coordinator that monitors that Facility (or group of Facilities) shall, ~~without delay~~, use the most ~~limitingconservative~~ of the values ~~(the value with the least impact on reliability)~~ under consideration. (*Violation Risk Factor: High*) (*Time Horizon: Real-time Operations*)

C. Measures

M1. Each Reliability Coordinator shall have, and make available upon request, evidence to confirm that it has Operating Processes, Procedures, or Plans to address both preventing and mitigating instances of exceeding IROLs in accordance with Requirement R1 ~~and Requirement R2~~. This evidence shall include a list of any IROLs (and each associated T_v) identified in advance, along with one or more dated Operating Processes, Procedures, or Plans that that will be used. (R1)

~~M1.M2.~~ Each Reliability Coordinator shall have, and make available upon request, evidence to demonstrate that it implemented one or more Operating Processes, Procedures or Plans to prevent exceeding an IROL when an assessment of actual or expected system conditions predicted that that an IROL in its Reliability Coordinator area would be exceeded. (R2)

~~M2.M3.~~ Each Reliability Coordinator shall have, and make available upon request, evidence to confirm that it acted or directed others to act in accordance with Requirement R3 ~~and Requirement R4~~. This evidence could include, but is not limited to, Operating Processes, Procedures, or Plans from Requirement R1, dated operating logs, dated voice recordings, dated transcripts of voice recordings, or other evidence.

~~M3.M4.~~ For a situation where Reliability Coordinators disagree on the value of an IROL or its T_v the Reliability Coordinator shall have, and make available upon request, evidence to confirm that it used the most ~~limitingconservative~~ of the values under consideration, ~~without delay~~. Such evidence could include, but is not limited to, dated computer printouts, dated operator logs, dated voice recordings, dated transcripts of voice recordings, or other equivalent evidence. (R45)

D. Compliance

1. Compliance Monitoring Process

1.1. Compliance Enforcement Authority

For Reliability Coordinators that work for the Regional Entity, the ERO shall serve as the Compliance Enforcement Authority.

For Reliability Coordinators that do not work for the Regional Entity, the Regional Entity shall serve as the Compliance Enforcement Authority.

1.2. Compliance Monitoring Period and Reset Time Frame

Not applicable.

1.3. Compliance Monitoring and Enforcement Processes

Compliance Audits

Self-Certifications

Spot Checking

Compliance Violation Investigations

Self-Reporting

Complaints

Exception Reporting

1.4. Data Retention

The Reliability Coordinator, shall keep data or evidence to show compliance as identified below unless directed by its Compliance Enforcement Authority to retain specific evidence for a longer period of time as part of an investigation:

The Reliability Coordinator shall retain evidence of Requirements R1, ~~Requirement R2, R3 and R4~~ and Measures M1, ~~M2, M3 and M4~~ for a rolling 12 months.

~~The Reliability Coordinator shall retain evidence of Requirement R3, Requirement R4, Requirement R5, Measure M2, and Measure M3 for a rolling 12 months.~~

The Compliance Enforcement Authority shall keep the last audit records and all requested and submitted subsequent audit records, and all IROL Violation Reports submitted since the last audit.

1.5. Additional Compliance Information

Exception Reporting: For each instance of exceeding an IROL for time greater than IROL T_v , the Reliability Coordinator shall submit an IROL Violation Report to its Compliance Enforcement Authority within 30 days of the initiation of the event.

2. Violation Severity Levels

Requirement	Lower	Moderate	High	Severe
R1	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<p>An IROL in its Reliability Coordinator Area was identified one or more days in advance and the Reliability Coordinator does not have an Operating Process, Procedure, or Plan that identifies actions to prevent exceeding that IROL. (R1, Part 1.1)</p> <p><u>OR</u></p> <p><u>An IROL in its Reliability Coordinator Area was identified one or more days in advance and the Reliability Coordinator does not have an Operating Process, Procedure, or Plan that identifies actions to mitigate exceeding that IROL within the IROL's T_v. (R1, Part 1.2)</u></p>
R2				<p>An IROL in its Reliability Coordinator Area was identified one or more days in advance and the Reliability Coordinator does not have an Operating Process, Procedure, or Plan that identifies actions to mitigate exceeding that IROL within the IROL's T_v.</p>

Requirement	Lower	Moderate	High	Severe
				(R2)
R23				An assessment of actual or expected system conditions predicted that an IROL in the Reliability Coordinator’s Area would be exceeded, but no Operating Processes, Procedures, or Plans were implemented. (R3)
R34			Actual system conditions showed that there was an instance of exceeding an IROL in its Reliability Coordinator Area, and there was a delay of five minutes or more before acting or directing others to act to mitigate the magnitude and duration of the instance of exceeding that IROL, however the IROL was mitigated within the IROL T_v. (R4)Not Applicable	Actual system conditions showed that there was an instance of exceeding an IROL in its Reliability Coordinator Area, and that IROL was not resolved within the IROL’s T _v . (R34)
R45	Not applicable.	Not applicable.	Not applicable.	There was a disagreement on the value of the IROL or its T _v and the most conservative limit under consideration was not used. (R45)

E. Regional Variances

None

F. Associated Documents

IROL Violation Report

Version History

Version	Date	Action	Change Tracking
1	October 17, 2008	Adopted by NERC Board of Trustees	
1	March 17, 2011	Order issued by FERC approving IRO-009-1 (approval effective 5/23/11)	
<u>2</u>	<u>TBD</u>		