

NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

Draft TPL-007-1

Project 2013-03 Geomagnetic Disturbance (GMD) Mitigation

Standard Drafting Team

Industry Webinar

June 26, 2014

RELIABILITY | ACCOUNTABILITY




- Summary of changes to TPL-007-1
- Comments on benchmark GMD event
- Overview of GMD assessment process
- Next steps
- Question and answer

Presentation posted on the project page:

<http://www.nerc.com/pa/Stand/Pages/Geomagnetic-Disturbance-Resource.aspx>

- It is NERC's policy and practice to obey the antitrust laws to avoid all conduct that unreasonably restrains competition. This policy requires the avoidance of any conduct that violates, or that might appear to violate, the antitrust laws. Among other things, the antitrust laws forbid any agreement between or among competitors regarding prices, availability of service, product design, terms of sale, division of markets, allocation of customers or any other activity that unreasonably restrains competition.
- It is the responsibility of every NERC participant and employee who may in any way affect NERC's compliance with the antitrust laws to carry out this commitment.

- Participants are reminded that this meeting is public. Notice of the meeting was posted on the NERC website and widely distributed. Participants should keep in mind that the audience may include members of the press and representatives of various governmental authorities, in addition to the expected participation by industry stakeholders.



- Requires a **GMD Vulnerability Assessment** of the system for its ability to withstand a Benchmark GMD Event without causing a wide area blackout, voltage collapse, or damage to transformers, once every five years.
 - Applicability: Planning Coordinators, Transmission Planners
- Requires a **Transformer thermal impact assessment** to ensure that all high-side, wye grounded transformers connected at 200kV or higher will not overheat based on the Benchmark GMD Event
 - Applicability: Generator Owners, Transmission Owners

- Reordered the requirements
 - Comments indicated some confusion as to the order in which the requirements would be executed
- Established a floor of 15 Amperes (A) for Transformer Thermal Assessment
 - If calculated GIC is 15A or less, no further transformer thermal analysis is required
 - Technical justification: Continuous 15A exposure does not result in temperatures of concern, based on transformer testing
- Revised Implementation Plan
 - Moved earlier implementation steps (determine responsibilities, build models)
 - Maintained 4 year timeline to develop Corrective Action Plan

- Include Reliability Coordinators (RC) as an applicable entity
 - But, RCs included as a recipient of the analyses for information and for situational awareness
- Establish an exemption for lower latitude systems
 - Benchmark definition includes adjustment factors for earth conductivity and geomagnetic latitude, but assessment is required
 - Technical justification not available at this point
- Change the benchmark GMD event geoelectric field magnitude

- Benchmark geoelectric field is too low
 - Earlier work by GMD Task Force had peak fields of 20 V/km or more
 - “Spatial averaging” technique is not documented in peer-reviewed technical papers
- Benchmark geoelectric field is too high
 - Statistical analysis calculates to a field of 5.8 V/km
 - Visual extrapolation implies a field of 3-8 V/km (why not 3 V/km or 5.8 V/km?)

$$E_{\text{peak}} = E_{\text{benchmark}} \times \alpha \times \beta \text{ (in V/km)}$$


where,

E_{peak} = Benchmark geoelectric field magnitude at System location

$E_{\text{benchmark}}$ = Benchmark geoelectric field magnitude at reference location (60° N geomagnetic latitude, resistive ground model)


α = Factor adjustment for geomagnetic latitude


β = Factor adjustment for regional earth conductivity model



Statistical occurrence of spatially averaged high-latitude geoelectric field amplitudes from IMAGE magnetometer data (1993 – 2013)

- Statistical analyses (GMD Task Force and standards project) are based on the same data
- Spatial averaging of geomagnetic observation data is a appropriate for assessing wide-area impacts
- Benchmark is conservatively “high” to provide for margin, given the uncertainties associated with these types of calculations





- Formal Comment and Initial Ballot— June 13 – July 30, 2014
 - Technical Conference July 17, 2014
- SDT reviews ballot results and comments—August, 2014
- Post for a second ballot—August, 2014
- Seek NERC Board adoption at November meeting
- File with FERC by January 2015

- Project page: <http://www.nerc.com/pa/Stand/Pages/Project-2013-03-Geomagnetic-Disturbance-Mitigation.aspx>

Program Areas & Departments > Standards > Project 2013-03 Geomagnetic Disturbance Mitigation

Project 2013-03 Geomagnetic Disturbance Mitigation

Related Files

Draft	Action	Dates
Draft 2		
Stage 2 Standard	Ballot and Non-Binding Poll	
TPL-007-1 Clean Redline to Last Posted	Info>> Vote>>	07/21/14 – 07/30/14
Implementation Plan Clean Redline to Last Posted		
Supporting Materials Unofficial Comment Form (Word)		
Benchmark GMD Event White Paper Clean Redline to Last Posted	Comment Period	
Transformer Thermal Impact Assessment White Paper Clean Redline to Last Posted	Info>> Submit Comments>>	06/13/14 - 07/30/14
Thermal Screening Criterion white paper Common Questions and Responses		
	Join Ballot Pool>>	6/13/14 – 07/14/14



Questions and Answers

Send questions by chat