

June 12, 2014

VIA ELECTRONIC FILING

Ms. Erica Hamilton, Commission Secretary
British Columbia Utilities Commission
Box 250, 900 Howe Street
Sixth Floor
Vancouver, B.C.
V6Z 2N3

Re: *North American Electric Reliability Corporation*

Dear Ms. Hamilton:

The North American Electric Reliability Corporation (“NERC”) hereby submits Notice of Filing of the North American Electric Reliability Corporation of Proposed Reliability Standards VAR-001-4 and VAR-002-3 and the Retirement of Reliability Standards VAR-001-3 and VAR-002-2b. NERC requests, to the extent necessary, a waiver of any applicable filing requirements with respect to this filing.

Please contact the undersigned if you have any questions.

Respectfully submitted,

/s/ Holly A. Hawkins
Holly A. Hawkins
Associate General Counsel for
North American Electric Reliability
Corporation

Enclosure

3353 Peachtree Road NE
Suite 600, North Tower
Atlanta, GA 30326
404-446-2560 | www.nerc.com

**BEFORE THE
BRITISH COLUMBIA UTILITIES COMMISSION
OF THE PROVINCE OF BRITISH COLUMBIA**

**NORTH AMERICAN ELECTRIC)
RELIABILITY CORPORATION)**

**NOTICE OF FILING OF THE NORTH AMERICAN ELECTRIC RELIABILITY
CORPORATION OF PROPOSED RELIABILITY STANDARDS
VAR-001-4 AND VAR-002-3 AND THE RETIREMENT OF RELIABILITY
STANDARDS VAR-001-3 AND VAR-002-2b**

Gerald W. Cauley
President and Chief Executive Officer
North American Electric Reliability
Corporation
3353 Peachtree Road, N.E.
Suite 600, North Tower
Atlanta, GA 30326
(404) 446-2560

Charles A. Berardesco
Senior Vice President and General Counsel
Holly A. Hawkins
Assistant General Counsel
Shamai Elstein
Counsel
North American Electric Reliability
Corporation
1325 G Street, N.W., Suite 600
Washington, DC 20005
(202) 400-3000
charlie.berardesco@nerc.net
holly.hawkins@nerc.net
shamai.elstein@nerc.net

*Counsel for the North American Electric
Reliability Corporation*

June 12, 2014

TABLE OF CONTENTS

	Page
I. EXECUTIVE SUMMARY	2
II. NOTICES AND COMMUNICATIONS.....	7
III. BACKGROUND	8
A. NERC Reliability Standards Development Procedure	8
B. The Existing VAR Reliability Standards	8
1. Reliability Standard VAR-001-3	8
2. Reliability Standard VAR-002-2b	10
C. Procedural History of Project 2013-04 – Voltage and Reactive Control (VAR) .	11
IV. JUSTIFICATION	13
A. Basis and Purpose of the Proposed Reliability Standards	13
B. Requirements in the Proposed Reliability Standards.....	15
1. Reliability Standard VAR-001-4	15
2. Reliability Standard VAR-002-3	25
C. Proposed VAR-001-4 and VAR-002-3 Satisfy Outstanding FERC Directives....	31
D. Enforceability of the Proposed Reliability Standards.....	39
V. EFFECTIVE DATE.....	39
Exhibit A Proposed Reliability Standards	
Exhibit A-1 Proposed Reliability Standard VAR-001-4	
Exhibit A-2 Proposed Reliability Standard VAR-002-3	
Exhibit B Implementation Plan	
Exhibit C Reliability Standards Criteria	
Exhibit D Mapping Document	
Exhibit D-1 Mapping Document for Proposed Reliability Standard VAR-001-4	
Exhibit D-2 Mapping Document for Proposed Reliability Standard VAR-002-3	
Exhibit E Analysis of Violation Risk Factors and Violation Severity Levels	
Exhibit F Summary of Development History and Record of Development	
Exhibit G Standard Drafting Team Roster	

**BEFORE THE
BRITISH COLUMBIA UTILITIES COMMISSION
OF THE PROVINCE OF BRITISH COLUMBIA**

**NORTH AMERICAN ELECTRIC)
RELIABILITY CORPORATION)**

**NOTICE OF FILING OF THE NORTH AMERICAN ELECTRIC RELIABILITY
CORPORATION OF PROPOSED RELIABILITY STANDARDS
VAR-001-4 AND VAR-002-3 AND THE RETIREMENT OF RELIABILITY
STANDARDS VAR-001-3 AND VAR-002-2b**

The North American Electric Reliability Corporation (“NERC”) hereby submits proposed Reliability Standards VAR-001-4 (Voltage and Reactive Control) and VAR-002-3 (Generator Operation for Maintaining Network Voltage Schedules).¹ The proposed Reliability Standards VAR-001-4 and VAR-002-3 are just, reasonable, not unduly discriminatory or preferential, and in the public interest.² NERC also provides notice of (i) the associated Implementation Plan, (ii) the associated Violation Risk Factors (“VRFs”) and Violation Severity Levels (“VSLs”), and (iii) the retirement of currently effective Reliability Standards VAR-001-3 and VAR-002-2b, as detailed in this filing.

This filing presents the technical basis and purpose of proposed Reliability Standards VAR-001-4 and VAR-002-3, a summary of the development history, and a demonstration that the proposed Reliability Standards meet the Reliability Standards criteria. This filing is organized as follows: First, the filing presents an executive summary of the proposed Reliability

¹ The NERC Board of Trustees approved proposed Reliability Standards VAR-001-4 on February 6, 2014 and VAR-002-3 on May 7, 2014.

² Unless otherwise designated, all capitalized terms shall have the meaning set forth in the *Glossary of Terms Used in NERC Reliability Standards* (“NERC Glossary”), available at http://www.nerc.com/files/Glossary_of_Terms.pdf.

Standards. Next, the filing provides background on the regulatory structure governing the Reliability Standards approval process, as well as information on the existing Reliability Standards that proposed VAR-001-4 and VAR-002-3 Reliability Standards will replace. The filing then discusses the proposed Reliability Standards in detail, including how they satisfy the Reliability Standards criteria. Finally, we provide the requested effective date for the proposed Reliability Standards.

The following documents are attached as exhibits to this filing: (a) the proposed Reliability Standards (Exhibit A, with VAR-001-4 as Exhibit A-1 and VAR-002-3 as Exhibit A-2), (b) the proposed Implementation Plan for the proposed Reliability Standards (Exhibit B), (c) a discussion of how the proposed Reliability Standards satisfy the Reliability Standards criteria (Exhibit C), (d) mapping documents showing how the proposed Reliability Standards compare to the corresponding existing Reliability Standards (Exhibit D, with VAR-001-4 compared against VAR-001-3 as Exhibit D-1 and VAR-002-3 compared against VAR-002-2b as Exhibit D-2), (e) an analysis of the VRFs and VSLs for the proposed Reliability Standards (Exhibit E), (f) a summary of the development history and record of development for the proposed Reliability Standards (Exhibit F), and (g) the standard drafting team roster (Exhibit G).

I. EXECUTIVE SUMMARY

The Voltage and Reactive (“VAR”) group of Reliability Standards, which consists of two continent-wide Reliability Standards, VAR-001-3 and VAR-002-2b,³ is designed to maintain voltage stability on the Bulk-Power System, protect transmission, generation, distribution, and

³ The VAR group of Reliability Standards also includes two regional Reliability Standards, VAR-002-WECC-1 and VAR-501-WECC-1. NERC is not proposing any modifications to these regional Reliability Standards. Additionally, VAR-001-3 includes a regional variance developed by the Western Electricity Coordinating Council (“WECC”) applicable to Generator Operators located in the WECC region. NERC has not substantively modified the WECC regional variance and it will be carried forward as part of VAR-001-4. Accordingly, this filing does not discuss the two regional Reliability Standards or the regional variance.

customer equipment, and support the reliable operation of the Bulk-Power System. Voltage stability is the ability of a power system to maintain acceptable voltage levels throughout the system under normal operating conditions and following a disturbance. Failure to maintain acceptable voltage levels (*i.e.*, voltage levels become too high or too low) may cause violations of System Operating Limits (“SOLs”) and Interconnection Reliability Operating Limits (“IROLs”), result in damage to Bulk-Power System equipment, and thereby threaten the reliable operation of the Bulk-Power System. The primary factor in maintaining voltage stability is having the appropriate amount of Reactive Power on the system.⁴ Proposed Reliability Standards VAR-001-4 and VAR-002-3 are intended to replace and improve upon Reliability Standards VAR-001-3 and VAR-002-2b, respectively, to ensure that the Bulk-Power System operates at acceptable voltage levels and that sufficient Reactive Power is available to maintain voltage stability.

In general, proposed Reliability Standard VAR-001-4 sets forth the requirements applicable to Transmission Operators for scheduling, monitoring, and controlling Reactive Power resources in the Real-time Operations, Same-day Operations, and Operational Planning time horizons to regulate voltage and Reactive Power flows for the reliable operation of the Bulk-Power System. Proposed Reliability Standard VAR-002-3 sets forth the requirements applicable to Generator Operators and Generator Owners for providing the necessary reactive support and voltage control necessary to maintain reliable operations. Generators are the largest and most reliable Reactive Power resource and play an integral role in maintaining voltage stability on the Bulk-Power System. Collectively, the proposed Reliability Standards are designed to prevent voltage instability and voltage collapse on the Bulk-Power System.

⁴ Reactive Power is the portion of electricity that establishes and sustains the electric and magnetic fields of Bulk-Power System equipment and supports voltage stability.

As described further below, proposed Reliability Standard VAR-001-4 requires each Transmission Operator to:

- Specify a system-wide voltage schedule (which is either a range or a target value with an associated tolerance band) as part of its plan to operate within SOLs and IROLs, and to provide the voltage schedule to its Reliability Coordinator and adjacent Transmission Operators upon request (Requirement R1);
- Schedule sufficient reactive resources to regulate voltage levels (Requirement R2);
- Operate or direct the operation of devices to regulate transmission voltage and reactive flows (Requirement R3);
- Develop a set of criteria to exempt generators from certain requirements under Reliability Standard VAR-002-3 related to voltage or Reactive Power schedules, automatic voltage regulations, and notification (Requirement R4);
- Specify a voltage or Reactive Power schedule (which is either a range or a target value with an associated tolerance band) for generators at either the high or low voltage side of the generator step-up transformer, provide the schedule to the associated Generator Operator, direct the Generator Operator to comply with that schedule in automatic voltage control mode, provide the Generator Operator the notification requirements for deviating from the schedule, and, if requested, provide the Generator Operator the criteria used to develop the schedule (Requirement R5); and
- Communicate step-up transformer tap changes, the time frame for completion, and the justification for these changes to Generator Owners (Requirement R6).

Proposed Reliability Standard VAR-002-3 requires each Generator Operator to:

- Operate each of its generators connected to the interconnected transmission system in automatic voltage control mode or in a different control mode as instructed by the Transmission Operator, unless the Generator Operator (1) is exempted pursuant to the criteria developed under VAR-001-4, Requirement R4, or (2) makes certain notifications to the Transmission Operator specifying the reasons it cannot so operate (Requirement R1);
- Maintain the Transmission Operator's generator voltage or Reactive Power schedule, unless the Generator Operator (1) is exempted pursuant to the criteria developed under VAR-001-4, Requirement R4, or (2) complies with the notification

requirements for deviations as established by the Transmission Owner pursuant to VAR-001-4, Requirement R5 (Requirement R2);⁵

- Notify the Transmission Operator of a change in status of its voltage controlling device within 30 minutes, unless the status is restored within that time period (Requirement R3); and
- Notify the Transmission Operator of a change in reactive capability due to factors other than those described in VAR-002-3, Requirement R3 within 30 minutes unless the capability has been restored during that time period (Requirement R4).

Proposed Reliability Standard VAR-002-3 also requires each Generator Owner to:

- Provide information on its step-up transformers and auxiliary transformers within 30 days of a request from the Transmission Operator or Transmission Planner (Requirement R5); and
- Comply with the Transmission Operator's step-up transformer tap change directives unless compliance would violate safety, an equipment rating, or applicable laws, rules or regulations (Requirement R6).

The proposed Reliability Standards were developed to address outstanding Federal Energy Regulatory Commission ("FERC") directives from Order Nos. 693⁶ and 724⁷ and build upon the previous versions of the Reliability Standards to improve their quality and content.⁸ In addition to addressing certain FERC directives, the proposed Reliability Standards streamline language for increased clarity, omit requirements duplicative with or otherwise unnecessary when compared to existing Reliability Standards, and remove requirements that provide little to

⁵ VAR-002-3, Requirement R2 also provides that: (1) when a generator's AVR is out of service or the generator does not have AVR, the Generator Operator shall use an alternative method to control the generator's Reactive Power output to meet the schedule; (2) when instructed to modify voltage, the Generator Operator shall comply or provide an explanation of why the schedule cannot be met; and (3) if the Generator Operator does not monitor voltage at the location specified in its voltage schedule, it shall have a methodology for converting the scheduled voltage specified by the Transmission Operator to the voltage point being monitored by the Generator Operator.

⁶ *Mandatory Reliability Standards for the Bulk Power System*, Order No. 693, FERC Stats. & Regs. ¶ 31,242 (2007), *order on reh'g*, Order No. 693-A, 120 FERC ¶ 61,053 (2007).

⁷ *Electric Reliability Organization Interpretations of Specific Requirements of Frequency Response and Bias and Voltage and Reactive Control Reliability Standards*, Order No. 724, 127 FERC ¶ 61,158 (2009).

⁸ Exhibits D-1 and D-2 to this filing provide mapping documents comparing the existing VAR-001-3 and VAR-002-2b Reliability Standards to the proposed VAR-001-4 and VAR-002-3 Reliability Standards.

no reliability benefit. As discussed further below, Reliability Standard VAR-001-4 improves upon the prior version of the standard as follows:

- Requirements that are duplicative of other currently enforceable and pending Reliability Standards are removed.
- Requirement R1 improves reliability by requiring Transmission Operators to (1) define system voltage schedules, which may be a range or a target value with an associated tolerance band, to help ensure the Bulk-Power System operates within operating limits, and (2) coordinate with adjacent Transmission Operators and Reliability Coordinators regarding those system voltage schedules.
- Requirement R2 consolidates Requirements R2 and R9 of VAR-001-3 to clarify the Transmission Operator’s responsibility to schedule sufficient reactive resources to regulate voltage levels under normal and Contingency conditions.⁹
- Requirement R3 consolidates Requirements R7 and R8 of VAR-001-3 to clarify the Transmission Operator’s responsibility to provide the necessary voltage support (*i.e.*, “operate or direct the Real-time operation of devices”¹⁰) to help maintain voltage stability.
- Requirement R4 continues to provide Transmission Operators the flexibility to exempt generators from certain compliance obligations, but clarifies the obligations from which generators may be exempt. Requirement R4 also eliminates the need for Transmission Operators to maintain a list of all generators that have been granted an exemption as such a requirement provides little to no reliability benefit.
- Requirement R5 creates a more transparent information-sharing process between Transmission Operators and Generator Operators about voltage or Reactive Power schedules and notification requirements for deviating from such schedules.
- Requirement R5 also addresses the Commission’s Order No. 693 directive to consider a time frame associated with an “incident” of non-compliance with VAR-002,¹¹ as well as the Order No. 724 directive to develop and implement technically sound voltage schedules.

Further, in proposed Reliability Standard VAR-002-3:

⁹ A Contingency is defined in the NERC Glossary as “the unexpected failure or outage of a system component, such as a generator, transmission line, circuit breaker, switch or other electrical element.”

¹⁰ VAR-001-4, Requirement R3.

¹¹ As further discussed in Section IV.C, this FERC directive was issued in reference to Reliability Standard VAR-002. However, the standard drafting team determined that this directive is more appropriately addressed in VAR-001-4, Requirement R5.

- Requirements R1 and R2 carry forward the obligations that Generator Operators operate in automatic voltage control mode and follow the voltage or Reactive Power schedule provided by the Transmission Operator but provide Generator Operators increased flexibility to deviate from voltage or Reactive Power schedules and operational modes where system-specific circumstances or events may require these deviations to protect reliability and prevent equipment damage.
- Requirements R3 and R4 remove unnecessary and overly burdensome communication requirements that provide little to no reliability benefit. Eliminating these notification requirements will enable Transmission Operators to focus resources on improving system monitoring and responding to voltage issues as they may arise in Real-time.
- Requirements R5 and R6 improve clarity by removing extraneous language (Requirement R5) and adopting consistent language throughout the requirement (Requirement R6), which will help responsible entities understand and more effectively apply these requirements.

For the reasons discussed herein, proposed Reliability Standards VAR-001-4 and VAR-002-3 are just, reasonable, not unduly discriminatory or preferential, and in the public interest.

II. NOTICES AND COMMUNICATIONS

Notices and communications with respect to this filing should be addressed to the following:

Charles A. Berardesco
 Senior Vice President and General Counsel
 Holly A. Hawkins
 Assistant General Counsel
 Shamai Elstein
 North American Electric Reliability Corporation
 1325 G Street, N.W., Suite 600
 Washington, DC 20005
 (202) 400-3000
charlie.berardesco@nerc.net
holly.hawkins@nerc.net
shamai.elstein@nerc.net

Valerie Agnew
 Director of Standards Development
 North American Electric Reliability
 Corporation
 3353 Peachtree Road, N.E.
 Suite 600, North Tower
 Atlanta, GA 30326
 (404) 446-2560
valerie.agnew@nerc.net

III. BACKGROUND

A. NERC Reliability Standards Development Procedure

NERC develops Reliability Standards in accordance with Section 300 of the NERC Rules of Procedure and the NERC Standard Processes Manual.¹² The NERC Rules of Procedure provide for reasonable notice and opportunity for public comment, due process, openness, and a balance of interests in developing Reliability Standards, and thus satisfy certain of the criteria for approving Reliability Standards. The development process is open to any person or entity with a legitimate interest in the reliability of the Bulk-Power System. NERC considers all stakeholder comments and requires a vote by stakeholders as well as the NERC Board of Trustees to approve a Reliability Standard before NERC will submit the Reliability Standard to the applicable governmental authorities. NERC developed proposed Reliability Standards VAR-001-4 and VAR-002-3 in an open and fair manner and in accordance with this process.

B. The Existing VAR Reliability Standards

1. Reliability Standard VAR-001-3

Currently enforceable Reliability Standard VAR-001-3 requires Transmission Operators to monitor, control and maintain voltage levels, reactive flows and reactive resources within certain limits in Real-time to protect equipment and the reliable operation of the Interconnection.¹³ Under the existing requirements,¹⁴ each Transmission Operator is required to:

¹² Rules of Procedure of the North American Electric Reliability Corporation, § 300 (“NERC Rules of Procedure”), available at <http://www.nerc.com/AboutNERC/Pages/Rules-of-Procedure.aspx>; Standard Processes Manual, v.3 (June 26, 2013), available at http://www.nerc.com/comm/SC/Documents/Appendix_3A_StandardsProcessesManual.pdf.

¹³ As noted above, VAR-001-3 also includes a regional variance applicable to Generator Operators in the Western Interconnection. Because NERC is not proposing any substantive changes to that regional variance, it is not discussed herein.

¹⁴ Requirement R5 has been retired effective January 21, 2014.

- Individually and jointly with other Transmission Operators ensure that formal policies and procedures are developed, maintained and implemented for monitoring and controlling voltage levels and MVar flows within their individual areas and the areas of neighboring Transmission Operators (Requirement R1);
- Acquire sufficient reactive resources within its areas to protect voltage levels under normal and Contingency conditions (Requirement R2);
- Specify criteria to exempt generators from compliance with the voltage or Reactive Power schedule developed by the Transmission Operator in accordance with VAR-001-3, maintain a list of exempted generators, and notify Generator Owners of any exempted generators (Requirement R3);
- Specify a voltage or Reactive Power schedule at the interconnection between the generator facilities and Transmission Owner’s facilities, provide the schedule to the associated Generator Operator, and direct it to comply with the schedule in automatic voltage control mode (Requirement R4);
- Know the status of all transmission Reactive Power resources and, when notified of the loss of an automatic voltage regulator (“AVR”) control, direct the Generator Operator to maintain or change its voltage or Reactive Power schedule (Requirement R6);
- Operate or direct operations of devices to regulate transmission voltage and reactive flow (Requirement R7);
- Operate or direct operations of capacitive and inductive reactive resources within its area to maintain system and Interconnection voltages within established limits (Requirement R8);
- Maintain reactive resources to support its voltage under first Contingency conditions and disperse and locate these resources to allow for effective and quick application when Contingencies occur (Requirement R9);
- Correct and report SOL and IROL violations resulting from reactive resource deficiencies (Requirement R10);
- Consult with and provide documentation to Generator Owners about required tap changes, timeframes for completion, and technical justification for these changes (Requirement R11); and
- Direct corrective action necessary to prevent voltage collapse when reactive resources are insufficient.

Currently enforceable Reliability Standard VAR-001-3, however, does not address the following outstanding FERC directives from Order Nos. 693 and 724:

- Include Reliability Coordinators as responsible entities;¹⁵
- Address the power factor range at the interface between Load Serving Entities (“LSEs”) and the Bulk-Power System;¹⁶
- Consider acceptable ranges of net power factors where LSEs receive service from the Bulk-Power System;¹⁷
- Specify and define requirements on “established limits” and “sufficient reactive resources” and identify voltage and Reactive Power margins to prevent voltage instability;¹⁸
- Require the performance of periodic voltage stability analysis using online and offline techniques to assist Real-time operations;¹⁹ and
- Ensure voltage schedules reflect sound engineering and operating judgment and experience.²⁰

As discussed below, proposed Reliability Standard VAR-001-4 or other existing or pending

Reliability Standards address these outstanding FERC directives.

2. Reliability Standard VAR-002-2b

Currently enforceable Reliability Standard VAR-002-2b requires that generators provide reactive and voltage control necessary to maintain voltage levels, reactive flows and reactive resources within applicable facility ratings to protect equipment and the reliable operation of the Interconnection. Under the existing requirements, each Generator Operator is required to:

- Operate in automatic voltage control mode unless it is exempted or the Generator Operator notifies its Transmission Operator that it is (1) operating the generator in start-up or shutdown mode pursuant to a Real-time communication or a procedure previously provided to the Transmission Operator, or (2) not operating the generator in automatic voltage control mode for a reason other than start-up or shutdown (Requirement R1);

¹⁵ Order No. 693 at P 1855.

¹⁶ *Id.* at P 1861.

¹⁷ *Id.* at PP 1860, 1862.

¹⁸ *Id.* at P 1868.

¹⁹ *Id.* at P 1875.

²⁰ Order No. 724 at P 49.

- Maintain the voltage or Reactive Power schedule, unless otherwise exempted by the Transmission Operator, use an alternative method for controlling the generator voltage and Reactive Power output when a generator’s AVR is out of service, and, when directed to modify voltage, provide an explanation to the Transmission Operator if it cannot meet the schedule (Requirement R2); and
- Notify its Transmission Operator as soon as practical, but within 30 minutes, of a status or capability change on any Reactive Power resource (generator or other), including the status of each AVR and power system stabilizer, and the expected duration of the identified change (Requirement R3).

Reliability Standard VAR-002-2b also requires each Generator Owner to:

- Provide tap-related information on step-up transformers and auxiliary transformers with primary voltages equal to or greater than the generator terminal voltage within 30 calendar days of a request from the Transmission Operator and Transmission Planner (Requirement R4); and
- Ensure that transformer tap positions are changed according to the Transmission Operator’s specifications, unless this action would violate safety, an equipment rating, or a regulatory or statutory requirement, in which case the Generator Owner must notify the Transmission Operator and justify why the Generator Owner is unable to comply (Requirement R5).

Currently enforceable Reliability Standard VAR-002-2b does not address FERC’s directive to consider an additional time frame associated with an “incident” of non-compliance with VAR-002.²¹ As discussed below, this directive is addressed in proposed Reliability Standard VAR-001-4.

C. Procedural History of Project 2013-04 – Voltage and Reactive Control (VAR)

In February 2013, NERC initiated an informal development process to revive efforts to modify the existing VAR Reliability Standards to address the outstanding FERC directives from Order Nos. 693 and 724 related to those standards.²² Participants in this informal process were industry subject matter experts, NERC staff, and FERC staff from the Office of Electric

²¹ Order No. 693 at PP 1883, 1885.

²² In 2008, NERC initiated Project 2008-01 to address the directives from Order No. 693 related to the VAR Reliability Standards. That project was not completed due to project reprioritization.

Reliability. The informal development group met numerous times between February 2013 and July 2013 to discuss the outstanding FERC directives and ways to improve the existing VAR Reliability Standards. The informal group also conducted industry outreach to obtain feedback on the existing standards.

After evaluating the VAR Reliability Standards and FERC's directives, the informal group concluded that certain of the existing requirements and outstanding directives overlapped with or were duplicative of requirements in other Reliability Standards to maintain and operate within SOLs and IROLs or were otherwise unnecessary from a reliability perspective. To that end, the informal participants developed revised drafts of the VAR Reliability Standards to address FERC directives, eliminate duplicative or unnecessary requirements, and improve the quality and content of those existing requirements that are necessary to help maintain voltage stability on the Bulk-Power System.

As discussed further in Exhibit F, Project 2013-04 formally commenced on July 19, 2013 with the posting of a Standard Authorization Request ("SAR") along with the initial drafts of the proposed Reliability Standards developed by the informal participants for a 45-day comment period and ballot. A formal standard drafting team was formed following the posting of the SAR and the initial drafts of the proposed Reliability Standards.²³

Following the close of the initial ballot, the standard drafting team addressed industry comments and posted second drafts of the proposed Reliability Standards on October 11, 2013 for an additional 45-day comment period and ballot. Proposed Reliability Standard VAR-001-4 received the requisite approval during the second ballot and was subsequently posted for a final ballot. The final ballot concluded on December 23, 2013 and received an approval rating of

²³ Exhibit G provides the standard drafting team roster.

75.35%. The NERC Board of Trustees approved proposed Reliability Standard VAR-001-4 on February 6, 2014.

The standard drafting team addressed additional industry comments on the second draft of proposed Reliability Standard VAR-002-3 and, on February 27, 2014, posted a third draft of the standard for a 45-day comment period and ballot. Proposed Reliability Standard VAR-002-3 received the requisite approval in the third ballot and was subsequently posted for a final ballot. The final ballot concluded on May 5, 2014 and received an approval rating of 88.26%. The NERC Board of Trustees approved proposed Reliability Standard VAR-002-3 on May 7, 2014.

IV. JUSTIFICATION

As discussed below and in Exhibit C, proposed Reliability Standards VAR-001-4 and VAR-002-3 are just, reasonable, not unduly discriminatory or preferential, and in the public interest. The following sections provide: (1) the basis and purpose of the proposed Reliability Standards; (2) a discussion of the requirements in the proposed Reliability Standards; (3) an explanation of how the proposed Reliability Standards satisfy outstanding FERC directives from Order Nos. 693 and 724; and (4) a discussion of the enforceability of the proposed Reliability Standards.

A. Basis and Purpose of the Proposed Reliability Standards

Proposed Reliability Standards VAR-001-4 and VAR-002-3 replace and improve upon the prior versions of the standards (VAR-001-3 and VAR-002-2b) by addressing outstanding FERC directives from Order Nos. 693 and 724, improving reliability, clarifying language in certain requirements, and eliminating redundant or unnecessary requirements. As is further discussed in Section IV.C below, the outstanding FERC directives are addressed by proposed Reliability Standards VAR-001-4 and VAR-002-3, or already have been addressed in other currently enforceable or pending Reliability Standards. So as to avoid unnecessary redundancies

or duplicative requirements, NERC does not propose to address in VAR-001-4 and VAR-002-3 those directives already addressed by other existing or pending Reliability Standards.

The standard drafting team sought to modify the currently enforceable Reliability Standards VAR-001-3 and VAR-002-2b to improve the clarity, quality, and content of the standards. These efforts include, but are not limited to, the following:

- VAR-001-4, Requirement R1 removes voltage level controls and monitoring obligations duplicative with other currently enforceable Reliability Standards and improves reliability by requiring Transmission Operators to (1) specify system voltage schedules, which may be either a range or a target value with associated tolerance bands, and (2) coordinate with adjacent Transmission Operators and Reliability Coordinators regarding those system voltage schedules.
- VAR-001-4, Requirements R2 and R3 simplify and consolidate several existing requirements while ensuring sufficient reactive resources are scheduled (Requirement R2) and voltage support is provided (Requirement R3).
- VAR-001-4, Requirement R4 removes unnecessary compliance complexities and offers Transmission Operators the flexibility to tailor exemption criteria to area-specific needs.
- VAR-001-4, Requirement R5 improves transparency of Transmission Operator voltage or Reactive Power schedules for generators and provides the Transmission Operator the flexibility to develop notification requirements for deviations from those schedules based on the unique characteristics and needs of its system.
- VAR-001-4, Requirement R6 maintains and improves upon the existing tap setting requirements to avoid an adverse reliability impact caused by an improper tap setting that in turn may affect the Reactive Power output of a generator.
- VAR-002-3, Requirement R1 improves upon the prior version of the Reliability Standard by providing an option for certain Generator Operators to operate in modes other than automatic voltage control mode, as may be instructed by the Transmission Operator. Further, in addition to start-up or shutdown, Requirement R1 adds testing as a time when a generator need not operate in automatic voltage control mode or a different mode instructed by the Transmission Operator.
- VAR-002-3, Requirement R2 carries forward the requirement that Generator Operators maintain the generator voltage or Reactive Power schedule provided by the Transmission Operator pursuant to VAR-001-4, Requirement R5 but allows the Generator Operator to deviate from that schedule if it is exempted or satisfies the notification requirements established by the Transmission Operator under VAR-001-4, Requirement R5, Part 5.2. VAR-002-3, Requirement R2 also clarifies that Generator Operators that do not monitor voltage at the location specified in their voltage schedule provided by the Transmission

Operator may convert the schedule to the voltage point monitored by the Generator Operator using a documented conversion methodology.

- VAR-002-3, Requirements R3 and R4 limit status change notification requirements to those changes lasting longer than 30 minutes because notification of changes resolved within a 30-minute window provides minimal, if any, reliability benefit.
- VAR-002-3, Requirements R5 and R6 include clarifying edits to remove an unnecessary sub-part (Requirement R5) and uniformly reference the applicable entity (Requirement R6).

B. Requirements in the Proposed Reliability Standards

1. Reliability Standard VAR-001-4

Proposed Reliability Standard VAR-001-4 consists of six requirements and is applicable to Transmission Operators and, for the WECC regional variance maintained and carried forward from Reliability Standard VAR-001-3, Generator Operators within the Western Interconnection. An explanation of the six requirements and the omission of certain VAR-001-3 requirements are provided below.²⁴

VAR-001-4, Requirement R1

R1. Each Transmission Operator shall specify a system voltage schedule (which is either a range or a target value with an associated tolerance band) as part of its plan to operate within System Operating Limits and Interconnection Reliability Operating Limits.

1.1. Each Transmission Operator shall provide a copy of the voltage schedules (which is either a range or a target value with an associated tolerance band) to its Reliability Coordinator and adjacent Transmission Operators within 30 calendar days of a request.

Requirement R1 is intended to replace and simplify the currently-effective VAR-001-3, Requirement R1, which requires Transmission Operators, individually and jointly, to develop formal policies and procedures for controlling and monitoring voltage levels and MVar flows. In

²⁴ The WECC regional variance is not reproduced herein as it has not been substantively modified from the currently enforceable VAR-001-3 regional variance. Only non-material changes have been made to reference the replacement of VAR-001-4, Requirements R4 and R5, rather than VAR-001-3, Requirements R3 and R5.

evaluating VAR-001-3, Requirement R1, the standard drafting team concluded that because controlling and monitoring voltage levels and MVar flows is already required by the Transmission Operations (“TOP”) group of Reliability Standards, it should not be duplicated in proposed Reliability Standard VAR-001-4. Specifically, currently effective Reliability Standard TOP-004-2, Requirement R6 also requires “Transmission Operators, individually and jointly with other Transmission Operators, [to] develop, maintain, and implement formal policies and procedures to provide for transmission reliability.” That requirement specifies that the “policies and procedures shall address the execution and coordination of activities that impact inter- and intra-Regional reliability, including,” among other things, “monitoring and controlling voltage levels and real and reactive power flows.”

Additionally, currently effective TOP Reliability Standards require that Transmission Operators plan to meet SOLs and IROLs (TOP-002-2.1b, Requirement R10) and operate within SOLs and IROLs (TOP-004-2, Requirement R1).²⁵ As stated in the NERC Glossary, a SOL is defined as:

the value (such as MW, MVar, Amperes, Frequency or Volts) that satisfies the most limiting of the prescribed operating criteria for a specified system configuration to ensure operation within acceptable reliability criteria. [SOLs] are based upon certain operating criteria. These include, but are not limited to: [1] Facility Ratings (Applicable pre- and post-Contingency equipment or facility ratings); [2] Transient Stability Ratings (Applicable pre- and post-Contingency Stability Limits); [3] Voltage Stability Ratings (Applicable pre- and post-Contingency Voltage Stability); and [4] System Voltage Limits (Applicable pre- and post-Contingency Voltage Limits).²⁶

²⁵ Reliability Standard FAC-014-2, Requirement R2 requires a Transmission Operator to establish SOLs (as directed by its Reliability Coordinator) for its portion of the Reliability Coordinator Area that are consistent with its Reliability Coordinator’s SOL Methodology.

²⁶ An IROL is defined in the NERC Glossary as “[a] SOL that, if violated, could lead to instability, uncontrolled separation, or Cascading outages that adversely impact the reliability of the Bulk Electric System” (footnote omitted).

Accordingly, to meet the obligations under Reliability Standards TOP-002-2.1b, Requirement R10 and TOP-004-2, Requirement R1 to plan to meet and operate within SOLs and IROLs, a Transmission Operator is required to monitor and control voltage levels and MVar flows. Failure to do so could lead to a violation of these requirements.

Similarly, monitoring and controlling voltage and MVar flows is fundamental to complying with TOP-004-2, Requirements R2 and R3, which require a Transmission Operator to operate to protect against instability, uncontrolled separation, or cascading outages from (1) the most severe single contingency (Requirement R2), and (2) multiple outages, as specified by its Reliability Coordinator (Requirement R3). Failure to monitor and control voltage and MVar flows could result in a violation of these requirements.

Certain of the TOP Reliability Standards are currently being modified as part of a standards development project at NERC. While certain language and obligations from the existing TOP Reliability Standards may change, the obligation to monitor and control voltage levels and reactive flows will remain. Specifically, as proposed, draft Reliability Standards TOP-001-3 and TOP-002-4 would collectively require Transmission Operators to plan to meet and operate within SOLs and IROLs.²⁷ In addition, those draft Reliability Standards would require each Transmission Operator to (1) monitor facilities within its area and neighboring areas to maintain reliability in its area, and (2) perform a Real-time Assessment at least once every 30 minutes. To comply with these obligations, Transmission Operators must monitor and control voltage, as discussed above.

²⁷ As of the date of this filing, proposed Reliability Standards TOP-001-3 and TOP-002-4 have been posted for an initial comment period and ballot, which is scheduled to close on July 2, 2014.

Because controlling and monitoring voltage and MVar flows is covered elsewhere, the standard drafting team modified VAR-001-4, Requirement R1 to only require that Transmission Operators (1) specify a system voltage schedule as part of its plan to operate with SOLs and IROLs, and (2) provide such schedules to adjacent Transmission Operators and applicable Reliability Coordinators, upon request. The requirement to specify a system voltage schedule as a range or a target value with an associated tolerance band will help ensure that the system maintains an appropriate voltage level in Real-time. The reactive behavior of any particular system depends on a myriad of local conditions which change over time. The intent of Requirement R1 is not to mandate that Transmission Operators set and maintain a static voltage level; rather it is to require Transmission Operators to identify the acceptable voltage limits (either by identifying a range or a target value with an associated tolerance band) that supports reliable operations in Real-time.

The requirement to share the voltage schedule with neighboring Transmission Operators and Reliability Coordinators will allow for increased and improved coordination between neighboring areas. Given the interconnected nature of the Bulk-Electric System, voltage coordination is necessary to help ensure that sufficient Reactive Power is available to support both Real-time and day-ahead operations.

VAR-001-4, Requirement R2

R2. Each Transmission Operator shall schedule sufficient reactive resources to regulate voltage levels under normal and Contingency conditions. Transmission Operators can provide sufficient reactive resources through various means including, but not limited to, reactive generation scheduling, transmission line and reactive resource switching, and using controllable load.

Requirement R2 modifies and consolidates the obligations in currently-effective VAR-001-3, Requirements R2 and R9 to require the scheduling of sufficient reactive resources. As

noted above, the primary factor in maintaining voltage stability is having the appropriate amount of Reactive Power on the system. Proposed Requirement R2 helps ensure that sufficient reactive resources are online and scheduled in Real-time.

VAR-001-3, Requirements R2 and R9 require each Transmission Operator to (1) “acquire sufficient reactive resources . . . within its area to protect the voltage levels under normal and Contingency conditions” and (2) “maintain reactive resources . . . to support its voltage under first Contingency conditions,” respectively. The standard drafting team concluded that these requirements should be combined into a single requirement that more directly states the desired performance for ensuring that sufficient Reactive Power is on the system in Real-time to maintain voltage stability (*i.e.*, to “schedule sufficient reactive resources to regulate voltage levels under normal and Contingency conditions”).²⁸

Requirement R2 also clarifies the language with respect to the manner in which Transmission Operators may schedule sufficient reactive resources (*e.g.*, through reactive generation scheduling, transmission line and reactive resource switching, and using controllable load). Consistent with FERC’s directive in Order No. 693,²⁹ Requirement R2 includes the use of controllable load in the non-exhaustive list of ways to provide sufficient reactive resources. As FERC stated, “in many cases, load response and demand-side investment can reduce the need for reactive power capability in the system.”³⁰

VAR-001-4, Requirement R3

R3. Each Transmission Operator shall operate or direct the Real-time operation of devices to regulate transmission voltage and reactive flow as necessary.

²⁸ VAR-001-4, Requirement R2.

²⁹ Order No. 693 at P 1879.

³⁰ *Id.*

Whereas Requirement R2 obligates the Transmission Operator to ensure that there are sufficient reactive resources online and scheduled, Requirement R3 requires that a Transmission Operator actually provide sufficient voltage support in Real-time by operating its own devices or directing others to do so.

Requirement R3 carries forward the obligation from VAR-001-3, Requirement R7. However, by deleting the phrase “be able to” Requirement R3 creates an affirmative obligation to operate or direct the operation of devices to regulate transmission voltage and reactive flow when necessary.³¹ Additionally, the standard drafting team concluded that there was no need to separately carry forward VAR-001-3, Requirement R8 because it was subsumed in proposed VAR-001-4, Requirement R3.

VAR-001-4, Requirement R4

R4. The Transmission Operator shall specify the criteria that will exempt generators from: 1) following a voltage or Reactive Power schedule, 2) from having its automatic voltage regulator (AVR) in service or from being in voltage control mode, or 3) from having to make any associated notifications.

4.1 If a Transmission Operator determines that a generator has satisfied the exemption criteria, it shall notify the associated Generator Operator.

As discussed below, proposed Reliability Standard VAR-002-3 imposes requirements on the Generator Operator for providing reactive support, including: (1) following the voltage or Reactive Power schedule provided by the Transmission Operator; (2) operating its generator(s) in automatic voltage control mode; and (3) notifying the Transmission Operator of any deviations from the schedule or changes to the status of its voltage control mode. In certain circumstances, however, it may not be necessary or desired for a Generator Operator to comply

³¹ VAR-001-3, Requirement R7 states as follows: “The Transmission Operator shall *be able to* operate or direct the operation of devices necessary to regulate transmission voltage and reactive flow” (emphasis added).

with such requirements. For instance, a Generator Operator may need to be exempt from performance for the following system events, among others: (1) maintenance during shoulder months; (2) scenarios where two generators are located within close proximity and cannot both operate in voltage control mode; and (3) system voltage swings where it would harm reliability if all Generator Operators provided deviation notifications to their respective Transmission Operators at one time.

Requirement R4 carries forward the authority in currently enforceable Reliability Standard VAR-001-3, Requirement R3 for a Transmission Operator to exempt a Generator Operator from having to comply with all or some of its Reactive Power obligations. Proposed Requirement R4 clarifies that a Transmission Operator may exempt a Generator Operator from the following requirements: (1) complying with a voltage or Reactive Power schedule; (2) operating in automatic voltage control mode; and (3) certain notification requirements. Requirement R4 also allows each Transmission Operator to tailor its criteria for exemptions to its area's specific needs.

Further, Requirement R4 simplifies Reliability Standard VAR-001-3, Requirement R3 by removing the need for Transmission Operators to maintain a list of generators in its area that are exempt from following a voltage or Reactive Power schedule. Removal of this list requirement alleviates unnecessary compliance burdens and complexities related to how often to update and maintain these lists. Instead, proposed Requirement R4 focuses on whether the exemption criteria are transparent and whether the Transmission Owner notified the Generator Operator that it is exempt.

VAR-001-4, Requirement R5

R5. Each Transmission Operator shall specify a voltage or Reactive Power schedule (which is either a range or a target value with an associated

tolerance band) at either the high voltage side or low voltage side of the generator step-up transformer at the Transmission Operator's discretion.

- 5.1.** The Transmission Operator shall provide the voltage or Reactive Power schedule (which is either a range or a target value with an associated tolerance band) to the associated Generator Operator and direct the Generator Operator to comply with the schedule in automatic voltage control mode (the AVR is in service and controlling voltage).
- 5.2.** The Transmission Operator shall provide the Generator Operator with the notification requirements for deviations from the voltage or Reactive Power schedule (which is either a range or a target value with an associated tolerance band).
- 5.3.** The Transmission Operator shall provide the criteria used to develop voltage schedules [or] Reactive Power schedule (which is either a range or a target value with an associated tolerance band) to the Generator Operator within 30 days of receiving a request.

Requirement R5 carries forward the obligation from currently-effective Reliability Standard VAR-001-3, Requirement R4 that Transmission Operators must provide a voltage or Reactive Power schedule for each generator and direct the associated Generator Operator to comply with that schedule in automatic voltage control mode unless otherwise instructed or exempted. Proposed Requirement R5 modifies that requirement to clarify that a Transmission Operator may provide the voltage or Reactive Power schedule at either the high or low voltage side of the generator step-up transformer.³² Specifying the location of the voltage or Reactive Power schedule provides a mechanism for the Generator Operator to convert the scheduled voltage to the voltage point it monitors. As discussed below, VAR-002-3, Requirement R2, Part 2.2 clarifies that if the Generator Operator does not monitor voltage at the location specified in the schedule provided by the Transmission Operator, the Generator Operator may use a

³² VAR-003-1, Requirement R4 simply states that the Transmission Operator must “specify a voltage or Reactive Power schedule at the interconnection between the generator facility and the Transmission Operator’s facilities” (footnote omitted).

conversion methodology for converting the scheduled voltage to the voltage point monitored by the Generator Operator.

As with the system level voltage schedule, the voltage or Reactive Power schedule provided to Generator Operators must be a range or a target value with an associated tolerance band. Specifying the voltage schedule as a range or as a target value with an associated tolerance band provides information that Generator Operators can use to set their control devices to appropriate settings to maintain operation within the specified tolerances.

Further, Part 5.2 requires Transmission Operators to provide Generator Operators the notification requirements for deviations from the voltage or Reactive Power schedule. Part 5.2 ensures that Generator Operators are aware of the notification requirements for deviating from the required schedule while also providing Transmission Operators the flexibility to develop notification requirements that best suit their needs.

Lastly, Requirement R5 provides for increased transparency of the Transmission Operator's development of voltage and Reactive Power schedules. Part 5.3 requires Transmission Operators to provide Generator Operators the criteria for developing the voltage or Reactive Power schedule, if requested. Part 5.3 will help ensure that the Transmission Operator has a technical basis for setting the required voltage and Reactive Power schedule that takes into account system needs and any limitations of the specific generator. Providing such criteria may alleviate some operational disputes between Transmission Operators and Generator Operators regarding the technical justifications for the voltage and Reactive Power schedules.

VAR-001-4, Requirement R6

- R6.** After consultation with the Generator Owner regarding necessary step-up transformer tap changes and the implementation schedule, the Transmission Operator shall provide documentation to the Generator

Owner specifying the required tap changes, a timeframe for making the changes, and technical justification for these changes.

Requirement R6 updates currently-effective VAR-001-3, Requirement R11 to allow for scheduling consultation. Because an improper tap setting may affect the amount of VARs produced by a generator, the standard drafting team concluded that this requirement needed to be included in proposed Reliability Standard VAR-001-4.

Omitted VAR-001-3 Requirements

Several currently enforceable requirements from Reliability Standard VAR-001-3 have been omitted from proposed Reliability Standard VAR-001-4 because they have been retired (Requirement R5)³³ or are duplicative with other currently enforceable and pending Reliability Standards (existing Requirements R6, R10 and R12). On this last category of omitted requirements:

- VAR-001-3, Requirement R6 is duplicative of currently enforceable TOP-006-2, Requirement R1, which requires that Transmission Operators know the status of all generating and transmission resources, including Reactive Power resources, available for use. In addition, TOP-006-2, Requirement R2 requires, among other things, each Reliability Coordinator, Transmission Operator, and Balancing Authority to monitor applicable real and reactive power flows, voltage, and the status of rotating and static reactive resources, which requires monitoring of power system stabilizers (“PSS”) in areas that rely on PSS equipment. The TOP Reliability Standards currently in development would require each Transmission Owner to monitor Facilities, sub-100 kV facilities, and the status of Special Protection Systems within its area and neighboring areas, as needed to maintain reliability within its Transmission Operator Area.³⁴ This monitoring activity requires Transmission Operators to know the status of Reactive Power resources.

³³ On March 19, 2013, NERC submitted a filing regarding the retirement of requirements in Reliability Standards, including Requirement R5 of VAR-001-2. (retirement of VAR-001-2, Requirement R5, effective January 21, 2014, because it is redundant with the *pro forma* Open Access Transmission Tariff and any resulting reliability gap is addressed by currently enforceable VAR-001-3, Requirement R2). (Currently effective VAR-001-3, Requirement R5 also notes that Requirement R5 will be retired effective January 21, 2014.) Proposed VAR-001-4, Requirement R2 will also achieve the reliability objective envisioned by retired Requirement R5.

³⁴ See draft Reliability Standard TOP-001-3, Requirement R10, available at <http://www.nerc.com/pa/Stand/Pages/Project-2014-03-Revisions-to-TOP-and-IRO-Standards.aspx>.

- VAR-001-3, Requirement R10 is duplicative of currently enforceable TOP-004-2, Requirement R1, which provides that Transmission Operators shall operate within SOLs and IROLs. This would include taking action to correct SOL and IROL violations resulting from reactive resource deficiencies. Additionally, TOP-004-2, Requirement R4 requires Transmission Operators that enter an unknown operating state (*i.e.*, any state for which valid operating limits have not been determined) to restore operations to respect proven reliable power system limits within 30 minutes. The TOP Reliability Standard currently in development will continue to require Transmission Operators to operate within SOLs and IROLs and take action to correct and report such violations.³⁵
- VAR-001-3, Requirement R12 is also duplicative with requirements in TOP-004-2 to take corrective action, including load-shedding, to operate within SOLs and IROLs and prevent voltage collapse. The TOP Reliability Standard currently in development will continue to require Transmission Operators to take action to prevent voltage collapse.³⁶ Additionally, Reliability Standard EOP-003-2 covers plans for load shedding to prevent voltage collapse.

2. Reliability Standard VAR-002-3

Proposed Reliability Standard VAR-002-3 consists of six requirements and is applicable to Generator Operators and Generator Owners. An explanation of each of the six requirements is provided below.

VAR-002-3, Requirement R1

R1. The Generator Operator shall operate each generator connected to the interconnected transmission system in the automatic voltage control mode (with its automatic voltage regulator (AVR) in service and controlling voltage) or in a different control mode as instructed by the Transmission Operator unless: 1) the generator is exempted by the Transmission Operator, or 2) the Generator Operator has notified the Transmission Operator of one of the following:

- That the generator is being operated in start-up,^[FN1] shutdown,^[FN2] or testing mode pursuant to a Real-time communication or a procedure that was previously provided to the Transmission Operator; or
- That the generator is not being operated in automatic voltage control mode or in the control mode that was instructed by the Transmission Operator for a reason other than start-up, shutdown, or testing.

³⁵ See draft Reliability Standard TOP-001-3, Requirements R12–R15.

³⁶ See *id.*

[FN1: Start-up is deemed to have ended when the generator is ramped up to its minimum continuously sustainable load and the generator is prepared for continuous operation.]

[FN2: Shutdown is deemed to begin when the generator is ramped down to its minimum continuously sustainable load and the generator is prepared to go offline.]

Requirement R1 carries forward the obligation in currently effective VAR-002-2b, Requirement R1 for Generator Operators to operate generators in automatic voltage control mode, but modifies the requirement to allow a Generator Operator to operate in a different control mode if instructed by the Transmission Operator. From a reliability perspective, it is beneficial for generators to operate in automatic voltage control mode. Once set in “voltage controlling” mode, the AVR should automatically adjust to voltage swings within its pre-defined voltage band. A different control mode, however, may be appropriate in certain circumstance. For instance, where two large generators are located within close proximity, if both generators operate in voltage control mode it may result in undesirable effects, such as voltage swings due to the units competing to control voltage. In such instances, to improve voltage regulation and stability, it may be beneficial to allow one of the units to be in automatic voltage control mode while directing the other unit to operate in an alternative mode. Proposed Reliability Standard VAR-002-3 therefore provides for a default mode of operation (*i.e.*, automatic voltage control mode) while also providing flexibility for Transmission Operators and Generator Operators to coordinate if a different control mode would be more effective.

Additionally, Requirement R1 modifies currently effective VAR-002-2b, Requirement R1 to add testing as a time when a generator need not operate in automatic voltage control mode or a different mode instructed by the Transmission Operator.

VAR-002-3, Requirement R2

R2. Unless exempted by the Transmission Operator, each Generator Operator shall maintain the generator voltage or Reactive Power schedule^[FN3] (within each generating Facility's capabilities^[FN4]) provided by the Transmission Operator, or otherwise shall meet the conditions of notification for deviations from the voltage or Reactive Power schedule provided by the Transmission Operator.

2.1. When a generator's AVR is out of service or the generator does not have an AVR, the Generator Operator shall use an alternative method to control the generator reactive output to meet the voltage or Reactive Power schedule provided by the Transmission Operator.

2.2. When instructed to modify voltage, the Generator Operator shall comply or provide an explanation of why the schedule cannot be met.

2.3. Generator Operators that do not monitor the voltage at the location specified in their voltage schedule shall have a methodology for converting the scheduled voltage specified by the Transmission Operator to the voltage point being monitored by the Generator Operator.

[FN3: The voltage or Reactive Power schedule is a target value with a tolerance band or a voltage or Reactive Power range communicated by the Transmission Operator to the Generator Operator.]

[FN4: Generating Facility capability may be established by test or other means, and may not be sufficient at times to pull the system voltage within the schedule tolerance band. Also, when a generator is operating in manual control, reactive power capability may change based on stability considerations.]

Requirement R2 carries forward the affirmative obligation from VAR-003-1, Requirement R2 that the Generator Operator maintain the voltage or Reactive Power schedule provided by the Transmission Operator, unless the Transmission Operator exempts the Generator Operator from doing so. Proposed Requirement R2 adds that the Generator Operator need not comply with the schedule if it satisfies the notification requirements for deviations established by the Transmission Operator under Reliability Standard VAR-001-4, Requirement R5, Part 5.2. By removing prescriptive notification requirements for the entire continent and providing

additional flexibility, proposed Requirement R2, together with VAR-001-4, Requirement R5, Part 5.2, allows each Transmission Operator to determine the notification requirements for each of its respective Generator Operators based on system requirements and generator needs.

Additionally, proposed Requirement R2 includes a new Part 2.3 to allow Generator Operators that do not monitor voltage at the location specified in their voltage schedule provided by the Transmission Operator to convert the schedule to the voltage point monitored by the Generator Operator. As noted above, proposed Reliability Standard VAR-001-4, Requirement R5 clarifies that the Transmission Operator may specify the schedule at either the high or low voltage side of the generator step-up transformer. Part 2.3 of proposed VAR-002-3 was included to allow a generator to continue monitoring voltage based on existing equipment, provided it has a methodology for conversion. There are many ways to convert the voltage schedule, including the development of voltage regulation curves for the transformers or the use of straight ratio conversion. This standard provides Generator Operators with the ability to meet a voltage schedule based on metering equipment while providing the necessary voltage support.

VAR-002-3, Requirements R3 and R4

- R3.** Each Generator Operator shall notify its associated Transmission Operator of a status change on the AVR, power system stabilizer, or alternative voltage controlling device within 30 minutes of the change. If the status has been restored within 30 minutes of such change, then the Generator Operator is not required to notify the Transmission Operator of the status change.
- R4.** Each Generator Operator shall notify its associated Transmission Operator within 30 minutes of becoming aware of a change in reactive capability due to factors other than a status change described in Requirement R3. If the capability has been restored within 30 minutes of the Generator Operator becoming aware of such change, then the Generator Operator is not required to notify the Transmission Operator of the change in reactive capability.

Proposed Requirements R3 and R4 separate the notification requirements in currently-effective VAR-002-2b, Requirement R3 into two requirements: (1) for AVR/PSS status changes

(proposed Requirement R3), and (2) for reactive capability changes (proposed Requirement R4). Each of the proposed requirements provides for a 30-minute window to allow a Generator Operator time to resolve an issue before having to notify the Transmission Operator of a change. For example, proposed Requirement R3 limits the notifications required when an AVR goes out of service and quickly comes back in service (*i.e.*, within 30 minutes) because notification of this type of status change provides little to no benefit to reliability. For the same reason, proposed Requirement R3 also removes existing Part 3.1, which requires that the Generator Operator provide an estimate for the expected duration of the status change.

Proposed Requirement R4 also limits the notifications required when a reactive capability change occurs and is quickly restored (*i.e.*, within 30 minutes) because notification of this type of status change provides little to no benefit to reliability. Proposed Requirement R4 improves VAR-002-2b, Requirement R3, which requires notification as soon as the reactive capability change occurs, to allow Generator Operators to report reactive capability changes after they become aware of the change. Proposed Requirement R4 also removes existing Part 3.2, which requires that the Generator Operator provide an estimate for the expected duration of the status change.

VAR-002-3, Requirement R5

R5. The Generator Owner shall provide the following to its associated Transmission Operator and Transmission Planner within 30 calendar days of a request.

5.1. For generator step-up transformers and auxiliary transformers with primary voltages equal to or greater than the generator terminal voltage:

5.1.1. Tap settings.

5.1.2. Available fixed tap ranges.

5.1.3. Impedance data.

Requirement R5 maintains most of currently-effective VAR-002-2b, Requirement R4 because of the importance of accurate tap settings. That is, if the tap setting is not properly set, then the VARs available from a particular generator may be affected. Proposed Requirement R5 removes existing Sub-part 4.1.4, which requires that a Generator Owner provide “[t]he +/- voltage range with step-change in % for load-tap changing transformers.” This percentage information is extraneous because tap settings, available fixed tap ranges and impedance data already are required³⁷ and can be used to calculate the step-change percentage, if needed.

VAR-002-3, Requirement R6

R6. After consultation with the Transmission Operator regarding necessary step-up transformer tap changes, the Generator Owner shall ensure that transformer tap positions are changed according to the specifications provided by the Transmission Operator, unless such action would violate safety, an equipment rating, a regulatory requirement, or a statutory requirement.

6.1. If the Generator Owner cannot comply with the Transmission Operator’s specifications, the Generator Owner shall notify the Transmission Operator and shall provide the technical justification.

Requirement R6 maintains most of currently-effective VAR-002-2b, Requirement R5 due to the importance of accurate tap settings, as explained above. However, Requirement R6 updates VAR-002-2b, Requirement R5 to clarify that the requirement and corresponding part apply to the same functional entity (Generator Owners).³⁸

³⁷ VAR-002-2b, Requirement R4, Sub-parts 4.1.1–4.1.3; VAR-002-3, Requirement R5, Sub-parts 5.1.1–5.1.3.

³⁸ Existing Requirement R5 references “Generator Owner” in Requirement R5 and “Generator Operator” in Part 5.1. Proposed Requirement R6 modifies the reference to “Generator Operator” in Part 5.1 to reference “Generator Owner” in what is now Part 6.1.

C. Proposed VAR-001-4 and VAR-002-3 Satisfy Outstanding FERC Directives

Project 2013-04 was initiated to address outstanding FERC directives from Order Nos. 693 and 724. The following is a discussion of each outstanding directive and the manner in which proposed Reliability Standards VAR-001-4 and VAR-002-3 address them.³⁹

Applicability to Reliability Coordinators: In Order No. 693, FERC directed NERC to modify Reliability Standard VAR-001 to “include reliability coordinators as applicable entities and include a new requirement(s) that identifies the reliability coordinator’s monitoring responsibilities.”⁴⁰ FERC reasoned that because “a reliability coordinator is the highest level of authority overseeing the reliability of the Bulk-Power System it is important to include the reliability coordinator as an applicable entity to assure that adequate voltage and reactive resources are being maintained.”⁴¹ Because the Interconnection Reliability Operations and Coordination (“IRO”) group of Reliability Standards address Reliability Coordinator monitoring functions, the standard drafting team concluded that any additional requirements on the Reliability Coordinator monitoring function regarding voltage should be addressed in the IRO Reliability Standards. There is currently a NERC standards development project, Project 2014-03 – Revisions to TOP and IRO Standards, which is modifying the IRO Reliability Standards. The standard drafting team for that project is considering whether any revisions are necessary to address this directive.⁴² Therefore, NERC does not propose to apply VAR-001-4 to Reliability

³⁹ Since the issuance of Order No. 693, FERC withdrew its directives from paragraphs 1863 and 1869 of Order No. 693 related to the VAR Reliability Standards. *Electric Reliability Organization Proposal to Retire Requirements in Reliability Standards*, 145 FERC ¶ 61,147 at PP 25–26, Att. A (2013).

⁴⁰ Order No. 693 at P 1855.

⁴¹ *Id.*

⁴² Specifically, the drafting team for Project 2014-03 has proposed a new IRO-002-4, Requirement R4, which provides:

continued . . .

Coordinators or develop any additional VAR-001-4 requirements applicable to Reliability Coordinators at this time.

Reactive Power requirements for LSEs: As directed by FERC,⁴³ NERC addressed Reactive Power requirements for LSEs on a comparable basis with purchasing-selling entities in Reliability Standard VAR-001-2, Requirement R5.⁴⁴ Subsequently, FERC approved retirement of the requirement addressing this directive because the directive is effectively addressed in Schedule 2 (Reactive Supply and Voltage Control from Generation or Other Sources Service) of FERC's *pro forma* Open Access Transmission Tariff.⁴⁵ As such, NERC does not propose to address this directive in the proposed Reliability Standards.

Power factor range at the interface between LSEs and the Bulk-Power System: FERC directed NERC to develop a modification to the VAR Reliability Standards "to address the power factor range at the interface between LSEs and the Bulk-Power System."⁴⁶ FERC was concerned that during high loads, if the power factor at the interface between many LSEs and the Bulk-Power System is so low as to result in low voltages at key busses on the Bulk-Power System, then there is risk for voltage collapse. Since the issuance of this directive, however, other Reliability Standards submitted to the applicable governmental authorities address this issue. Specifically, Reliability Standard TPL-001-4, which is subject to future enforcement,

Each Reliability Coordinator shall monitor Facilities within its Reliability Coordinator Area and neighboring Reliability Coordinator Areas to determine any potential [SOL and IROL] exceedances within its Reliability Coordinator Area, including sub-100 kV facilities needed to make this determination and the status of Special Protection Systems in its Reliability Coordinator Area.

⁴³ Order No. 692 at P 1858.

⁴⁴ On March 3, 2011, NERC submitted a filing regarding proposed modifications to Reliability Standards BAL-002-1; EOP-002-3; FAC-002-1; MOD-021-2; PRC-004-2; and VAR-001-2.

⁴⁵ Order No. 788 at P 17.

⁴⁶ Order No. 693 at P 1861.

requires that system models include Real and reactive Load forecasts.⁴⁷ These system model inputs provide the appropriate power factors to be maintained. Additionally, Reliability Standard FAC-001-1 requires that each Transmission Owner and applicable Generator Owner provide a written summary of its plan to achieve the required system performance for “Voltage, Reactive Power, and *power factor control*.”⁴⁸ Because currently enforceable Reliability Standards TPL-001-4 and FAC-001-1 address the appropriate power factors to be maintained, the VAR standard drafting team determined it would be duplicative and unnecessary for reliability purposes to add the same or similar requirements to proposed Reliability Standards VAR-001-4 and VAR-002-3.

Consideration of acceptable ranges of net power factor range: FERC directed NERC to consider the difficulty of reaching “an agreement on acceptable ranges of net power factors at the interfaces where LSEs receive service from the Bulk-Power System because the acceptable range of power factors at any particular point on the electrical system varies based on many location-specific factors.”⁴⁹ The standard drafting team considered this directive carefully and determined that it has been addressed by the interconnection process and related agreements, as well as by currently enforceable Reliability Standards TPL-001-4 and FAC-001-1, as discussed above. Therefore, the standard drafting team did not include any additional language to proposed Reliability Standards VAR-001-4 and VAR-002-3 to address this directive.

Detailed and definitive requirement on established limits and sufficient reactive resources: FERC directed NERC to “include more detailed and definitive requirements on ‘established limits’ and ‘sufficient reactive resources’ and identify acceptable margins (*i.e.*,

⁴⁷ TPL-001-4, Requirement R1, Part 1.1.4, available at <http://www.nerc.com/files/TPL-001-4.pdf>.

⁴⁸ See FAC-001-1, Requirement R3, Part 3.1.9, available at <http://www.nerc.com/files/FAC-001-1.pdf> (emphasis added).

⁴⁹ Order No. 693 at PP 1860, 1862.

voltage and/or reactive power margins) above voltage instability points to prevent voltage instability and to ensure reliable operation.”⁵⁰ FERC, in part, was addressing concerns that the Transmission Operator should be required to have a technical basis for setting the required voltage schedule that takes into account system needs and any limitations of the specific generator.⁵¹ Proposed Reliability Standard VAR-001-4 addresses this concern by requiring Transmission Operators to (1) share their system voltage schedules with their Reliability Coordinators and adjacent Transmission Operators (Requirement R1, Part 1.1), and (2) provide Generator Operators the criteria used to develop generator-specific voltage and Reactive Power schedules (Requirement R5, Part 5.3). This increased transparency will help ensure that Transmission Operators have a technical basis for setting system-wide and generator specific voltage and Reactive Power schedules that takes into account system needs and any limitations of the specific generator.

Additionally, FERC stated that “the Reliability Standard would benefit from having more defined requirements that clearly define what voltage limits are used and how much reactive resources are needed to ensure voltage instability will not occur under normal and emergency conditions.”⁵² Currently enforceable FAC and TOP Reliability Standards, however, address this directive by requiring entities to develop methodologies for establishing SOLs and IROLs that include detailed and definitive requirements for voltage limits and margins. Specifically, Reliability Standard FAC-011-2, Requirement R1 requires the Reliability Coordinator to have a documented methodology for use in developing SOLs (the “SOL Methodology”) within its

⁵⁰ *Id.* at P 1868.

⁵¹ *See id.* at P 1864.

⁵² *Id.* at P 1870.

Reliability Coordinator Area for use in the operations horizon.⁵³ Among other things, the SOL Methodology must include a requirement that SOLs provide BES performance consistent with maintaining voltage stability.⁵⁴

Reliability Standard FAC-014-2 then requires (1) each Reliability Coordinator to ensure that SOLs, including IROLs, for its Reliability Coordinator Area are established and consistent with its SOL Methodology, and (2) each Transmission Operator to establish SOLs (as directed by its Reliability Coordinator) for its portion of the Reliability Coordinator Area that are consistent with its Reliability Coordinator’s SOL Methodology.

These FAC Reliability Standards operate in tandem with the TOP Reliability Standards, which, as discussed above, require that each Transmission Operator plan to meet and operate within SOLs and IROLs. The standard drafting team determined that these currently enforceable FAC and TOP Reliability Standards collectively provide sufficient detail on “established limits” and margins, and it was unnecessary to include any additional definitive and detailed requirements in VAR-001-4 or VAR-002-3 to address voltage instability and ensure reliable operations. The standard drafting team determined, however, that because acceptable voltage limits and the level of sufficient Reactive Power necessary to maintain voltage depends on the

⁵³ Reliability Standard FAC-010-2.1 requires the Reliability Coordinator to have a documented SOL Methodology for use in the planning horizon.

⁵⁴ Specifically, FAC-011-2, Requirement R2 provides that:

[t]he Reliability Coordinator’s SOL Methodology shall include a requirement that SOLs provide BES performance consistent with the following:

R2.1. In the pre-contingency state, the BES shall demonstrate transient, dynamic and ***voltage stability***; all Facilities shall be within their Facility Ratings and within their thermal, voltage and ***stability limits***. . . .

R2.2. [T]he system shall demonstrate transient, dynamic and ***voltage stability***; all Facilities shall be operating within their Facility Ratings and within their thermal, ***voltage and stability limits***; and Cascading or uncontrolled separation shall not occur.

(Emphasis added.)

unique characteristics of each system, the proposed Reliability Standards cannot dictate a specific, “one-size-fits-all” approach to determining what constitutes a sufficient level of Reactive Power. Rather, the SOL Methodologies developed by Reliability Coordinators under FAC-011-2 will provide the necessary detail tailored to the needs of the system in question.

Periodic voltage stability analysis: FERC directed NERC to include a requirement to “perform voltage stability analysis periodically, using online techniques where commercially-available, and offline simulation tools where online tools are not available, to assist real-time operations.”⁵⁵ FERC stated that “[t]he ERO should consider the available technologies and software as it develops this modification to VAR-001-1 and identify a process to assure that the Reliability Standard is not limiting the application of validated software or other tools.”⁵⁶ The standard drafting team concluded that requiring periodic voltage stability analysis in proposed VAR-001-4 was duplicative of requirements in the TOP group of Reliability Standards. Specifically, period voltage stability analysis is already required to comply with Reliability Standards TOP-002-2.1b, Requirements R10⁵⁷ and R11,⁵⁸ TOP-004-2, Requirement R6,⁵⁹ and

⁵⁵ Order No. 693 at P 1875.

⁵⁶ *Id.*

⁵⁷ Reliability Standard TOP-002-2.1b, Requirement R10 provides that “[e]ach Balancing Authority and Transmission Operator shall plan to meet all [SOLs] and [IROLs].”

⁵⁸ Reliability Standard TOP-002-2.1b, Requirement R11 provides that the “Transmission Operator shall perform seasonal, next-day, and current-day Bulk Electric System studies to determine SOLs.” The requirement also specifies that the “Transmission Operator shall update these Bulk Electric System studies as necessary to reflect current system conditions; and shall make the results of Bulk Electric System studies available to the Transmission Operators, Balancing Authorities (subject to confidentiality requirements), and to its Reliability Coordinator.”

⁵⁹ TOP-004-2, Requirement R6 provides that “Transmission Operators, individually and jointly with other Transmission Operators, shall develop, maintain, and implement formal policies and procedures to provide for transmission reliability. These policies and procedures shall address the execution and coordination of activities that impact inter- and intra-Regional reliability, including . . . [m]onitoring and controlling voltage levels and real and reactive power flows.

TOP-006-2, Requirement R2.⁶⁰ Each of these existing Reliability Standards requires active planning and monitoring to operate within SOLs. Because periodic voltage stability analysis is an inherent component of these monitoring requirements, particularly TOP-002-2.1b, Requirement R11, the standard drafting team did not propose to duplicate these requirements in proposed Reliability Standards VAR-001-4 and VAR-002-3. As noted above, the TOP Reliability Standards currently in development propose to carry forward the obligation to plan to meet and operate within SOLs and IROLs. Further, draft Reliability Standard TOP-002-4, Requirement R1 would require Transmission Operators to perform an Operational Planning Analysis that will allow it to assess whether its planned operations for the next day within its Transmission Operator Area will exceed any of its SOLs.⁶¹ An Operational Planning Analysis would include a voltage stability analysis to assist Real-time operations.

NERC is not proposing to modify its Reliability Standards to require that entities perform periodic voltage stability analyses using online techniques where commercially-available or offline simulation tools where online tools are not available. From a Reliability Standards perspective, the goal is to ensure that relevant entities perform periodic voltage stability analyses in a manner that helps maintain reliable operation in Real-time, not to limit or dictate the techniques or tools used to perform the analysis. An entity may perform the analysis using online techniques or offline simulation tools based on their availability and effectiveness. To

⁶⁰ TOP-006-2, Requirement R2 requires that “[e]ach Reliability Coordinator, Transmission Operator, and Balancing Authority shall monitor applicable transmission line status, real and reactive power flows, voltage, load-tap-changer settings, and status of rotating and static reactive resources.”

⁶¹ The term “Operational Planning Analysis” is proposed to be modified as follows:

An evaluation of projected system conditions to assess anticipated (pre-Contingency) and potential (post-Contingency) conditions for next-day operations. The evaluation shall reflect inputs including, but not limited to, load forecasts; generation output levels; Interchange; known Protection System and Special Protection System status or degradation; Transmission outages; generator outages; Facility Ratings; and identified phase angle and equipment limitations.

comply with the TOP Reliability Standards, however, the entity must show that it performed a voltage stability analysis using techniques and/or tools designed to assess voltage stability effectively.

Controllable load: FERC directed NERC to include controllable load as a reactive resource.⁶² As noted above, proposed Reliability Standard VAR-001-4, Requirement R2 addresses this directive as controllable load is included as a “sufficient reactive resource.”

VAR-002 non-compliance window: FERC directed NERC to consider modifying VAR-002 to add a time frame associated with an “incident” of non-compliance with VAR-002.⁶³ The standard drafting team considered modifications to VAR-002, but could not reach consensus on establishing, or developing guidelines for defining, a continent-wide time frame that would apply to all generators under VAR-002. Rather, the directive was addressed in an equally effective and efficient manner in proposed Reliability Standard VAR-001-4, Requirement R5, which requires that each Transmission Operator provide its Generator Operators with applicable voltage or Reactive Power schedules and notification requirements for deviations from those schedules. This approach provides the necessary flexibility to each Transmission Operator to define time frames based on its unique system assessments and tailor deviation notifications to the voltage constraints experienced in a particular area.

Technically sound voltage schedules: In Order No. 724, FERC remanded to NERC an interpretation of VAR-001-1, Requirement R4 to ensure voltage schedules “reflect sound engineering, as well as operating judgment and experience.”⁶⁴ To address this directive, Requirement R5, Part 5.3 requires a Transmission Operator, upon request, to provide the

⁶² Order No. 693 at P 1879.

⁶³ *Id.* at PP 1883, 1885.

⁶⁴ Order No. 724 at P 49.

Generator Operator the technical support for how a voltage schedule and an associated tolerance band was established. This increased transparency will help ensure that the schedules reflect sound engineering and operating judgment.

D. Enforceability of the Proposed Reliability Standards

Proposed Reliability Standards VAR-001-4 and VAR-002-3 include VRFs and VSLs. The VRFs and VSLs guide how NERC will enforce the requirements of the proposed Reliability Standards and comport with NERC and FERC guidelines related to their assignment. Exhibit E provides a detailed review of the VRFs and VSLs, as well as analysis on how the VRFs and VSLs were determined using the NERC and FERC guidelines.

The proposed Reliability Standards also include measures that support each requirement promulgated thereunder by clearly identifying what is required for compliance and how the requirement will be enforced. These measures help ensure that the requirements will be enforced in a clear, consistent and non-preferential manner and without prejudice to any party.

V. EFFECTIVE DATE

As described in the Implementation Plan attached hereto as Exhibit B, proposed Reliability Standards VAR-001-4 and VAR-002-3 and the retirement of VAR-001-3 and VAR-002-2b will be effective on the first day of the first calendar quarter after the date that the standard is approved by an applicable governmental authority or as otherwise provided for in a jurisdiction where approval by an applicable governmental authority is required for a standard to go into effect. Where approval by an applicable governmental authority is not required, VAR-001-4 and VAR-002-3 shall become effective on the first day of the first calendar quarter after the date the standard is adopted by the NERC Board of Trustees or as otherwise provided for in that jurisdiction. The proposed implementation period will provide sufficient time for responsible entities to develop or modify their processes to transition from compliance with

existing Reliability Standards VAR-001-3 and VAR-002-2b to proposed Reliability Standards VAR-001-4 and VAR-002-3.

Respectfully submitted,

/s/ Shama Elstein

Charles A. Berardesco
Senior Vice President and General Counsel
Holly A. Hawkins
Assistant General Counsel
Shama Elstein
North American Electric Reliability Corporation
1325 G Street, N.W., Suite 600
Washington, DC 20005
(202) 400-3000
charlie.berardesco@nerc.net
holly.hawkins@nerc.net
shama.elstein@nerc.net

Counsel for the North American Electric Reliability Corporation

Date: June 12, 2014

Exhibits A—B and D – G

(Available on the NERC Website at

http://www.nerc.com/FilingsOrders/ca/Canadian%20Filings%20and%20Orders%20DL/Attachments_VA_R-001_VAR-002_filing.pdf)

EXHIBIT C

Reliability Standards Criteria

The discussion below explains how proposed Reliability Standards VAR-001-4 and VAR-002-3 have met or exceeded the Reliability Standards criteria:

- 1. Proposed Reliability Standards must be designed to achieve a specified reliability goal and must contain a technically sound means to achieve that goal.**

The proposed Reliability Standards achieve specific reliability goals. Proposed Reliability Standard VAR-001-4 (Voltage and Reactive Control) ensures that responsible entities monitor, control, and maintain voltage levels, reactive flows, and reactive resources in Real-time to protect equipment and maintain reliable operations. Proposed Reliability Standard VAR-002-3 (Generator Operation for Maintaining Network Voltage Schedules) ensures that responsible entities provide the reactive support and voltage control necessary to protect equipment and maintain reliable operations. Collectively, these proposed Reliability Standards are designed to prevent voltage instability and voltage collapse of the Bulk-Power System.

- 2. Proposed Reliability Standards must be applicable only to users, owners, and operators of the Bulk-Power System, and must be clear and unambiguous as to what is required and who is required to comply.**

Proposed Reliability Standard VAR-001-4 applies to Transmission Operators and, within the Western Interconnection, Generator Operators and is clear and unambiguous as to what is required and who is required to comply. Proposed Reliability Standard VAR-001-4 contains six requirements that clearly and unambiguously state to whom each requirement applies and establishes the applicable entities' compliance obligations.

Proposed Reliability Standard VAR-002-3 applies to Generator Operators and Generator Owners and is clear and unambiguous as to what is required and who is required

to comply. Proposed Reliability Standard VAR-002-3 contains six requirements that clearly and unambiguously state to whom each requirement applies and establishes the applicable entities' compliance obligations.

3. A proposed Reliability Standard must include clear and understandable consequences and a range of penalties (monetary and/or non-monetary) for a violation.

Proposed Reliability Standards VAR-001-4 and VAR-002-3 include Violation Risk Factors (VRFs) and Violation Severity Levels (VSLs) that comport with NERC and FERC guidelines. As explained further in Exhibit F, the severity level assigned to each requirement (for a violation of the requirement) contains a clear explanation of the basis for the assignment, which promotes uniformity and consistency in applying each requirement. The VSLs do not use any ambiguous terminology, thereby supporting uniformity and consistency in the determination of similar penalties for similar violations.

Proposed Reliability Standards VAR-001-4 and VAR-002-3 also include clear and understandable consequences and a range of penalties (monetary and/or non-monetary) for a violation. The ranges of penalties for violations will be based on the applicable VRF and VSL in accordance with the sanctions table and the supporting penalty determination process described in the NERC Sanction Guidelines, Appendix 4B to the NERC Rules of Procedure.

4. A proposed Reliability Standard must identify a clear and objective criterion or measure for compliance, so that it can be enforced in a consistent and non-preferential manner.

The proposed Reliability Standards identify clear and objective criteria or measures for compliance, so that each Reliability Standard can be enforced in a consistent non-preferential manner. Specifically, each proposed Reliability Standard includes a clear statement of its purpose, the rationale behind each requirement, and a statement of the

measures to be used in assessing compliance with each requirement. These provisions help provide clarity on how the requirements will be enforced, and ensure that the requirements will be assessed and enforced in a clear, consistent, and non-preferential manner, without prejudice to any party.

- 5. Proposed Reliability Standards should achieve a reliability goal effectively and efficiently – but do not necessarily have to reflect “best practices” without regard to implementation cost or historical regional infrastructure design.**

The proposed Reliability Standards achieve the reliability goals effectively and efficiently. Collectively, the proposed Reliability Standards improve reliability by ensuring that the Bulk-Power System operates at acceptable voltage levels and that sufficient Reactive Power on the Bulk-Power System exists to provide the voltage support necessary to maintain voltage stability. Proposed Reliability Standard VAR-001-4 improves reliability by requiring set system voltage schedules and voltage coordination among responsible entities. Proposed Reliability Standard VAR-002-3 improves reliability by requiring reactive support and voltage control from responsible entities necessary to protect equipment and maintain reliable operations. In each case, the proposed Reliability Standard provides flexibility to the responsible entities to determine how best to achieve compliance, thereby ensuring reliability without imposing unduly burdensome costs or requiring the adoption of “best practices.”

- 6. Proposed Reliability Standards cannot be “lowest common denominator,” *i.e.*, cannot reflect a compromise that does not adequately protect Bulk-Power System reliability. Proposed Reliability Standards can consider costs to implement for smaller entities, but not at consequences of less than excellence in operating system reliability.**

The proposed Reliability Standards do not reflect a “lowest common denominator” approach. To the contrary, proposed Reliability Standards VAR-001-4 and VAR-002-3 represent a significant improvement over the previous versions as described herein.

7. **Proposed Reliability Standards must be designed to apply throughout North America to the maximum extent achievable with a single Reliability Standard while not favoring one geographic area or regional model. It should take into account regional variations in the organization and corporate structures of transmission owners and operators, variations in generation fuel type and ownership patterns, and regional variations in market design if these affect the proposed Reliability Standard.**

The proposed Reliability Standards apply throughout North America and do not favor one geographic area or regional model. The existing regional variance in VAR-001-3 applicable in the Western Interconnection will continue to be enforced in proposed VAR-001-4.

8. **Proposed Reliability Standards should cause no undue negative effect on competition or restriction of the grid beyond any restriction necessary for reliability.**

The Proposed Reliability Standards do not cause undue negative effect on competition or restriction of the grid. Specifically, neither proposed Reliability Standard VAR-001-4 nor VAR-002-3 restricts the available transmission capability or limit use of the Bulk-Power System in a preferential manner.

9. **The implementation time for the proposed Reliability Standard is reasonable.**

The implementation time and proposed effective dates for the proposed Reliability Standards are just and reasonable and appropriately balance the urgency in the need to implement the Reliability Standards against the reasonableness of the time allowed for those who must comply to develop necessary procedures, software, facilities, staffing, or other relevant capability. The proposed effective dates will allow applicable entities adequate time to ensure compliance with the requirements and are explained in the proposed Implementation Plan, attached as Exhibit B.

10. The Reliability Standard was developed in an open and fair manner and in accordance with the Reliability Standard development process.

The proposed Reliability Standards were developed in accordance with NERC's ANSI-accredited processes for developing and approving Reliability Standards. Exhibit F includes a summary of the Reliability Standards development proceedings, and details the processes followed to develop the proposed Standards.

These processes included, among other things, multiple comment periods, pre-ballot review periods, and balloting periods. Additionally, all drafting team meetings were properly noticed and open to the public. Ballot initiatives achieved a quorum and exceeded the required ballot pool approval levels.

11. NERC must explain any balancing of vital public interests in the development of proposed Reliability Standards.

NERC has identified no competing vital public interests regarding the request for approval of proposed Reliability Standards VAR-001-4 and VAR-002-3. No comments were received indicating that the proposed Reliability Standards conflict with other vital public interests.

12. Proposed Reliability Standards must consider any other appropriate factors.

No other negative factors relevant to whether the proposed Reliability Standards satisfy the Reliability Standards criteria were identified.