

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application	
			B1	B2	B3	B4	B5	B6	B7	B8	B9							
INT	all	Georgia Sys Ops Corp	x		x			x					Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Note: INT-007-1 R1.2 is part of Initial Phase.	x				
INT	all	City of Austin											Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, we recommend that the Standards Drafting Team retire the INT Reliability Standards and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.	x	x		x	
INT-001-3	R1.	Occidental Energy Ventures						X	X		X		OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-001-3	R1.1.	Occidental Energy Ventures						X	X		X		OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-001-3	R2.	Occidental Energy Ventures						X	X		X		OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-001-3	R2.1.	Occidental Energy Ventures						X	X		X		OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-001-3	R2.2.	Occidental Energy Ventures						X	X		X		OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-003-3	R1.	Occidental Energy Ventures						X	X		X		OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application
			B1	B2	B3	B4	B5	B6	B7	B8	B9						
INT-003-3	R1.1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-003-3	R1.1.1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-003-3	R1.1.2.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-003-3	R1.2.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-004-2	R1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-004-2	R2.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-004-2	R2.1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-004-2	R2.2.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-004-2	R2.3.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application
			B1	B2	B3	B4	B5	B6	B7	B8	B9						
INT-005-3	R1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-005-3	R1.1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-006-3	R1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-006-3	R1.1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-006-3	R1.1.1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-006-3	R1.1.2.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-006-3	R1.1.3.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-006-3	R1.2.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-007-1	R1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application
			B1	B2	B3	B4	B5	B6	B7	B8	B9						
INT-007-1	R1.1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-007-1	R1.2.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-007-1	R1.3.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-007-1	R1.3.1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-007-1	R1.3.2.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-007-1	R1.3.3.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-007-1	R1.3.4.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-007-1	R1.4.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-008-3	R1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application
			B1	B2	B3	B4	B5	B6	B7	B8	B9						
INT-008-3	R1.1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-008-3	R1.1.1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-008-3	R1.1.2.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-009-1	R1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-010-1	R1.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-010-1	R2.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-010-1	R3.	Occidental Energy Ventures						X	X		X	OEVC has only addressed the Requirements where OEVC has additional comments to what the Trades have provided.In addition, OEVC believes the following requirements can also be removed:	x				
INT-001-3	R1.	EEI						x	x		x	Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.	x			x	

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application	
			B1	B2	B3	B4	B5	B6	B7	B8	B9							
INT-001-3	R1.1.	EEI						x	x				<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-001-3	R2.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-001-3	R2.1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-001-3	R2.2.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application	
			B1	B2	B3	B4	B5	B6	B7	B8	B9							
INT-003-3	R1.	EEI						x	x				<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-003-3	R1.1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-003-3	R1.1.1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-003-3	R1.1.2.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application	
			B1	B2	B3	B4	B5	B6	B7	B8	B9							
INT-003-3	R1.2.	EEI						x	x				<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-004-2	R1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-004-2	R2.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-004-2	R2.1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	



Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application		
			B1	B2	B3	B4	B5	B6	B7	B8	B9								
INT-004-2	R2.2.	EEI						x	x					Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.	x			x	
INT-004-2	R2.3.	EEI						x	x					Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.	x			x	
INT-005-3	R1.	EEI						x	x					Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.	x			x	
INT-005-3	R1.1.	EEI						x	x					Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.	x			x	

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application	
			B1	B2	B3	B4	B5	B6	B7	B8	B9							
INT-006-3	R1.	EEI						x	x				<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-006-3	R1.1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-006-3	R1.1.1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-006-3	R1.1.2.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application	
			B1	B2	B3	B4	B5	B6	B7	B8	B9							
INT-006-3	R1.1.3.	EEI						x	x				<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-006-3	R1.2.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-007-1	R1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-007-1	R1.1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application	
			B1	B2	B3	B4	B5	B6	B7	B8	B9							
INT-007-1	R1.3.	EEI						x	x				<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-007-1	R1.3.1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-007-1	R1.3.2.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-007-1	R1.3.3.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application	
			B1	B2	B3	B4	B5	B6	B7	B8	B9							
INT-007-1	R1.3.4.	EEI						x	x				<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-007-1	R1.4.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-008-3	R1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-008-3	R1.1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application	
			B1	B2	B3	B4	B5	B6	B7	B8	B9							
INT-008-3	R1.1.1.	EEI						x	x				<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-008-3	R1.1.2.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-009-1	R1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-010-1	R1.	EEI						x	x			x	<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	

Std	Req	Company	Criteria									Full Text	retire	modify	clarify	combine	eliminate application	
			B1	B2	B3	B4	B5	B6	B7	B8	B9							
INT-010-1	R2.	EEl						x	x				<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-010-1	R3.	EEl						x	x				<p>Many of the INT Reliability Standard requirements are very close to duplicative of similar requirements in the BAL Reliability Standards or address commercial matters. As drafted, the INT Reliability Standards include tasks or activities that do little, if anything, to promote the protection the Bulk Electric System. Thus, it is recommended that the Standards Drafting Team retire the INT Reliability Standards, and, as necessary, transfer any requirement that protect reliability to the BAL Reliability Standards.</p>	x			x	
INT-004-2	R1.	ACES Power Mktg										x	<p>INT-004-2 R1 has nothing to do with reliability and should be included in the list of retirements. Failing to reload an Interchange Transaction that was curtailed for a reliability event has no reliability impact. It is a remnant from the NERC Policies that was added at the request of market participants because once transactions were cut, reliability entities did not always allow the transaction to resume once the reliability issue had been addressed. This is strictly a commercial issue.</p>	x				
INT-001-3	R1.	Occidental Power Services, Inc.						x				x	<p>This requirement is at best a business practice of markets (protocol). These schedules can be rejected if not correctly submitted, can be cut if not executed correctly, and the PSE can be penalized if there are offenses. Remove PSE from R1 and applicability section.</p>		x			x

